

NAUSORI, Fiji

WMO: 916830

Lat: 18.043S

Lon: 178.559E

Elev: 5

StdP: 101.26

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	18.1	13.9	9.9	21.8	14.9	10.6	21.9	8.9	24.5	8.2	24.8	0.4	300	0.281

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.8	31.9	26.3	31.2	26.2	30.9	26.1	27.1	30.2	26.7	29.8	26.5	29.4	4.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	28.5	26.1	21.5	28.4	25.8	21.1	28.2	86.0	30.5	84.3	30.2	82.9	29.7	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.1	7.2	6.3	DB	15.4	33.3	1.0	0.8	14.7	33.9	14.1	34.4	13.5	34.8	12.8	35.4
			WB	14.7	28.1	0.9	0.6	14.1	28.5	13.6	28.9	13.1	29.2	12.4	29.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	27.0	27.1	27.1	26.3	24.8	23.9	23.1	23.1	23.7	24.5	25.5	26.4	(6)
(7)		DBStd	1.95	1.00	1.02	0.91	1.06	1.36	1.41	1.43	1.47	1.50	1.46	1.22	1.13	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	5545	526	479	529	489	458	418	407	405	411	449	466	507	(10)
(11)		CDD18.3	2503	268	246	271	239	200	168	149	147	161	191	216	249	(11)
(12)		CDH23.3	18210	2493	2311	2505	1975	1261	852	592	563	757	1134	1583	2184	(12)
(13)	CDH26.7	4177	738	724	764	486	196	96	46	46	77	152	306	547	(13)	
(14)	Wind	WSAvg	2.2	2.1	1.9	1.8	1.9	2.0	2.0	2.1	2.3	2.6	2.6	2.4	2.5	(14)
(15)	Precipitation	PrecAvg	2872	340	287	373	323	226	146	124	134	172	239	245	315	(15)
(16)		PrecMax	3910	652	588	799	944	496	387	285	389	494	588	645	924	(16)
(17)		PrecMin	1922	40	102	111	103	38	18	27	20	12	33	27	70	(17)
(18)		PrecStd	431	155	115	152	157	119	101	60	96	101	152	152	179	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.7	32.2	31.8	30.2	29.7	28.9	29.0	29.4	30.2	31.1	31.9	(19)
(20)			MCWB	26.3	27.0	26.5	26.3	25.6	25.0	24.2	24.3	24.5	25.2	25.8	26.1	(20)
(21)		2%	DB	31.6	31.9	31.5	30.9	29.2	28.6	27.9	27.9	28.5	29.1	30.1	31.0	(21)
(22)			MCWB	26.2	26.3	26.4	26.1	24.9	24.4	23.6	23.5	24.0	24.5	25.2	26.0	(22)
(23)		5%	DB	31.0	31.1	31.0	30.1	28.7	27.9	27.0	27.0	27.5	28.2	29.2	30.1	(23)
(24)			MCWB	26.2	26.2	26.3	25.7	24.5	24.0	23.1	22.9	23.5	24.0	24.8	25.6	(24)
(25)		10%	DB	30.1	30.2	30.2	29.2	27.9	27.0	26.1	26.0	26.7	27.3	28.3	29.2	(25)
(26)			MCWB	25.7	25.9	25.9	25.3	24.0	23.4	22.5	22.5	23.0	23.5	24.3	25.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.7	27.5	27.1	26.4	26.0	25.3	25.1	25.6	26.1	26.6	26.9	(27)
(28)			MCDWB	30.5	30.8	30.3	30.0	28.8	28.3	27.5	27.6	28.0	28.8	29.3	30.0	(28)
(29)		2%	WB	26.9	27.1	27.0	26.6	25.8	25.3	24.6	24.4	24.9	25.4	26.0	26.4	(29)
(30)			MCDWB	30.0	30.3	30.2	29.5	28.1	27.5	26.6	26.6	27.2	27.9	28.8	29.4	(30)
(31)		5%	WB	26.5	26.7	26.6	26.2	25.4	24.7	24.0	23.8	24.4	24.9	25.6	26.1	(31)
(32)			MCDWB	29.4	29.7	29.6	29.0	27.6	26.7	25.9	25.8	26.5	27.2	28.2	28.9	(32)
(33)		10%	WB	26.2	26.3	26.3	25.9	24.8	24.3	23.5	23.3	23.8	24.5	25.1	25.7	(33)
(34)			MCDWB	28.9	29.1	29.1	28.5	26.9	26.1	25.3	25.3	25.8	26.5	27.5	28.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.8	6.6	6.2	6.1	6.0	6.0	5.8	5.5	5.7	6.0	6.2	(35)
(36)			MCDBR	7.7	7.8	7.6	7.4	7.1	7.2	7.1	7.2	6.9	6.8	7.3	7.2	(36)
(37)			MCWBR	3.2	3.3	3.2	3.3	3.3	3.5	3.5	3.6	3.3	3.1	3.3	3.1	(37)
(38)		5% WB	MCDBR	6.8	7.1	6.9	6.6	6.2	6.1	6.0	6.0	6.0	6.0	6.6	6.5	(38)
(39)			MCWBR	3.1	3.3	3.2	3.3	3.3	3.4	3.3	3.4	3.3	3.0	3.2	3.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.383	0.382	0.379	0.377	0.374	0.373	0.363	0.367	0.383	0.384	0.384	0.384	(40)	
(41)		taud	2.615	2.625	2.643	2.637	2.613	2.603	2.617	2.608	2.551	2.566	2.588	2.602	(41)	
(42)		Ebn at Noon	961	952	933	898	865	847	867	895	914	939	954	960	(42)	
(43)		Edh at Noon	103	101	96	91	87	85	85	92	103	106	105	104	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.08	5.78	5.33	4.53	3.99	3.56	3.80	4.24	4.92	5.50	5.83	5.92	(44)	
(45)		RadStd	0.61	0.45	0.35	0.35	0.28	0.26	0.19	0.42	0.43	0.45	0.57	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.21	N/A	N/A	N/A	N/A	+0.25	N/A	N/A	+85	+85	(46)
(47)	Regional (7 neighbors)	+0.18	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+67	+66	(47)

Nomenclature: See separate page