

ILE FUTUNA, Wallis and Futuna

WMO: 917540

Lat: 14.308S

Lon: 178.117W

Elev: 36

StdP: 100.89

Time Zone: 12.00 (E12)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.1	23.5	17.1	12.3	25.3	18.1	13.1	25.4	6.6	25.0	6.1	25.4	2.0	10	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.0	32.3	27.2	31.7	27.0	31.2	26.7	27.9	31.3	27.5	30.8	27.2	30.4	2.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	30.5	26.6	22.2	30.0	26.2	21.7	29.5	89.5	31.5	87.8	31.0	86.3	30.6	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	5.2	4.5	21.7	33.3	0.8	1.1	21.1	34.1	20.6	34.8	20.1	35.5	19.5	36.3		
(5)			19.1	28.5	1.6	0.5	17.9	28.9	17.0	29.2	16.1	29.4	15.0	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	28.1	28.0	28.0	27.8	27.3	26.8	26.2	26.2	26.7	27.4	27.7	(6)	
(7)		DBStd	1.15	1.12	1.08	0.89	0.87	0.90	0.90	0.90	0.90	0.87	0.85	0.95	1.00	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6301	562	504	559	533	536	504	502	502	500	527	522	549	(10)
(11)		CDD18.3	3259	303	271	301	283	277	254	244	244	250	269	272	291	(11)
(12)		CDH23.3	32169	3351	2947	3242	2974	2745	2349	2002	1996	2222	2540	2724	3077	(12)
(13)	CDH26.7	7871	1097	933	1002	836	622	387	243	254	389	534	694	878	(13)	
(14)	Wind	WSAvg	2.2	2.0	2.3	2.0	1.9	2.0	2.2	2.4	2.5	2.6	2.6	1.9	1.8	(14)
(15)	Precipitation	PrecAvg	3312	377	328	338	308	248	189	154	181	236	226	319	406	(15)
(16)		PrecMax	4836	849	997	743	743	628	409	363	713	449	369	732	1157	(16)
(17)		PrecMin	2441	42	76	95	30	33	50	33	30	78	95	110	103	(17)
(18)		PrecStd	538	191	176	152	155	132	101	84	143	97	77	146	245	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	32.9	32.7	32.0	31.4	30.5	29.9	29.9	30.8	31.4	31.8	32.5	(19)
(20)			MCWB	27.5	27.6	27.5	27.0	26.4	26.3	25.8	25.8	26.1	26.5	27.0	27.6	(20)
(21)		2%	DB	32.3	31.9	31.7	31.2	30.6	29.7	29.2	29.2	29.8	30.5	31.1	31.5	(21)
(22)			MCWB	27.2	27.1	27.0	26.7	26.2	25.9	25.3	25.3	25.7	26.1	26.5	26.9	(22)
(23)		5%	DB	31.5	31.2	31.1	30.6	30.1	29.2	28.6	28.7	29.3	29.9	30.5	30.8	(23)
(24)			MCWB	26.9	26.8	26.6	26.5	26.0	25.6	25.0	25.0	25.4	25.9	26.2	26.5	(24)
(25)		10%	DB	30.8	30.6	30.6	30.2	29.5	28.7	28.1	28.2	28.8	29.3	29.9	30.2	(25)
(26)			MCWB	26.6	26.5	26.4	26.2	25.7	25.3	24.6	24.7	25.2	25.5	25.9	26.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.2	28.2	28.2	27.7	27.5	27.1	26.6	26.7	26.7	27.2	27.5	28.1	(27)
(28)			MCDWB	32.0	31.8	31.6	30.8	30.2	29.6	28.9	28.8	29.5	30.3	30.9	31.5	(28)
(29)		2%	WB	27.7	27.7	27.6	27.2	26.9	26.5	26.0	26.0	26.2	26.7	27.0	27.5	(29)
(30)			MCDWB	31.3	31.1	31.0	30.3	29.6	28.8	28.4	28.4	29.0	29.6	30.3	30.7	(30)
(31)		5%	WB	27.3	27.2	27.1	26.8	26.5	26.1	25.6	25.5	25.9	26.2	26.6	27.0	(31)
(32)			MCDWB	30.8	30.5	30.3	29.9	29.1	28.4	27.9	27.9	28.6	29.1	29.7	30.1	(32)
(33)		10%	WB	26.9	26.8	26.7	26.5	26.1	25.7	25.2	25.1	25.5	25.8	26.2	26.5	(33)
(34)			MCDWB	30.2	29.9	29.7	29.4	28.7	27.9	27.3	27.3	28.1	28.6	29.2	29.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	4.9	5.0	4.7	4.1	3.5	3.5	4.0	4.3	4.7	4.7	(35)	
(36)			MCDBR	6.3	5.8	5.8	5.4	5.1	4.3	4.3	4.4	4.9	5.3	5.6	5.7	(36)
(37)			MCWBR	3.1	2.7	2.7	2.5	2.4	2.2	2.3	2.3	2.4	2.6	2.6	2.6	(37)
(38)		5% WB	MCDWB	5.7	5.4	5.5	5.0	4.4	4.0	4.1	4.1	4.6	4.8	5.2	5.3	(38)
(39)			MCWBR	3.0	2.7	2.8	2.5	2.3	2.2	2.2	2.4	2.5	2.5	2.6	2.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.385	0.379	0.377	0.387	0.389	0.401	0.396	0.401	0.409	0.392	0.385	0.387	(40)
(41)		taud		2.640	2.663	2.672	2.639	2.619	2.560	2.567	2.551	2.533	2.588	2.625	2.627	(41)
(42)		Ebn at Noon		958	956	939	896	861	831	846	870	895	933	952	955	(42)
(43)		Edh at Noon		100	97	94	92	88	91	92	99	106	104	101	101	(43)
(44)	All-Sky Solar Radiation	RadAvg		5.89	5.72	5.64	4.98	4.46	4.20	4.47	5.04	5.66	5.91	5.93	5.79	(44)
(45)		RadStd		0.77	0.71	0.41	0.47	0.37	0.28	0.22	0.26	0.30	0.35	0.47	0.43	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page