

BORA BORA, French PolynesiaWMO: **919290**Lat: **16.445S**Lon: **151.752W**Elev: **10**StdP: **14.69**Time Zone: **-10.00 (W10)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	72.4	73.4	60.6	79.0	76.4	62.6	84.9	77.1	28.4	76.6	25.5	77.4	9.3	120	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	9.0	90.5	79.9	89.4	79.3	88.6	79.0	80.9	88.3	80.3	87.5	79.9	86.9	11.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	149.6	85.7	78.2	146.4	85.1	77.7	144.0	84.6	44.5	88.8	43.9	87.9	43.4	87.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.6	22.0	20.1	DB	69.5	91.0	1.5	1.8	68.5	92.2	67.6	93.3	66.8	94.3	65.7	95.6	(4)
(5)			WB	63.9	81.4	1.9	1.2	62.5	82.3	61.4	82.9	60.3	83.6	59.0	84.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	82.4	82.6	83.2	82.8	81.6	80.4	79.5	79.2	79.8	80.6	81.7	82.2
	DBStd	2.33	2.15	2.19	1.93	1.87	1.72	1.74	1.70	1.77	1.80	1.82	1.95	2.18
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11433	1003	912	1030	985	981	911	916	904	894	948	952	997
	CDD65	5958	538	492	565	535	516	461	451	439	444	483	502	532
	CDH74	60571	6009	5550	6586	6078	5337	4243	3774	3498	3798	4554	5296	5848
	CDH80	16738	1938	1845	2355	2015	1379	809	603	582	757	1067	1539	1849
(14) Wind	WSAvg	11.5	11.0	11.5	10.7	10.5	11.2	12.2	12.6	12.4	12.1	11.9	11.2	10.3
(15) Precipitation	PrecAvg	80.2	10.8	9.7	8.3	5.4	5.7	4.1	3.6	3.1	3.3	5.1	9.0	11.8
	PrecMax	106.9	26.7	31.8	24.5	11.9	14.1	14.8	9.3	12.6	9.7	12.2	25.4	22.8
	PrecMin	41.3	3.0	1.6	2.4	0.8	1.6	0.6	0.6	0.4	0.2	0.9	1.1	2.8
	PrecStd	13.9	6.2	5.9	4.5	3.3	2.8	3.2	2.3	2.4	2.2	2.8	5.5	5.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	91.5	91.5	90.8	89.1	87.2	86.6	87.7	88.6	89.4	91.0	90.9
		MCWB	80.4	80.6	80.6	80.5	79.5	77.6	76.5	77.0	77.6	78.5	79.3	80.0
	2%	DB	89.3	89.5	89.8	89.1	87.5	86.0	85.1	85.3	86.1	87.1	88.7	89.1
		MCWB	79.2	79.4	79.8	79.5	78.5	77.0	75.8	75.7	76.4	77.4	78.5	79.1
	5%	DB	88.2	88.3	88.8	88.1	86.4	85.1	84.2	84.2	85.0	86.0	87.4	88.0
		MCWB	78.7	78.9	79.4	79.0	77.8	76.5	75.4	75.1	75.8	76.7	77.9	78.5
	10%	DB	87.1	87.3	87.7	87.1	85.5	84.1	83.3	83.3	84.0	85.0	86.3	86.9
		MCWB	78.3	78.5	79.0	78.5	77.3	75.9	75.0	74.5	75.3	76.2	77.6	78.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	81.3	81.9	81.1	80.6	79.2	78.2	78.3	78.6	79.7	80.5	81.2
		MCDB	88.6	89.4	89.0	88.7	87.2	85.3	84.0	85.4	86.4	86.3	88.2	88.7
	2%	WB	80.2	80.4	80.8	80.3	79.5	78.2	77.2	77.1	77.4	78.5	79.5	80.1
		MCDB	87.5	87.8	88.0	87.5	85.8	84.1	83.1	83.3	84.4	85.3	86.9	87.3
	5%	WB	79.6	79.7	80.1	79.7	78.8	77.4	76.4	76.3	76.8	77.8	78.8	79.4
		MCDB	86.5	86.7	87.0	86.6	84.9	83.2	82.3	82.3	83.4	84.3	86.0	86.3
	10%	WB	78.9	79.1	79.5	79.0	78.1	76.9	75.8	75.6	76.1	77.2	78.2	78.8
		MCDB	85.4	85.7	86.2	85.6	83.9	82.5	81.5	81.4	82.4	83.3	84.8	85.4
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	8.8	9.0	8.4	8.0	7.5	7.7	8.3	8.7	8.7	8.9	8.7
		MCDBR	10.1	9.9	10.0	9.5	8.9	8.3	8.4	8.9	9.8	9.7	10.3	10.1
		MCWBR	4.4	4.2	4.3	4.0	4.0	3.8	3.8	4.0	4.3	4.3	4.3	4.3
	5% WB	MCDBR	9.6	9.3	9.4	9.0	8.4	7.8	8.1	8.5	9.1	9.3	9.6	9.6
		MCWBR	4.5	4.4	4.4	4.2	4.1	3.9	3.9	4.2	4.3	4.5	4.4	4.4
(40) Clear-Sky Solar Irradiance	taub	0.382	0.381	0.379	0.382	0.377	0.370	0.368	0.369	0.384	0.377	0.382	0.384	(40)
	taud	2.632	2.638	2.640	2.641	2.641	2.640	2.633	2.622	2.580	2.612	2.620	2.627	(41)
	Ebn at Noon	305	303	297	285	275	272	275	284	291	300	303	305	(42)
	Edh at Noon	32	32	30	29	27	26	27	29	32	32	32	32	(43)
(44) All-Sky Solar Radiation	RadAvg	1922	1912	1889	1657	1447	1364	1442	1657	1883	2024	2069	1967	(44)
	RadStd	187	210	106	130	87	72	60	84	68	126	132	225	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page