

TAHITI, French Polynesia

WMO: 919380

Lat: 17.554S

Lon: 149.607W

Elev: 2

StdP: 101.31

Time Zone: -10.00 (W10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.1	21.0	14.2	10.1	22.8	15.5	11.0	23.3	11.5	24.9	10.3	25.3	1.9	100	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.3	32.1	26.0	31.8	25.8	31.2	25.6	26.8	30.7	26.6	30.5	26.3	30.2	3.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.2	29.7	25.2	20.3	29.4	25.0	20.1	29.3	84.4	31.0	83.1	30.7	81.8	30.1	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.3	7.3	DB	18.5	33.0	0.9	0.6	17.9	33.5	17.3	33.8	16.8	34.1	16.2	34.5	
			WB	15.3	27.4	1.1	0.7	14.5	27.9	13.9	28.3	13.3	28.7	12.5	29.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	27.6	27.7	28.0	27.8	26.9	26.0	25.5	25.3	25.7	26.2	27.1	27.4
	DBStd	1.33	0.98	0.95	0.86	0.82	0.89	1.01	0.99	1.08	0.94	0.91	0.89	1.01
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6123	547	497	558	534	523	481	482	474	472	503	512	540
	CDD18.3	3082	288	263	300	284	265	231	223	216	222	245	262	282
	CDH23.3	29642	3129	2869	3341	3021	2493	1883	1676	1604	1788	2197	2672	2967
Wind	WSAvg	3.0	3.2	3.1	2.8	2.6	2.7	2.9	2.9	3.2	3.0	3.0	2.9	3.2
	PrecAvg	1661	287	239	177	121	99	67	54	46	49	95	132	286
	PrecMax	2484	956	759	941	598	432	271	173	169	200	293	365	785
	PrecMin	759	46	21	5	6	3	0	0	0	0	4	5	20
	PrecStd	372	209	183	168	125	85	57	41	37	47	66	93	191
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.2	32.2	32.2	31.2	30.9	30.2	30.2	30.2	30.9	31.4	32.1
		MCWB	25.9	26.0	26.3	25.8	25.4	24.9	24.1	24.1	23.8	24.7	25.4	26.1
	2%	DB	31.8	31.9	32.0	31.8	30.9	30.1	29.8	29.4	29.9	30.1	31.0	31.2
		MCWB	25.7	25.9	26.1	25.7	25.3	24.5	24.1	23.8	23.9	24.5	25.3	25.7
	5%	DB	31.1	31.2	31.4	31.1	30.2	29.8	29.1	29.0	29.2	29.8	30.3	30.9
		MCWB	25.5	25.7	25.9	25.6	24.9	24.3	23.7	23.6	23.7	24.4	24.9	25.6
	10%	DB	30.6	30.8	31.0	30.8	29.9	29.1	28.8	28.3	28.9	29.1	30.0	30.2
		MCWB	25.3	25.6	25.8	25.5	24.7	23.9	23.5	23.1	23.5	24.0	24.8	25.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.2	27.3	26.7	26.6	25.8	25.4	25.4	25.4	26.1	26.6	27.1
		MCDB	30.8	30.6	31.4	30.9	30.3	29.5	29.2	29.0	29.0	29.6	30.6	30.9
	2%	WB	26.5	26.7	26.7	26.5	26.1	25.3	24.7	24.7	24.7	25.5	26.0	26.5
		MCDB	30.3	30.4	30.9	30.6	29.8	29.2	28.6	28.4	28.6	29.2	29.9	30.3
	5%	WB	26.1	26.3	26.4	26.1	25.6	24.8	24.3	24.2	24.3	25.0	25.5	26.1
		MCDB	29.9	30.2	30.5	30.3	29.3	28.8	28.2	28.0	28.3	28.9	29.5	29.9
	10%	WB	25.7	25.9	26.0	25.7	25.1	24.3	23.9	23.7	23.8	24.5	25.1	25.6
		MCDB	29.5	29.9	30.2	29.8	28.9	28.3	27.8	27.6	27.9	28.3	29.1	29.4
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.0	6.3	6.3	6.3	6.6	6.7	6.6	6.5	6.2	6.0	5.8
		MCDBR	6.6	6.6	6.7	6.7	6.7	7.0	7.0	6.9	6.8	6.6	6.4	6.3
		MCWBR	3.5	3.6	3.6	3.6	3.6	3.8	3.8	4.0	3.7	3.7	3.5	3.5
	5% WB	MCDBR	5.9	6.1	6.3	6.3	6.2	6.5	6.4	6.4	6.3	6.1	6.0	5.9
		MCWBR	3.5	3.5	3.6	3.6	3.6	3.8	3.8	3.9	3.7	3.7	3.6	3.5
Clear-Sky Solar Irradiance	taub		0.383	0.382	0.380	0.382	0.375	0.366	0.363	0.364	0.381	0.376	0.382	0.385
	taud		2.621	2.629	2.629	2.626	2.634	2.640	2.635	2.622	2.575	2.603	2.612	2.618
	Ebn at Noon		961	952	933	894	865	856	869	899	917	947	956	959
	Edh at Noon		102	101	97	92	85	82	84	91	101	102	103	103
All-Sky Solar Radiation	RadAvg		6.05	5.99	5.81	5.01	4.34	4.08	4.33	5.00	5.70	6.17	6.44	6.08
	RadStd		0.57	0.63	0.30	0.38	0.29	0.23	0.16	0.23	0.28	0.39	0.36	0.69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
Station Only	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page