

PITCAIRN, Pitcairn

WMO: 919640

Lat: 25.0734S

Lon: 130.1050W

Elev: 869

StdP: 14.24

Time Zone: -8.00 (W08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	58.7	59.6	47.5	50.1	60.7	49.1	53.3	61.4	39.6	61.7	32.1	65.9	14.1	160	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.5	80.3	74.3	79.3	73.9	78.5	73.5	76.0	78.4	75.2	77.8	74.5	77.1	10.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.2	136.7	77.4	74.3	132.5	76.6	73.6	129.3	76.0	40.0	78.6	39.2	78.0	38.5	77.3	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.1	26.6	23.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.7	74.1	75.0	75.0	72.2	69.5	67.6	65.7	64.7	65.3	67.3	68.9	71.8
	DBStd	4.29	1.77	1.75	1.91	2.31	2.37	2.57	2.62	2.68	2.54	2.59	2.11	2.27
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	108	0	0	0	0	1	7	24	38	27	10	1	0
	CDD50	7201	748	701	774	667	604	528	487	457	460	535	566	674
	CDD65	1835	283	281	309	217	140	85	46	30	36	81	118	209
	CDH74	3162	755	889	973	273	21	1	0	0	0	3	18	229
	CDH80	40	6	17	16	1	0	0	0	0	0	0	0	0
Wind	WSAvg	11.9	10.7	10.8	10.7	11.4	12.5	12.2	12.7	12.8	12.0	12.9	12.1	11.9
Precipitation	PrecAvg	66.2	4.7	5.5	4.4	5.0	4.6	6.4	5.8	5.2	5.3	5.9	4.9	6.2
	PrecMax	103.9	17.0	19.5	13.3	12.2	12.8	18.1	16.5	14.5	13.8	21.3	14.4	24.4
	PrecMin	23.9	0.2	0.2	0.7	0.6	0.4	0.4	1.4	0.6	1.3	0.7	0.4	0.2
	PrecStd	19.1	3.6	4.1	3.2	2.6	2.8	4.1	3.7	3.6	3.3	4.4	3.3	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.7	81.9	81.7	79.7	75.9	73.9	72.3	72.7	72.9	74.5	75.8	78.3
		MCWB	74.8	75.1	75.0	73.5	71.6	71.0	68.9	69.4	68.8	70.4	69.5	73.0
	2%	DB	79.3	80.5	80.2	77.9	74.6	72.8	71.2	71.1	71.5	73.2	74.4	77.3
		MCWB	73.5	74.2	74.5	73.1	71.2	70.3	68.3	68.5	68.2	69.6	69.5	72.5
	5%	DB	78.6	79.3	79.3	76.8	73.7	71.9	70.4	69.9	70.2	72.0	73.3	76.3
		MCWB	72.9	73.9	74.3	72.5	70.6	69.7	67.8	67.8	67.6	68.9	69.3	72.0
	10%	DB	77.8	78.4	78.3	75.6	72.8	71.1	69.5	68.9	69.1	70.9	72.2	75.3
		MCWB	72.6	73.6	73.8	71.7	70.0	69.0	67.2	66.9	66.7	68.2	68.8	71.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	76.5	77.7	75.6	73.7	72.4	71.0	70.6	70.4	72.2	72.9	75.0
		MCDB	79.4	78.8	79.4	77.0	74.3	72.9	71.3	71.5	71.4	73.0	73.5	77.0
	2%	WB	75.0	75.7	76.4	74.4	72.6	71.4	69.9	69.3	69.3	70.8	71.9	73.7
		MCDB	78.0	78.2	78.6	76.3	73.5	72.1	70.4	70.3	70.3	71.9	72.7	75.5
	5%	WB	74.2	75.1	75.1	73.5	71.8	70.7	68.9	68.4	68.4	69.9	71.0	73.0
		MCDB	76.9	77.7	78.1	75.7	72.8	71.5	69.7	69.5	69.7	71.1	72.1	74.7
	10%	WB	73.5	74.4	74.3	72.6	71.0	69.8	67.9	67.5	67.4	69.0	70.0	72.3
		MCDB	75.9	77.1	77.2	74.8	72.2	70.8	69.0	68.6	68.8	70.4	71.3	74.2
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.5	6.5	5.6	5.0	4.9	5.1	5.5	5.8	5.6	5.8	5.8
		MCDBR	7.3	7.3	7.3	6.7	5.5	5.5	5.8	6.4	6.6	6.5	6.9	6.8
		MCWBR	4.2	4.1	4.2	4.4	4.3	4.3	4.6	5.1	4.9	4.4	4.8	4.6
	5% WB	MCDBR	7.0	6.6	6.9	6.2	4.7	5.0	5.2	5.9	5.8	6.0	5.8	6.1
		MCWBR	4.5	4.3	4.6	4.7	4.3	4.4	4.8	5.4	5.1	4.5	5.4	4.9
Clear-Sky Solar Irradiance	taub	0.352	0.355	0.349	0.351	0.342	0.335	0.335	0.337	0.346	0.345	0.348	0.353	
	taud	2.672	2.662	2.694	2.677	2.682	2.683	2.671	2.661	2.619	2.626	2.646	2.662	
	Ebn at Noon	314	309	302	287	277	272	277	288	298	308	313	314	
	Edh at Noon	31	30	28	26	24	23	24	26	30	31	31	31	
All-Sky Solar Radiation	RadAvg	2189	2090	1860	1435	1131	997	1076	1300	1599	1834	2028	2134	
	RadStd	291	196	150	132	74	68	64	97	125	170	207	179	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page