

PITCAIRN, Pitcairn

WMO: 919640

Lat: 25.0734S

Lon: 130.1050W

Elev: 265

StdP: 98.18

Time Zone: -8.00 (W08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.8	15.3	8.6	7.2	15.9	9.5	7.6	16.3	17.7	16.5	14.4	18.9	6.3	160	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.6	26.8	23.5	26.3	23.3	25.9	23.1	24.4	25.8	24.0	25.5	23.6	25.0	4.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.5	25.2	23.5	18.9	24.8	23.1	18.5	24.4	75.2	25.9	73.3	25.5	71.8	25.2	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.9	11.9	10.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	23.4	23.9	23.9	22.3	20.8	19.8	18.7	18.2	18.5	19.6	20.5	22.1
	DBStd	2.38	0.98	0.97	1.06	1.28	1.31	1.43	1.45	1.49	1.41	1.44	1.17	1.26
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	60	0	0	0	0	1	4	13	21	15	6	1	0
	CDD10.0	4001	416	389	430	371	336	293	271	254	256	297	314	374
	CDD18.3	1019	157	156	172	121	78	47	26	17	20	45	66	116
	CDH23.3	1757	419	494	541	152	12	1	0	0	0	2	10	127
	CDH26.7	22	3	9	9	1	0	0	0	0	0	0	0	0
Wind	WSAvg	5.3	4.8	4.8	4.8	5.1	5.6	5.5	5.7	5.7	5.4	5.8	5.4	5.3
Precipitation	PrecAvg	1681	120	140	113	126	118	162	147	133	135	150	124	157
	PrecMax	2640	433	496	339	309	326	461	420	368	350	541	365	619
	PrecMin	608	5	4	17	16	10	11	35	15	32	17	9	5
	PrecStd	485	91	105	81	66	70	104	94	92	85	111	84	112
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	27.7	27.6	26.5	24.4	23.3	22.4	22.6	22.7	23.6	24.4	25.7
		MCWB	23.8	24.0	23.9	23.1	22.0	21.6	20.5	20.8	20.4	21.3	20.8	22.8
	2%	DB	26.3	26.9	26.8	25.5	23.6	22.7	21.8	21.7	21.9	22.9	23.6	25.2
		MCWB	23.0	23.4	23.6	22.8	21.8	21.3	20.2	20.3	20.1	20.9	20.9	22.5
	5%	DB	25.9	26.3	26.3	24.9	23.1	22.2	21.3	21.1	21.2	22.2	23.0	24.6
		MCWB	22.7	23.3	23.5	22.5	21.4	20.9	19.9	19.9	19.8	20.5	20.7	22.2
	10%	DB	25.4	25.8	25.7	24.2	22.7	21.7	20.9	20.5	20.6	21.6	22.4	24.0
		MCWB	22.6	23.1	23.2	22.0	21.1	20.6	19.6	19.4	19.3	20.1	20.4	22.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.5	24.7	25.4	24.2	23.1	22.5	21.7	21.4	21.3	22.3	22.7	23.9
		MCDB	26.3	26.0	26.3	25.0	23.5	22.7	21.9	21.9	21.9	22.8	23.0	25.0
	2%	WB	23.9	24.3	24.6	23.6	22.6	21.9	21.0	20.7	20.7	21.5	22.2	23.2
		MCDB	25.6	25.7	25.9	24.6	23.0	22.3	21.3	21.3	21.3	22.2	22.6	24.2
	5%	WB	23.5	23.9	24.0	23.1	22.1	21.5	20.5	20.2	20.2	21.0	21.7	22.8
		MCDB	25.0	25.4	25.6	24.3	22.7	21.9	20.9	20.8	20.9	21.7	22.3	23.7
	10%	WB	23.1	23.5	23.5	22.6	21.7	21.0	20.0	19.7	19.7	20.6	21.1	22.4
		MCDB	24.4	25.0	25.1	23.8	22.3	21.6	20.5	20.3	20.4	21.3	21.8	23.4
Mean Daily Temperature Range	5% DB	MDBR	3.7	3.6	3.6	3.1	2.8	2.7	2.8	3.1	3.2	3.1	3.2	3.2
		MCDBR	4.1	4.0	4.0	3.7	3.1	3.0	3.2	3.5	3.7	3.6	3.8	3.8
	5% WB	MCWBR	2.3	2.3	2.4	2.4	2.4	2.4	2.6	2.8	2.7	2.4	2.7	2.5
		MCWBR	3.9	3.7	3.8	3.5	2.6	2.8	2.9	3.3	3.2	3.3	3.2	3.4
Clear-Sky Solar Irradiance	taub		0.352	0.355	0.349	0.351	0.342	0.335	0.335	0.337	0.346	0.345	0.348	0.353
		taud	2.672	2.662	2.694	2.677	2.682	2.683	2.671	2.661	2.619	2.626	2.646	2.662
	Ebn at Noon		991	973	952	906	873	859	872	908	940	972	988	991
		Edh at Noon	97	96	89	83	76	73	76	83	94	98	99	99
All-Sky Solar Radiation	RadAvg		6.90	6.59	5.87	4.53	3.57	3.14	3.39	4.10	5.04	5.78	6.39	6.73
	RadStd		0.92	0.62	0.47	0.41	0.23	0.21	0.20	0.31	0.39	0.54	0.65	0.56

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page