

PORT MORESBY, Papua New Guinea

WMO: 920350

Lat: 9.443S

Lon: 147.220E

Elev: 146

StdP: 14.62

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.8	71.5	61.4	81.9	77.1	63.2	87.2	77.2	26.5	80.5	23.5	81.4	1.7	130	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.8	91.6	77.9	90.6	77.8	89.7	77.8	80.6	87.4	80.0	86.7	79.5	86.1	12.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	151.1	83.6	78.4	148.2	83.2	77.4	143.5	82.6	44.4	87.5	43.7	87.6	43.3	86.6	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 22.8	20.5	18.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	62.7	83.3	3.3	2.8	60.3	85.4	58.4	87.1	56.6	88.6	54.2	90.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.9	82.1	81.8	81.2	81.3	80.7	80.1	79.1	79.1	80.0	81.1	82.0	82.5
	DBStd	2.15	1.88	1.77	1.78	1.48	1.86	1.96	2.05	2.07	1.98	1.89	1.64	1.65
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11280	994	889	968	939	951	902	901	903	901	963	961	1008
	CDD65	5805	529	469	503	489	486	452	436	438	451	498	511	543
	CDH74	54766	5462	4705	4771	4779	4630	3975	3326	3278	3746	4761	5396	5937
(13)	CDH80	17340	2062	1697	1589	1554	1315	987	740	737	938	1452	1937	2332
(14)	Wind	WSAvg	7.1	6.6	6.1	5.2	4.6	6.1	8.1	9.6	9.8	7.9	6.2	6.0
(15) Precipitation	PrecAvg	44.4	8.4	7.1	8.1	4.0	3.2	1.8	1.0	1.1	1.1	1.5	2.3	5.1
	PrecMax	64.1	18.3	14.6	19.6	12.6	15.9	12.3	4.4	5.3	3.7	5.1	11.1	11.5
	PrecMin	25.2	2.1	3.3	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	9.9	3.7	3.4	4.2	2.4	3.0	2.7	1.2	1.2	0.9	1.5	2.7	3.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.0	92.4	91.4	90.0	89.7	89.3	88.2	88.6	89.5	90.0	91.8	93.5
		MCWB	76.8	77.6	77.5	79.3	79.6	77.9	76.7	76.9	77.4	77.7	77.9	78.5
	2%	DB	91.1	91.0	89.7	89.2	88.1	87.8	87.4	86.9	87.8	89.1	90.0	91.5
		MCWB	77.3	77.8	77.9	79.1	78.9	77.7	76.6	76.3	76.9	77.5	77.8	78.2
	5%	DB	89.7	89.4	88.2	87.9	87.2	86.4	85.9	85.7	86.3	87.9	89.3	90.0
		MCWB	77.4	77.7	78.0	78.8	78.4	76.9	76.0	75.6	76.2	77.3	77.7	77.7
	10%	DB	88.2	88.0	87.3	86.9	86.0	85.3	84.2	84.2	85.1	86.6	88.0	89.1
		MCWB	77.5	77.7	77.9	78.3	77.6	76.5	75.0	74.7	75.5	76.7	77.5	77.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	80.6	80.6	81.2	80.8	79.8	79.1	79.4	79.1	79.9	80.6	81.0
		MCDB	88.1	87.8	87.5	87.3	87.0	85.8	84.6	84.2	85.7	87.2	87.8	88.7
	2%	WB	79.8	79.7	79.7	80.1	79.9	79.0	78.0	78.1	78.2	79.0	79.6	80.0
		MCDB	86.9	86.7	86.3	86.3	85.8	84.7	83.9	83.7	84.8	86.1	86.7	87.5
	5%	WB	79.1	79.1	79.1	79.5	79.2	78.3	77.2	77.2	77.5	78.3	79.0	79.2
		MCDB	86.1	85.9	85.5	85.5	84.7	83.9	83.2	83.1	83.9	85.2	86.1	86.5
	10%	WB	78.5	78.5	78.5	79.0	78.7	77.6	76.4	76.4	76.8	77.7	78.4	78.8
		MCDB	85.3	85.1	84.7	84.7	84.0	83.1	82.2	81.9	82.9	84.3	85.3	85.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.3	13.0	12.3	12.3	11.5	11.2	11.1	11.3	11.3	12.3	13.0	13.8
		MCDBR	14.9	15.1	14.0	13.4	12.4	12.3	12.6	12.6	12.1	13.1	14.1	15.3
		MCWBR	4.9	5.3	5.1	5.4	4.9	4.9	4.9	5.1	4.6	5.0	5.1	5.3
	5% WB	MCDBR	13.7	13.6	13.1	12.7	11.6	11.3	11.6	11.7	11.1	12.3	13.1	14.2
		MCWBR	5.4	5.5	5.3	5.4	5.0	5.0	5.1	5.3	4.7	5.2	5.2	5.5
(40) Clear-Sky Solar Irradiance	taub		0.415	0.410	0.415	0.421	0.425	0.419	0.414	0.423	0.437	0.456	0.469	0.455
	taud		2.482	2.491	2.484	2.465	2.452	2.470	2.480	2.446	2.404	2.331	2.300	2.348
	Ebn at Noon		294	294	288	277	266	263	267	272	277	278	276	281
	Edh at Noon		37	37	36	35	34	33	33	36	39	43	44	42
(44) All-Sky Solar Radiation	RadAvg		1701	1744	1629	1571	1441	1328	1407	1564	1685	1901	1911	1858
	RadStd		102	139	85	86	97	110	75	117	130	93	128	147

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page