

PORT MORESBY, Papua New Guinea

WMO: 920350

Lat: 9.443S

Lon: 147.220E

Elev: 45

StdP: 100.79

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.0	21.9	16.4	11.7	25.0	17.3	12.5	25.1	11.8	26.9	10.5	27.4	0.8	130	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.7	33.1	25.5	32.5	25.5	32.1	25.4	27.0	30.8	26.7	30.4	26.4	30.1	5.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.6	28.7	25.8	21.2	28.4	25.2	20.5	28.1	85.3	30.8	83.9	30.9	82.8	30.3	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.2	8.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	17.1	28.5	1.8	1.6	15.7	29.7	14.7	30.6	13.7	31.5	12.3	32.6	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	27.8	27.6	27.3	27.4	27.0	26.7	26.1	26.2	26.7	27.3	27.8	28.1
	DBStd	1.19	1.05	0.99	0.99	0.82	1.03	1.09	1.14	1.15	1.10	1.05	0.91	0.92
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6267	552	494	538	522	528	501	501	502	501	535	534	560
	CDD18.3	3225	294	261	279	272	270	251	242	243	251	277	284	302
	CDH23.3	30426	3034	2614	2651	2655	2572	2208	1848	1821	2081	2645	2998	3298
	CDH26.7	9633	1146	943	883	863	731	548	411	409	521	807	1076	1296
Wind	WSAvg	3.2	3.0	2.7	2.3	2.0	2.7	3.6	4.1	4.3	4.4	3.5	2.8	2.7
Precipitation	PrecAvg	1127	213	180	207	102	81	45	25	27	27	39	58	129
	PrecMax	1627	465	371	498	320	404	313	112	135	93	129	283	291
	PrecMin	639	53	83	1	6	0	0	0	0	0	0	0	3
	PrecStd	251	95	87	107	61	76	69	30	30	24	39	68	80
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	33.6	33.0	32.2	32.1	31.9	31.2	31.5	31.9	32.2	33.2	34.2
		MCWB	24.9	25.3	25.3	26.3	26.4	25.5	24.9	24.9	25.2	25.4	25.5	25.8
	2%	DB	32.8	32.8	32.0	31.8	31.2	31.0	30.8	30.5	31.0	31.7	32.2	33.1
		MCWB	25.2	25.4	25.5	26.2	26.0	25.4	24.8	24.6	25.0	25.3	25.5	25.7
	5%	DB	32.1	31.9	31.2	31.1	30.7	30.2	29.9	29.8	30.2	31.1	31.8	32.2
		MCWB	25.2	25.4	25.5	26.0	25.8	25.0	24.5	24.2	24.5	25.2	25.4	25.4
	10%	DB	31.2	31.1	30.7	30.5	30.0	29.6	29.0	29.0	29.5	30.3	31.1	31.7
		MCWB	25.3	25.4	25.5	25.7	25.3	24.7	23.9	23.7	24.2	24.8	25.3	25.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.0	27.0	27.4	27.1	26.5	26.2	26.3	26.2	26.6	27.0	27.2
		MCDB	31.2	31.0	30.8	30.7	30.6	29.9	29.2	29.0	29.8	30.7	31.0	31.5
	2%	WB	26.5	26.5	26.5	26.7	26.6	26.1	25.6	25.6	25.7	26.1	26.4	26.6
		MCDB	30.5	30.4	30.2	30.2	29.9	29.3	28.8	28.7	29.3	30.1	30.4	30.8
	5%	WB	26.2	26.2	26.1	26.4	26.2	25.7	25.1	25.1	25.3	25.7	26.1	26.2
		MCDB	30.0	30.0	29.7	29.7	29.3	28.8	28.4	28.4	28.8	29.5	30.1	30.3
	10%	WB	25.8	25.8	25.8	26.1	26.0	25.4	24.7	24.6	24.9	25.4	25.8	26.0
		MCDB	29.6	29.5	29.3	29.3	28.9	28.4	27.9	27.7	28.3	29.1	29.6	29.9
Mean Daily Temperature Range	5% DB	MDBR	7.4	7.2	6.9	6.8	6.4	6.2	6.1	6.3	6.3	6.8	7.2	7.7
		MCDBR	8.3	8.4	7.8	7.4	6.9	6.8	7.0	7.0	6.7	7.3	7.8	8.5
		MCWBR	2.7	3.0	2.8	3.0	2.7	2.7	2.7	2.8	2.6	2.8	2.8	2.9
	5% WB	MCDBR	7.6	7.5	7.3	7.1	6.5	6.3	6.4	6.5	6.2	6.8	7.3	7.9
		MCWBR	3.0	3.0	2.9	3.0	2.8	2.8	2.8	2.9	2.6	2.9	2.9	3.1
Clear-Sky Solar Irradiance	taub	0.415	0.410	0.415	0.421	0.425	0.419	0.414	0.423	0.437	0.456	0.469	0.455	
	taud	2.482	2.491	2.484	2.465	2.452	2.470	2.480	2.446	2.404	2.331	2.300	2.348	
	Ebn at Noon	927	927	907	872	838	828	841	859	873	875	871	887	
	Edh at Noon	117	116	114	111	107	103	103	112	122	134	139	133	
All-Sky Solar Radiation	RadAvg	5.36	5.50	5.13	4.95	4.54	4.19	4.43	4.93	5.31	5.99	6.02	5.86	
	RadStd	0.32	0.44	0.27	0.27	0.31	0.35	0.23	0.37	0.41	0.29	0.40	0.46	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page