

HOKITIKA, New Zealand

WMO: 936140

Lat: 42.7131S

Lon: 170.9844E

Elev: 40

StdP: 100.84

Time Zone: 12.00 (NZL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.3	1.3	-4.2	2.7	4.1	-2.8	3.0	4.0	11.7	11.9	10.1	11.5	2.0	140	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.0	21.7	17.7	20.7	17.2	19.9	16.7	18.8	20.4	18.1	19.7	17.5	19.1	3.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.2	19.6	17.5	12.6	18.9	16.8	12.1	18.4	53.5	20.5	51.4	19.6	49.4	19.2	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.7	7.4	-3.2	24.1	3.9	1.8	-6.0	25.5	-8.3	26.6	-10.4	27.6	-13.2	28.9		
(5)			-4.2	19.7	3.6	0.9	-6.8	20.3	-8.9	20.9	-10.9	21.4	-13.5	22.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	15.6	15.9	14.6	12.6	10.6	8.4	7.5	8.3	9.7	10.9	12.2	14.2
	DBStd	3.46	2.10	2.10	2.04	1.98	2.29	2.20	2.01	1.96	1.85	1.85	1.89	2.21
	HDD10.0	266	0	1	1	3	19	59	81	58	27	12	3	1
	HDD18.3	2437	87	72	117	173	239	299	334	311	259	232	184	129
	CDD10.0	877	174	164	143	80	38	10	4	6	18	39	69	131
	CDD18.3	7	3	2	1	0	0	0	0	0	0	0	0	1
	CDH23.3	6	3	1	0	0	0	0	0	0	0	0	0	1
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.1	3.2	3.0	2.8	2.7	2.8	2.8	2.7	2.8	3.3	3.7	3.6	3.5
Precipitation	PrecAvg	2795	238	178	222	216	246	235	216	230	244	267	247	258
	PrecMax	3377	587	370	430	533	502	465	408	515	480	492	482	458
	PrecMin	2337	67	39	41	4	79	78	28	62	96	107	43	50
	PrecStd	288	114	79	94	105	98	94	99	101	92	100	99	116
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	23.0	22.0	19.5	17.9	15.0	14.4	15.4	16.5	17.6	19.5	21.8
		MCWB	18.6	18.3	16.5	14.4	14.0	12.1	10.6	10.4	11.8	12.7	15.1	17.3
	2%	DB	21.7	21.6	20.4	17.9	16.1	13.9	13.3	13.7	14.9	16.2	17.9	20.2
		MCWB	17.9	18.0	16.5	14.6	13.8	12.1	10.6	10.4	11.7	13.0	14.3	16.7
	5%	DB	20.6	20.6	19.4	17.0	15.2	13.2	12.3	12.9	14.1	15.2	16.9	19.1
		MCWB	17.3	17.4	16.2	14.5	13.4	11.6	10.0	10.3	11.5	12.5	13.8	16.0
	10%	DB	19.6	19.9	18.5	16.3	14.5	12.3	11.4	12.0	13.3	14.4	15.9	18.0
		MCWB	16.7	17.0	15.8	14.1	12.8	10.7	9.3	9.9	11.3	12.1	13.3	15.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.0	19.7	18.7	16.9	15.7	13.9	13.1	12.8	13.7	14.8	16.3	18.4
		MCDB	22.4	21.3	19.9	17.7	16.3	14.3	13.4	13.5	14.5	16.1	17.9	20.4
	2%	WB	18.8	18.9	17.9	16.1	14.8	13.0	11.8	11.8	13.1	14.0	15.3	17.5
		MCDB	20.4	20.5	18.9	16.8	15.5	13.5	12.5	12.7	13.8	15.1	16.7	19.0
	5%	WB	18.0	18.2	17.1	15.4	14.0	12.1	10.7	11.0	12.5	13.4	14.6	16.8
		MCDB	19.6	19.9	18.5	16.2	14.8	12.8	11.6	12.1	13.4	14.5	16.0	18.3
	10%	WB	17.3	17.6	16.4	14.5	13.1	11.0	9.7	10.3	11.7	12.8	14.0	16.1
		MCDB	19.0	19.3	17.9	15.7	14.1	11.9	10.9	11.5	12.9	13.9	15.2	17.6
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.0	7.1	7.1	6.8	6.9	7.4	7.3	6.8	6.5	6.5	6.3
		MCDBR	7.6	8.0	8.0	7.7	7.1	7.0	8.1	7.9	7.9	7.4	7.8	7.5
		MCWBR	4.9	5.3	5.1	5.4	5.2	5.4	5.9	5.6	5.6	5.1	5.2	4.9
	5% WB	MCDBR	6.2	6.7	5.8	5.4	5.4	5.1	5.9	6.2	5.7	5.6	5.5	5.7
		MCWBR	4.3	5.0	4.4	4.6	4.7	4.6	5.1	5.1	4.7	4.6	4.3	4.2
Clear-Sky Solar Irradiance	taub	0.344	0.336	0.316	0.306	0.297	0.291	0.281	0.303	0.327	0.334	0.330	0.339	
	taud	2.552	2.592	2.656	2.666	2.650	2.625	2.655	2.608	2.528	2.524	2.560	2.569	
	Ebn at Noon	982	963	940	881	818	784	829	869	910	954	990	993	
	Edh at Noon	105	96	82	69	59	55	58	72	91	102	104	105	
All-Sky Solar Radiation	RadAvg	6.09	5.51	4.13	2.71	1.71	1.33	1.59	2.29	3.31	4.49	5.62	6.08	
	RadStd	0.46	0.42	0.24	0.26	0.14	0.11	0.13	0.15	0.30	0.38	0.57	0.46	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.30	+0.53	N/A	N/A	N/A	N/A	-54	-102	N/A
(47) Regional (3 neighbors)		+0.27	N/A	N/A	N/A	N/A	N/A	-39	N/A	N/A

Nomenclature: See separate page