

PUYSEGUR POINT, New Zealand

WMO: 938050

Lat: 46.156S

Lon: 166.613E

Elev: 144

StdP: 14.62

Time Zone: 12.00 (NZL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.1	39.6	29.5	23.7	41.4	31.6	26.1	42.0	53.6	51.3	47.6	53.1	10.6	40	0.836

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.7	68.7	60.9	66.6	59.8	65.0	58.9	62.7	66.8	61.1	65.0	59.9	63.8	27.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.9	80.3	64.6	59.3	75.7	63.3	57.9	72.1	62.3	28.4	66.9	27.3	65.3	26.4	63.8	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.3	44.5	40.2	35.5	72.8	2.3	2.7	33.8	74.8	32.5	76.3	31.1	77.9	29.5	79.8
			32.7	64.5	2.0	1.9	31.2	65.8	30.0	66.9	28.9	68.0	27.4	69.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	57.0	57.4	56.1	53.5	51.2	47.8	47.2	47.8	49.3	50.2	51.5	54.9	(6)
	DBStd	5.18	3.98	4.05	3.93	3.84	3.94	3.37	3.54	3.40	3.63	3.58	3.81	4.11	(7)
	HDD50	431	0	0	1	10	32	82	101	84	54	40	23	4	(8)
	HDD65	4761	249	215	279	344	428	516	551	533	470	459	405	312	(9)
	CDD50	1152	218	208	189	116	69	16	15	16	34	46	68	157	(10)
	CDD65	6	2	3	1	0	0	0	0	0	0	0	0	0	(11)
	CDH74	1	0	1	0	0	0	0	0	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	17.4	19.2	17.7	17.7	17.6	18.1	16.3	15.4	15.4	17.4	18.3	18.5	17.9	(14)
(15) Precipitation	PrecAvg	93.0	8.4	6.8	8.2	8.5	8.4	7.9	7.3	6.5	7.3	8.1	7.6	6.9	(15)
	PrecMax	112.5	16.4	13.1	16.7	16.8	15.1	14.1	10.9	10.3	12.0	13.2	14.0	11.2	(16)
	PrecMin	62.8	3.0	2.2	3.3	3.4	2.6	3.7	1.7	0.4	2.5	4.0	2.4	1.1	(17)
	PrecStd	11.6	3.0	2.9	3.2	3.7	2.9	2.8	2.2	2.1	2.6	2.6	3.1	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.5	72.4	69.3	65.9	63.7	59.0	58.3	58.6	61.9	63.7	65.4	69.5	(19)
		MCWB	61.8	63.4	60.6	57.5	56.8	53.2	51.5	50.7	52.4	54.7	56.6	60.5	(20)
	2%	DB	68.1	68.7	67.1	63.4	60.8	56.2	55.9	56.2	58.9	60.7	62.3	66.1	(21)
		MCWB	60.9	61.4	60.4	56.2	55.0	51.8	50.1	49.8	52.0	53.5	55.8	58.6	(22)
	5%	DB	65.8	66.2	64.8	61.7	58.9	54.5	54.3	54.3	56.8	58.3	60.1	64.1	(23)
		MCWB	59.8	60.1	59.3	55.9	54.1	51.0	49.5	49.4	50.8	52.7	54.7	57.9	(24)
	10%	DB	63.8	64.2	62.7	59.9	57.1	52.9	52.8	52.8	54.9	56.0	57.9	61.9	(25)
		MCWB	58.6	59.1	57.8	55.3	53.4	49.8	48.9	48.8	50.0	51.4	53.3	57.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.3	65.2	63.8	59.9	58.9	54.6	53.1	52.5	54.6	56.4	58.9	62.1	(27)
		MCDB	67.1	70.3	67.1	63.0	62.2	57.3	56.2	55.2	59.0	60.5	62.7	66.9	(28)
	2%	WB	62.2	62.7	61.7	58.2	56.3	52.7	51.7	51.1	53.0	54.8	57.2	60.2	(29)
		MCDB	66.7	67.0	64.9	61.4	59.0	55.4	54.5	54.2	56.8	59.1	60.5	64.3	(30)
	5%	WB	60.7	61.0	60.0	56.8	54.9	51.5	50.4	50.1	51.7	53.3	55.5	58.7	(31)
		MCDB	64.7	65.0	63.7	60.3	57.8	54.0	53.3	53.4	55.7	57.3	59.1	63.2	(32)
	10%	WB	59.3	59.5	58.3	55.6	53.6	50.2	49.2	49.2	50.4	52.0	53.9	57.3	(33)
		MCDB	63.2	63.3	62.3	59.2	56.8	52.6	52.3	52.4	54.2	55.4	57.5	61.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	7.7	7.5	7.1	6.3	6.5	6.8	6.9	7.0	7.1	7.2	7.7	(35)
		MCDBR	10.8	10.7	10.2	9.4	7.8	7.6	8.0	8.3	9.4	10.1	10.1	10.9	(36)
	5% WB	MCWBR	7.1	7.0	6.8	6.8	6.0	6.3	6.0	5.8	6.5	6.9	6.8	7.1	(37)
		MCWBR	9.2	9.5	8.8	8.4	6.9	7.0	6.7	7.2	8.5	8.6	8.8	9.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.346	0.341	0.329	0.316	0.319	0.311	0.306	0.313	0.342	0.339	0.335	0.336	(40)
		taud	2.538	2.564	2.603	2.624	2.560	2.533	2.574	2.581	2.490	2.514	2.544	2.571	(41)
	Ebn at Noon		309	301	289	268	237	225	240	264	279	298	310	314	(42)
		Edh at Noon	33	31	27	22	19	17	18	22	29	32	33	33	(43)
(44) All-Sky Solar Radiation	RadAvg		1770	1504	1099	704	408	313	379	614	944	1344	1677	1858	(44)
	RadStd		144	100	72	51	29	31	33	35	65	96	138	123	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (3 neighbors)		N/A	N/A	+1.17	N/A	N/A	N/A	-76	-230	+140	N/A

Nomenclature: See separate page