

TROUGHTON ISLAND, Australia

WMO: 941020

Lat: 13.754S

Lon: 126.149E

Elev: 8

StdP: 101.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	21.8	6.4	6.0	23.8	7.9	6.6	24.3	12.9	23.3	12.2	23.3	5.8	120	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.2	33.7	26.9	33.2	26.9	32.8	26.9	30.0	31.2	29.1	31.0	28.5	30.9	5.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.7	26.7	30.7	28.7	25.1	30.1	28.0	24.1	30.0	99.9	31.2	95.2	30.7	92.5	31.0	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.3	10.3	18.7	34.5	5.9	0.5	14.4	34.8	11.0	35.1	7.7	35.4	3.5	35.7		
(5)			11.7	29.8	4.1	1.2	8.7	30.7	6.3	31.4	4.0	32.1	1.0	32.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	29.3	29.2	29.4	29.8	28.5	26.1	25.3	25.7	27.5	28.9	30.3	30.4	(6)
(7)		DBStd	2.18	1.21	1.32	1.23	1.19	1.37	1.64	1.20	1.07	1.06	1.64	0.71	2.00	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	1	0	0	0	0	0	0	0	0	0	1	0	0	(9)
(10)		CDD10.0	6701	598	538	602	594	572	483	476	486	524	586	609	631	(10)
(11)		CDD18.3	3661	340	304	344	344	314	233	217	228	274	329	359	373	(11)
(12)		CDH23.3	42483	4426	3876	4443	4506	3618	1913	1448	1631	2729	3954	4821	5118	(12)
(13)	CDH26.7	17263	1979	1669	1992	2131	1309	376	188	255	741	1546	2422	2655	(13)	
(14)	Wind	WSAvg	5.3	6.6	6.1	5.0	4.5	6.0	6.4	5.3	4.6	4.4	4.7	4.8	5.6	(14)
(15)	Precipitation	PrecAvg	1133	285	249	187	73	28	5	5	2	6	27	59	208	(15)
(16)		PrecMax	1799	600	450	428	293	212	59	20	6	20	157	108	477	(16)
(17)		PrecMin	683	118	85	64	2	1	0	0	0	1	3	12	29	(17)
(18)		PrecStd	262	102	98	108	67	46	10	4	1	4	30	24	109	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.3	33.6	34.1	33.0	31.2	29.8	29.9	31.6	32.8	33.7	47.1	(19)
(20)			MCWB	27.8	27.9	27.4	24.9	23.9	23.6	21.9	22.4	24.6	25.7	27.5	28.3	(20)
(21)		2%	DB	32.6	32.7	32.9	33.4	32.2	30.1	29.1	29.2	30.9	32.2	33.2	34.9	(21)
(22)			MCWB	27.7	27.8	27.3	25.4	23.8	22.6	21.7	22.2	24.7	25.9	27.2	27.9	(22)
(23)		5%	DB	32.0	32.2	32.3	32.8	31.5	29.3	28.4	28.7	30.3	31.7	32.7	33.3	(23)
(24)			MCWB	27.6	27.7	27.3	25.6	23.7	22.3	21.5	21.9	24.6	25.9	27.1	27.7	(24)
(25)		10%	DB	31.5	31.5	31.7	32.2	30.8	28.7	27.8	28.1	29.7	31.2	32.4	32.7	(25)
(26)			MCWB	27.4	27.5	27.2	25.5	23.5	21.9	21.2	21.6	24.5	25.8	26.9	27.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.7	30.9	31.1	28.6	27.2	26.0	25.1	26.2	27.2	28.5	29.2	30.8	(27)
(28)			MCDWB	31.2	31.6	31.7	31.4	30.0	29.1	26.8	27.4	29.4	30.2	31.3	32.2	(28)
(29)		2%	WB	29.4	29.2	29.3	27.8	26.6	25.1	24.4	25.0	26.5	27.6	28.6	29.5	(29)
(30)			MCDWB	30.7	30.8	31.1	31.2	29.5	28.2	26.6	27.2	28.9	30.0	31.2	31.4	(30)
(31)		5%	WB	28.6	28.4	28.4	27.3	26.0	24.4	23.8	24.3	26.0	27.1	28.1	28.7	(31)
(32)			MCDWB	30.5	30.5	30.8	30.8	29.0	27.7	26.4	27.0	28.5	29.9	31.3	31.2	(32)
(33)		10%	WB	28.1	28.0	27.8	26.8	25.5	23.7	23.2	23.7	25.6	26.6	27.7	28.1	(33)
(34)			MCDWB	30.4	30.4	30.6	30.5	29.1	27.3	26.1	26.6	28.2	29.7	31.0	31.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	3.8	4.2	4.7	4.7	4.7	5.1	5.3	4.7	4.6	4.3	4.2	(35)
(36)			MCDBR	4.5	4.3	4.7	5.1	5.2	4.9	5.4	5.5	4.8	4.7	4.5	4.6	(36)
(37)			MCWBR	2.5	2.3	2.4	2.6	3.1	3.3	3.4	3.1	2.2	2.1	2.1	2.2	(37)
(38)		5% WB	MCDWB	4.5	4.2	4.5	4.5	4.4	4.5	4.8	4.6	4.4	4.4	4.4	4.5	(38)
(39)			MCWBR	3.0	2.8	2.8	2.3	2.4	2.6	2.7	2.3	2.0	2.1	2.3	2.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.424	0.412	0.394	0.377	0.372	0.349	0.343	0.354	0.407	0.433	0.432	0.417	(40)	
(41)		taud	2.502	2.540	2.590	2.603	2.567	2.591	2.590	2.551	2.432	2.382	2.420	2.508	(41)	
(42)		Ebn at Noon	921	925	923	907	878	884	899	916	897	895	907	926	(42)	
(43)		Edh at Noon	115	110	102	95	93	88	90	99	118	127	124	114	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.65	5.82	5.92	5.83	5.36	5.11	5.38	6.08	6.75	7.08	7.08	6.20	(44)	
(45)		RadStd	0.73	0.81	0.70	0.50	0.31	0.21	0.16	0.11	0.15	0.23	0.22	0.55	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page