

BROWSE ISLAND, AustraliaWMO: **941030**Lat: **14.109S**Lon: **123.548E**Elev: **16**StdP: **14.69**Time Zone: **8.00 (E08)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	75.0	75.9	N/A	N/A	N/A	N/A	N/A	N/A	24.9	79.8	23.0	79.4	11.6	80	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	4.3	91.0	N/A	89.9	N/A	89.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.5	23.7	21.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.1	84.2	83.8	84.9	86.2	83.6	80.9	79.7	79.5	80.9	83.4	85.0	85.3
	DBStd	2.82	1.90	1.95	2.17	1.91	1.65	1.94	1.63	1.27	1.29	1.47	1.31	2.15
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12084	1062	946	1083	1085	1040	928	920	913	926	1035	1051	1095
	CDD65	6609	597	526	618	635	575	478	455	448	476	570	601	630
	CDH74	78905	7809	6744	8256	8677	7009	4808	3999	3804	4705	6763	7818	8513
	CDH80	29140	3370	2735	3814	4370	2591	919	403	307	743	2322	3500	4066
Wind	WSAvg	10.4	13.7	12.9	10.7	8.2	10.4	12.1	10.4	9.0	8.5	8.2	9.3	11.7
Precipitation	PrecAvg	37.6	9.8	8.4	6.1	3.1	1.7	0.4	0.4	0.2	0.2	0.4	0.6	6.4
	PrecMax	60.4	25.1	15.9	19.5	10.0	10.6	2.4	1.6	0.5	0.4	3.5	3.1	15.6
	PrecMin	16.7	1.9	1.5	0.6	0.2	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.4
	PrecStd	10.0	4.6	3.8	4.5	2.7	2.4	0.5	0.4	0.1	0.0	0.6	0.7	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.1	90.8	91.9	92.4	88.6	86.3	84.7	84.2	86.3	88.7	89.6	92.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	89.2	89.2	90.5	91.0	87.4	85.2	83.5	83.2	85.0	87.5	88.6	90.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	88.3	87.6	89.1	89.8	86.8	84.4	82.7	82.5	84.1	86.7	87.9	89.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	87.3	86.4	88.1	88.9	86.1	83.7	81.9	81.7	83.2	85.8	87.2	88.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.0	3.7	4.1	4.3	4.2	3.8	4.1	4.5	4.4	4.4	3.9	4.4
		MCDBR	4.9	4.6	4.7	5.2	4.8	4.3	4.4	5.2	5.6	5.3	4.8	5.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.417	0.405	0.395	0.376	0.376	0.353	0.343	0.357	0.406	0.429	0.419	0.406	
	taud	2.523	2.568	2.589	2.612	2.568	2.607	2.619	2.553	2.432	2.392	2.455	2.545	
	Ebn at Noon	294	296	292	288	277	279	285	289	285	285	292	297	
	Edh at Noon	36	34	32	30	30	27	28	31	37	40	38	35	
All-Sky Solar Radiation	RadAvg	1854	1929	1913	1920	1713	1635	1737	1973	2188	2314	2346	2056	
	RadStd	250	249	220	98	104	83	54	29	47	64	70	167	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page