

BROWSE ISLAND, AustraliaWMO: **941030**Lat: **14.109S**Lon: **123.548E**Elev: **5**StdP: **101.26**Time Zone: **8.00 (E08)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.9	24.4	N/A	N/A	N/A	N/A	N/A	N/A	11.1	26.6	10.3	26.3	5.2	80	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	2.4	32.8	N/A	32.2	N/A	31.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.6	9.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	29.0	28.8	29.4	30.1	28.6	27.2	26.5	26.4	27.1	28.5	29.5	29.6		
	DBStd	1.57	1.06	1.08	1.21	1.06	0.92	1.08	0.91	0.71	0.72	0.81	0.73	1.20		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6713	590	526	602	603	578	516	511	507	514	575	584	608		
	CDD18.3	3672	332	292	343	353	319	266	253	249	264	317	334	350		
	CDH23.3	43836	4338	3747	4587	4821	3894	2671	2222	2113	2614	3757	4343	4729		
	CDH26.7	16189	1872	1519	2119	2428	1439	511	224	171	413	1290	1944	2259		
(14) Wind	WSAvg	4.7	6.1	5.8	4.8	3.7	4.7	5.4	4.6	4.0	3.8	3.7	4.2	5.2		
(15) Precipitation	PrecAvg	955	248	214	154	79	42	11	9	6	5	9	16	163		
	PrecMax	1533	637	405	495	254	269	62	40	13	9	89	78	396		
	PrecMin	424	47	39	15	4	0	2	2	3	2	2	2	10		
	PrecStd	254	118	96	115	68	60	13	9	2	1	15	17	103		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.3	32.7	33.3	33.6	31.5	30.2	29.3	29.0	30.2	31.5	32.0	33.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	31.8	31.8	32.5	32.8	30.8	29.6	28.6	28.5	29.5	30.8	31.5	32.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	31.3	30.9	31.7	32.1	30.4	29.1	28.1	28.0	28.9	30.4	31.1	31.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	30.7	30.2	31.2	31.6	30.0	28.7	27.7	27.6	28.4	29.9	30.7	31.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.2	2.1	2.3	2.4	2.3	2.1	2.3	2.5	2.4	2.4	2.2	2.5		
		MCDBR	2.7	2.6	2.6	2.9	2.7	2.4	2.4	2.9	3.1	3.0	2.7	3.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.417	0.405	0.395	0.376	0.376	0.353	0.343	0.357	0.406	0.429	0.419	0.406		
	taud		2.523	2.568	2.589	2.612	2.568	2.607	2.619	2.553	2.432	2.392	2.455	2.545		
	Ebn at Noon		928	932	922	907	873	879	899	912	897	898	920	937		
	Edh at Noon		113	107	102	94	93	86	87	98	117	126	120	110		
(44) All-Sky Solar Radiation	RadAvg		5.85	6.08	6.03	6.05	5.40	5.15	5.47	6.22	6.90	7.29	7.40	6.48		
	RadStd		0.79	0.79	0.69	0.31	0.33	0.26	0.17	0.09	0.15	0.20	0.22	0.53		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page