

DUM IN MIRRIE ISLAND, AustraliaWMO: **941160**Lat: **12.635S**Lon: **130.373E**Elev: **14**StdP: **14.69**Time Zone: **9.50 (AUC)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	60.9	63.3	38.1	33.7	75.1	41.8	39.0	74.1	18.2	79.5	15.0	80.0	3.5	130	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	10.2	92.1	77.2	91.3	78.1	90.6	78.2	82.3	88.8	81.7	88.2	81.2	87.6	8.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	158.8	86.3	79.9	155.3	85.9	79.3	152.3	85.5	46.1	88.9	45.5	88.5	45.0	88.0	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.9	12.2	56.5	95.6	2.3	1.6	54.9	96.7	53.6	97.7	52.3	98.5	50.6	99.7		
(5)			49.9	83.4	1.8	0.9	48.6	84.0	47.6	84.5	46.6	85.0	45.3	85.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	83.4	83.2	83.2	83.2	80.3	76.4	75.3	76.4	80.7	83.9	84.7	84.6
	DBStd	4.16	2.28	2.26	1.98	2.06	3.01	3.78	3.10	2.56	2.44	2.01	1.94	2.30
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11414	1037	931	1030	996	938	792	784	820	922	1050	1042	1072
	CDD65	5939	572	511	565	546	473	342	319	355	472	585	592	607
	CDH74	67638	7112	6269	6793	6358	4569	2649	2364	3015	5230	7489	7893	7897
	CDH80	26905	2889	2478	2657	2614	1701	802	593	797	1767	3277	3726	3604
Wind	WSAvg	5.9	7.3	7.1	5.9	5.3	5.4	5.6	5.5	5.5	5.6	5.9	5.8	6.3
Precipitation	PrecAvg	72.6	17.1	15.4	12.5	3.6	1.1	0.1	0.1	0.2	0.7	2.7	5.6	13.5
	PrecMax	98.5	30.1	40.2	22.6	16.4	4.9	0.5	1.0	1.5	3.3	8.2	8.7	25.4
	PrecMin	46.2	6.1	2.3	4.9	0.2	0.0	0.0	0.0	0.0	0.0	0.2	3.1	3.6
	PrecStd	13.6	6.0	8.6	5.1	3.8	1.4	0.1	0.2	0.3	0.9	2.3	1.6	5.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.9	90.9	91.4	94.0	92.3	90.5	90.0	89.8	91.4	92.3	92.6	92.5
		MCWB	81.0	81.2	79.5	74.1	72.2	70.8	68.5	65.2	70.3	77.1	80.2	80.8
	2%	DB	89.8	89.8	90.2	91.8	90.4	88.2	87.2	87.2	89.0	90.8	91.4	91.5
		MCWB	80.9	80.8	80.0	75.1	73.1	70.6	68.2	67.3	74.5	77.9	79.6	80.4
	5%	DB	88.9	88.9	89.1	90.5	89.0	86.4	85.1	85.5	87.8	89.8	90.6	90.7
		MCWB	80.6	80.5	80.1	76.3	73.6	70.1	68.7	69.2	75.3	78.0	79.3	80.2
	10%	DB	88.0	87.9	88.1	89.2	87.5	84.7	83.3	84.1	86.7	88.9	89.8	89.7
		MCWB	80.3	80.2	79.8	77.2	73.8	69.7	69.0	70.4	75.3	77.7	79.1	80.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.8	82.7	82.9	82.4	79.7	77.9	76.0	76.4	79.2	80.9	82.0	82.7
		MCDB	88.9	88.9	88.7	87.8	86.4	84.8	82.5	83.4	86.9	89.3	90.1	90.2
	2%	WB	81.8	81.8	82.0	80.8	78.7	76.0	74.6	75.4	78.2	80.0	81.2	81.8
		MCDB	88.0	87.8	87.7	86.8	85.3	82.4	81.3	82.1	85.6	88.3	89.2	89.1
	5%	WB	81.2	81.2	81.3	79.9	77.8	74.9	73.7	74.5	77.5	79.4	80.6	81.2
		MCDB	87.3	87.1	87.0	86.0	84.3	81.1	80.4	81.3	84.6	87.4	88.6	88.3
	10%	WB	80.7	80.7	80.7	79.2	76.9	73.7	72.6	73.7	76.9	78.9	80.0	80.7
		MCDB	86.7	86.4	86.3	85.2	83.4	80.3	79.3	80.6	84.0	86.7	87.8	87.7
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.1	9.5	13.0	15.8	18.1	18.2	17.2	12.8	10.8	10.2	9.3
		MCDBR	9.1	9.3	10.9	14.8	16.6	18.4	19.4	19.0	13.8	11.5	10.9	10.5
		MCWBR	4.1	4.3	4.6	5.1	6.3	8.0	8.5	8.1	5.4	4.5	4.5	4.3
	5% WB	MCDBR	8.5	8.6	9.5	11.8	13.1	15.0	15.7	13.5	11.0	10.3	10.3	9.3
MCWBR		4.3	4.5	4.8	4.8	5.0	6.4	7.1	5.9	4.5	4.3	4.7	4.4	
Clear-Sky Solar Irradiance	taub	0.426	0.413	0.399	0.379	0.375	0.356	0.355	0.370	0.431	0.452	0.455	0.419	
	taud	2.487	2.522	2.564	2.597	2.559	2.555	2.556	2.510	2.364	2.326	2.350	2.494	
	Ebn at Noon	292	293	292	288	279	279	282	286	278	279	281	293	
	Edh at Noon	37	36	33	30	30	29	30	33	40	43	42	37	
All-Sky Solar Radiation	RadAvg	1639	1708	1767	1834	1703	1635	1707	1898	2071	2155	2054	1791	
	RadStd	164	250	214	138	90	57	42	48	67	75	87	176	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	+0.43	N/A	+0.13	N/A	N/A	N/A	N/A

Nomenclature: See separate page