

PIRLANGIMPI, Australia

WMO: 941190

Lat: 11.4022S

Lon: 130.4217E

Elev: 19

StdP: 101.09

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 16.3	(c) 17.6	(d) 7.5	(e) 6.4	(f) 25.2	(g) 9.4	(h) 7.3	(i) 25.1	(j) 6.5	(k) 29.4	(l) 6.2	(m) 29.5	(n) 0.6	(o) 130	(p) 0.301

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.9	34.3	25.1	33.7	25.3	33.2	25.4	30.1	30.7	28.6	30.4	27.7	30.6	3.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
30.0	27.2	30.5	28.3	24.6	29.5	26.9	22.7	29.0	100.7	30.6	93.2	30.4	88.3	30.7	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.0	5.3	4.6	DB	14.3	35.9	1.2	0.8	13.5	36.4	12.8	36.9	12.1	37.4	11.3	38.0	
			WB	11.7	29.6	1.3	2.0	10.8	31.0	10.0	32.2	9.3	33.3	8.3	34.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	28.3	28.2	28.0	27.9	26.9	25.2	25.1	25.5	27.2	28.4	28.8	28.8
	DBStd	1.85	1.20	1.15	1.01	1.18	1.50	2.07	1.60	1.35	1.11	0.87	0.81	1.11
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6332	567	509	559	537	524	455	467	481	516	570	564	582
	CDD18.3	3291	309	276	301	287	266	205	209	223	266	312	314	323
	CDH23.3	33002	3412	2936	3054	2834	2498	1706	1693	1943	2581	3309	3419	3615
Wind	WSAvg	1.6	1.7	1.6	1.2	1.3	1.8	1.9	1.9	1.8	1.7	1.6	1.3	1.3
	PrecAvg	2066	414	396	375	132	22	1	3	6	30	86	200	349
	PrecMax	2767	780	781	706	560	97	13	45	72	125	228	475	853
	PrecMin	1483	144	126	131	15	0	0	0	0	0	1	39	94
	PrecStd	368	169	151	162	109	24	2	9	14	37	69	82	182
	DB	33.7	33.7	33.7	34.2	33.7	32.9	32.7	33.4	34.5	35.2	35.1	34.6	34.6
	MCWB	27.3	27.1	26.7	24.6	24.0	24.2	21.9	21.3	22.9	23.4	26.0	26.8	26.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	32.8	32.7	32.9	33.3	32.8	31.8	31.6	32.2	33.6	34.0	34.0	33.7	33.7
	2% MCWB	27.3	27.2	26.5	25.1	24.0	23.0	21.6	21.6	23.1	24.4	26.1	26.8	26.8
	5% DB	32.0	31.9	32.0	32.5	32.0	30.9	30.8	31.5	32.6	33.2	33.2	32.9	32.9
	5% MCWB	27.2	27.0	26.4	25.3	23.9	22.4	21.5	21.4	23.6	24.7	26.1	26.8	26.8
	10% DB	31.2	31.0	31.1	31.7	31.2	30.1	30.0	30.6	31.8	32.4	32.5	32.0	32.0
	10% MCWB	26.9	26.9	26.4	25.3	23.7	22.0	21.1	21.2	23.7	24.8	26.1	26.8	26.8
	WB	31.6	30.5	28.1	32.1	29.1	29.2	24.9	30.2	30.0	27.0	28.0	30.8	30.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	31.7	30.9	31.7	32.4	29.7	29.4	29.6	30.6	31.1	31.9	32.7	31.2	31.2
	2% WB	29.1	29.1	27.5	28.3	26.3	25.2	23.7	24.5	26.0	26.2	27.2	28.6	28.6
	2% MCDB	30.3	30.4	31.1	29.9	30.1	28.8	28.6	29.2	30.5	31.3	32.2	30.8	30.8
	5% WB	27.9	27.7	27.0	27.0	25.6	24.0	23.1	23.6	25.2	25.8	26.7	27.5	27.5
	5% MCDB	30.1	30.2	30.5	30.0	29.7	28.5	28.2	28.5	30.0	30.9	31.7	31.1	31.1
	10% WB	27.1	27.1	26.6	26.4	25.1	23.2	22.5	23.0	24.6	25.5	26.4	27.0	27.0
	10% MCDB	30.1	30.0	29.9	29.4	28.9	27.8	27.4	28.0	29.4	30.2	31.1	30.9	30.9
Mean Daily Temperature Range	MDBR	5.9	6.0	6.5	8.0	9.4	10.5	11.0	11.6	10.4	9.3	8.4	6.9	6.9
	5% DB MCDBR	7.0	7.4	7.9	9.3	9.9	10.5	11.1	12.1	11.2	10.2	9.2	8.3	8.3
	5% DB MCWBR	3.0	3.2	3.0	3.7	3.6	4.1	4.0	4.0	3.8	3.0	3.2	3.0	3.0
	5% WB MCDBR	6.4	6.7	6.9	7.1	8.8	9.8	10.1	10.4	9.4	8.7	8.5	7.3	7.3
	5% WB MCWBR	4.1	4.1	3.2	4.3	4.3	4.9	4.2	4.7	4.5	3.3	3.4	3.6	3.6
	taub	0.416	0.406	0.398	0.377	0.373	0.362	0.362	0.380	0.423	0.441	0.431	0.407	0.407
	taud	2.521	2.547	2.570	2.623	2.601	2.577	2.566	2.504	2.386	2.354	2.420	2.531	2.531
Clear-Sky Solar Irradiance	Ebn at Noon	927	931	921	911	884	877	886	895	884	888	906	934	934
	Edh at Noon	113	109	105	94	91	91	93	105	124	131	124	111	111
	RadAvg	5.05	5.23	5.25	5.55	5.26	5.12	5.33	5.94	6.50	6.69	6.43	5.44	5.44
All-Sky Solar Radiation	RadStd	0.55	0.66	0.60	0.56	0.33	0.15	0.12	0.16	0.21	0.28	0.28	0.54	0.54

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	+0.24	N/A	+0.07	N/A	N/A	N/A	N/A

Nomenclature: See separate page