

BACHELOR, Australia

WMO: 941250

Lat: 13.0544S

Lon: 131.0253E

Elev: 105

StdP: 100.07

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.7	15.3	-3.3	2.9	26.8	-1.1	3.5	24.3	8.2	26.6	7.7	26.0	0.9	140	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.2	36.6	22.0	35.7	22.3	35.0	22.8	27.5	30.7	27.0	30.6	26.6	30.2	3.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.8	22.7	28.6	26.2	22.0	28.1	25.8	21.4	27.8	88.3	30.6	86.0	30.6	84.2	30.4	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	6.1	5.4	DB	10.9	38.5	1.8	1.1	9.6	39.3	8.6	39.9	7.5	40.5	6.2	41.2	(4)
(5)			WB	7.0	28.1	1.0	0.8	6.3	28.6	5.7	29.1	5.1	29.6	4.4	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	27.9	27.8	28.0	27.6	25.8	24.2	24.2	25.1	28.0	29.5	29.3	28.6	(6)	
	DBStd	2.39	1.43	1.35	1.18	1.41	1.96	2.29	1.86	1.72	1.52	1.24	1.35	1.43	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6262	553	499	558	527	491	427	441	467	539	603	579	577	(10)	
	CDD18.3	3221	295	266	299	277	232	177	183	209	289	345	329	318	(11)	
	CDH23.3	33919	2847	2537	2954	2909	2334	1706	1881	2311	3357	4033	3712	3338	(12)	
	CDH26.7	15394	1042	938	1207	1364	1053	697	811	1119	1817	2118	1810	1418	(13)	
(14) Wind	WSAvg	2.0	2.1	2.1	1.8	1.9	2.2	2.7	2.4	2.1	1.9	1.8	1.6	1.8	(14)	
(15) Precipitation	PrecAvg	1472	338	305	245	87	22	1	2	2	12	57	152	241	(15)	
	PrecMax	2072	669	581	653	484	120	3	14	22	49	146	265	488	(16)	
	PrecMin	854	82	137	57	0	0	0	0	0	0	0	66	50	(17)	
	PrecStd	265	145	126	157	113	36	1	4	5	12	42	53	146	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	34.7	34.8	35.3	34.6	33.6	33.6	34.7	36.9	38.2	37.4	36.1	(19)	
		MCWB	25.9	25.5	24.7	22.9	21.5	20.8	19.9	19.7	20.3	21.4	23.1	25.1	(20)	
	2%	DB	33.6	33.8	34.0	34.2	33.5	32.5	32.6	33.6	35.9	36.8	36.1	34.9	(21)	
		MCWB	26.0	25.6	24.6	22.9	21.4	20.4	19.4	19.3	20.2	21.6	23.6	25.3	(22)	
	5%	DB	32.8	33.0	33.3	33.5	32.6	31.6	31.8	32.8	35.1	35.9	35.1	34.0	(23)	
		MCWB	26.0	25.7	24.6	22.9	21.4	19.9	18.9	19.0	20.4	21.9	24.2	25.4	(24)	
	10%	DB	31.7	31.8	32.4	32.7	31.7	30.6	30.9	31.9	34.2	34.8	34.0	32.9	(25)	
		MCWB	25.9	25.7	24.9	22.9	21.2	19.3	18.5	18.5	20.5	22.4	24.5	25.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	27.9	27.7	26.8	25.4	24.2	22.9	23.7	25.9	27.2	28.1	27.9	(27)	
		MCDB	30.9	30.7	29.9	29.7	29.6	28.0	28.0	28.8	30.5	31.4	31.9	31.0	(28)	
	2%	WB	27.2	27.1	27.0	26.0	24.7	23.0	22.1	22.7	24.7	26.1	26.9	27.1	(29)	
		MCDB	30.6	30.5	30.2	29.4	29.0	28.2	27.7	28.4	29.2	30.0	30.9	30.8	(30)	
	5%	WB	26.7	26.7	26.5	25.5	24.1	22.1	21.3	22.0	24.1	25.4	26.2	26.6	(31)	
		MCDB	30.2	30.1	29.8	29.1	28.4	27.5	27.4	27.6	28.6	29.5	30.3	30.5	(32)	
	10%	WB	26.3	26.2	26.0	25.0	23.5	21.2	20.5	21.3	23.6	24.9	25.7	26.1	(33)	
		MCDB	29.7	29.6	29.4	28.9	27.7	27.6	27.0	27.0	28.4	29.2	29.9	30.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	7.6	8.6	10.8	12.3	12.9	13.9	14.4	13.9	12.2	10.5	8.6	(35)	
		MCDBR	9.4	9.7	10.4	12.0	13.0	13.4	14.4	14.7	14.4	13.5	11.7	10.5	(36)	
	5% WB	MCWBR	3.0	3.2	3.2	3.4	3.9	4.2	4.4	4.3	3.9	3.4	2.9	3.0	(37)	
		MCWBR	8.1	8.2	8.4	9.6	10.5	11.8	13.3	13.1	12.7	11.5	10.3	9.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.418	0.408	0.395	0.372	0.369	0.347	0.343	0.359	0.426	0.449	0.453	0.420	(40)	
		taud	2.470	2.495	2.528	2.564	2.516	2.525	2.530	2.472	2.315	2.281	2.306	2.445	(41)	
	Ebn at Noon		927	929	923	912	882	887	900	911	880	881	888	923	(42)	
		Edh at Noon	119	115	109	99	98	94	96	107	132	141	139	121	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.34	5.51	5.68	5.84	5.40	5.19	5.44	6.07	6.54	6.74	6.42	5.80	(44)	
	RadStd		0.53	0.83	0.68	0.44	0.29	0.20	0.14	0.19	0.29	0.30	0.27	0.52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)			N/A	N/A	N/A	+0.24	N/A	+0.07	N/A	N/A	N/A

Nomenclature: See separate page