

POINT STUART, Australia

WMO: 941270

Lat: 12.244S

Lon: 131.879E

Elev: 2

StdP: 101.31

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	16.4	5.0	5.4	22.8	7.1	6.2	23.0	8.3	28.2	7.7	28.4	2.1	120	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.2	35.2	26.3	34.2	26.0	33.5	25.8	29.4	31.8	28.7	31.5	28.1	31.1	4.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.8	25.3	30.8	28.0	24.2	30.3	27.4	23.3	29.8	96.9	32.1	93.3	31.6	90.6	31.1	32.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.4	6.6	11.7	35.7	2.2	1.0	10.1	36.4	8.8	37.0	7.6	37.6	6.0	38.4		
(5)			8.7	29.6	1.3	1.4	7.7	30.6	7.0	31.4	6.3	32.2	5.3	33.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	28.4	28.2	28.2	27.8	26.3	24.5	24.1	24.8	27.2	28.6	29.2	29.0		
	DBStd	2.31	1.13	1.07	1.04	1.14	1.62	2.03	1.85	1.69	2.14	1.46	0.99	1.33		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6270	569	509	566	535	504	436	436	458	516	577	576	588		
	CDD18.3	3228	311	276	307	285	246	186	178	200	266	318	326	329		
	CDH23.3	36224	3584	3111	3466	3154	2372	1579	1549	1927	3134	4034	4229	4085		
	CDH26.7	14601	1350	1106	1250	1174	846	514	507	666	1384	1893	2059	1852		
(14) Wind	WSAvg	3.2	3.9	3.7	3.1	2.7	2.9	3.0	3.0	3.2	3.0	3.1	3.0	3.4		
(15) Precipitation	PrecAvg	1613	360	341	265	109	20	1	1	2	14	62	144	294		
	PrecMax	2337	702	670	651	600	79	6	6	16	85	199	234	498		
	PrecMin	1056	140	117	108	4	0	0	0	0	0	1	76	109		
	PrecStd	273	134	133	125	123	23	1	2	4	17	49	40	100		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	33.6	33.6	33.7	32.8	32.0	32.5	32.6	38.1	38.2	35.1	35.7		
		MCWB	27.5	28.6	28.1	25.7	24.3	23.2	21.1	20.4	15.3	18.4	26.3	27.5		
	2%	DB	32.9	32.6	32.6	32.6	31.9	31.2	31.2	31.7	35.3	34.9	34.2	34.4		
		MCWB	27.4	28.1	27.7	26.0	24.2	22.7	21.0	20.7	20.2	23.5	25.9	27.0		
	5%	DB	32.1	31.9	31.9	31.9	31.2	30.5	30.4	30.9	33.2	33.5	33.6	33.5		
		MCWB	27.3	27.8	27.3	25.8	24.0	22.2	20.8	20.6	22.7	24.6	25.7	26.6		
	10%	DB	31.3	31.1	31.2	31.2	30.6	29.7	29.6	30.1	32.1	32.8	33.0	32.7		
		MCWB	27.0	27.3	26.8	25.4	23.7	21.6	20.5	20.5	23.1	24.6	25.5	26.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.5	30.7	31.2	29.8	28.1	26.7	24.4	24.6	27.5	28.0	28.5	28.9		
		MCDB	32.0	32.3	31.5	31.1	31.0	29.4	28.1	28.7	30.4	31.4	32.4	33.6		
	2%	WB	28.6	29.4	29.2	28.2	26.8	25.1	23.6	23.9	26.1	27.0	27.6	28.2		
		MCDB	31.2	31.7	31.7	30.6	29.8	28.6	27.7	28.3	29.7	31.6	32.2	32.5		
	5%	WB	28.0	28.6	28.4	27.3	25.8	24.1	22.9	23.3	25.0	26.2	26.9	27.7		
		MCDB	30.7	31.1	31.0	30.1	28.8	28.2	27.4	28.0	29.8	30.9	31.9	31.8		
	10%	WB	27.5	28.0	27.6	26.6	25.2	23.3	22.2	22.8	24.3	25.7	26.4	27.3		
		MCDB	30.2	30.4	30.2	29.6	28.4	27.7	26.8	27.5	29.4	30.5	31.3	31.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	5.8	6.0	7.1	9.3	10.8	11.9	11.5	9.9	8.7	8.2	7.2		
		MCDBR	7.0	7.0	7.0	7.9	9.5	10.6	12.0	11.9	10.6	9.3	8.7	8.5		
		MCWBR	2.9	3.8	3.2	2.9	3.4	4.3	4.4	4.3	3.3	3.1	2.9	2.9		
	5% WB	MCDBR	6.3	6.7	6.8	7.2	7.3	9.0	10.2	9.3	8.6	8.3	8.6	7.8		
		MCWBR	3.3	4.0	3.8	3.2	2.9	3.9	4.1	3.6	3.2	3.3	3.4	3.2		
(40) Clear-Sky Solar Irradiance	taub		0.418	0.421	0.403	0.378	0.367	0.355	0.348	0.366	0.423	0.450	0.453	0.426		
	taud		2.512	2.494	2.546	2.601	2.592	2.570	2.584	2.516	2.370	2.317	2.347	2.471		
	Ebn at Noon		926	917	916	908	887	882	897	906	883	880	888	916		
	Edh at Noon		114	115	107	96	92	91	91	103	126	136	133	118		
(44) All-Sky Solar Radiation	RadAvg		5.24	5.45	5.51	5.75	5.39	5.18	5.43	6.09	6.63	6.81	6.45	5.70		
	RadStd		0.54	0.75	0.65	0.50	0.29	0.17	0.14	0.18	0.26	0.29	0.24	0.53		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page