

MCCLUER ISLAND, Australia

WMO: 941350

Lat: 11.047S

Lon: 132.979E

Elev: 8

StdP: 14.69

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	71.4	72.7	53.1	60.0	74.8	56.7	68.4	75.6	29.1	76.5	27.7	76.7	15.9	130	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.0	90.5	80.7	89.6	80.2	88.9	80.0	84.5	86.5	83.1	86.3	81.9	86.1	9.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
84.1	178.5	85.9	82.4	169.0	85.3	80.9	160.5	84.7	48.9	86.4	47.3	86.1	45.9	86.3	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.3	26.3	24.3	68.8	92.0	2.7	0.6	66.9	92.5	65.3	92.9	63.8	93.2	61.8	93.7		
(5)			57.8	83.6	2.8	1.9	55.8	85.0	54.2	86.1	52.6	87.2	50.6	88.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	84.2	83.7	83.8	83.5	81.2	78.1	77.1	80.2	82.6	85.1	85.6	(6)		
(7)		DBStd	3.42	1.95	1.96	1.94	1.78	1.87	2.54	1.87	1.61	1.58	1.58	1.53	2.09	(7)	
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
(10)		CDD50	11636	1061	944	1046	1005	969	842	839	859	905	1012	1052	1102	(10)	
(11)		CDD65	6161	596	524	581	555	504	392	374	394	455	547	602	637	(11)	
(12)		CDH74	69420	7590	6485	7245	6970	5563	3211	2536	2834	4354	6265	7827	8540	(12)	
(13)		CDH80	23382	3173	2512	2855	2712	1419	327	80	114	646	1919	3522	4103	(13)	
(14)	Wind	WSAvg	14.5	15.3	14.5	12.2	14.0	17.5	17.6	17.7	16.6	14.0	13.0	10.6	11.6	(14)	
(15)	Precipitation	PrecAvg	52.9	12.3	9.6	9.8	5.8	1.6	0.3	0.1	0.0	0.1	0.3	2.6	9.1	(15)	
(16)		PrecMax	76.1	25.4	20.1	19.6	16.1	9.8	2.8	0.9	0.0	1.3	2.2	8.1	19.1	(16)	
(17)		PrecMin	19.8	3.1	3.3	2.2	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.2	1.4	(17)	
(18)		PrecStd	14.1	5.4	4.3	5.0	3.9	2.5	0.6	0.2	0.0	0.3	0.5	1.7	5.0	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.8	90.3	89.9	89.8	87.2	85.0	82.8	83.2	85.8	88.2	90.9	91.7	(19)	
(20)			MCWB	80.7	80.7	80.8	80.7	78.8	76.5	73.1	73.6	76.6	78.3	80.9	81.1	(20)	
(21)		2%	DB	89.4	89.0	88.8	88.4	86.0	83.6	81.7	82.0	84.6	87.2	89.9	90.6	(21)	
(22)			MCWB	80.3	80.4	80.3	79.7	77.8	75.9	73.3	73.5	76.2	78.1	80.2	80.7	(22)	
(23)		5%	DB	88.4	88.0	88.0	87.5	85.2	82.8	80.9	81.3	83.7	86.3	88.9	89.8	(23)	
(24)			MCWB	80.2	80.1	80.0	79.2	77.4	75.3	73.2	73.2	75.8	77.9	79.7	80.1	(24)	
(25)		10%	DB	87.5	87.0	87.1	86.7	84.4	81.9	80.1	80.5	83.0	85.5	88.0	88.9	(25)	
(26)			MCWB	80.1	79.9	79.8	79.0	77.1	74.8	73.0	72.9	75.5	77.7	79.2	79.9	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.3	82.5	83.5	84.5	81.3	79.9	78.5	76.5	79.1	81.0	85.1	87.1	(27)
(28)				MADB	86.7	87.2	87.1	87.6	84.2	81.0	79.1	80.2	83.1	84.5	86.4	88.4	(28)
(29)	2%		WB	82.0	81.7	82.3	82.6	80.1	78.7	76.7	75.8	78.0	80.0	83.6	85.3	(29)	
(30)			MADB	86.3	86.3	86.4	86.0	83.8	80.7	79.3	79.9	82.4	84.2	85.9	86.8	(30)	
(31)	5%		WB	81.4	81.2	81.6	81.4	79.4	77.6	75.6	75.2	77.3	79.2	82.4	83.9	(31)	
(32)			MADB	86.0	85.7	86.0	85.3	83.5	81.0	79.2	79.7	81.9	84.0	85.5	86.2	(32)	
(33)	10%		WB	80.9	80.8	80.9	80.5	78.8	76.7	74.8	74.5	76.7	78.8	81.0	81.3	(33)	
(34)			MADB	85.7	85.3	85.6	84.8	83.2	81.0	79.0	79.3	81.5	83.9	86.1	87.1	(34)	
(35)	Mean Daily Temperature Range		5% DB	MDBR	6.0	5.9	6.1	5.7	5.3	5.5	5.5	5.6	5.5	6.0	6.0	(35)	
(36)				MCDBR	6.7	6.6	6.7	6.4	5.8	5.6	5.7	5.9	6.1	6.2	6.8	6.6	(36)
(37)		MCWBR		3.1	3.0	3.4	3.3	3.6	4.1	4.3	3.8	2.9	2.8	3.1	2.9	(37)	
(38)		5% WB	MCDBR	6.2	6.1	6.3	5.9	4.9	4.7	4.7	5.3	5.5	5.5	6.7	5.8	(38)	
(39)			MCWBR	3.3	3.3	3.7	3.4	3.4	3.7	4.0	3.4	2.7	2.9	3.4	3.2	(39)	
(40)		Clear-Sky Solar Irradiance	taub	0.416	0.406	0.394	0.384	0.384	0.371	0.362	0.369	0.403	0.422	0.420	0.405	(40)	
(41)	taud		2.539	2.564	2.605	2.622	2.592	2.592	2.611	2.567	2.457	2.418	2.464	2.554	(41)		
(42)	Ebn at Noon		294	295	294	287	277	276	282	287	286	287	291	297	(42)		
(43)	Edh at Noon		35	34	32	30	29	29	29	31	36	39	37	35	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1655	1712	1672	1718	1653	1586	1679	1927	2122	2217	2165	1822	(44)		
(45)		RadStd	204	231	187	207	120	74	58	55	65	85	96	215	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.72	N/A	N/A	N/A	N/A	-0.85	N/A	N/A	N/A	N/A

Nomenclature: See separate page