

MILINGIMBI, Australia

WMO: 941400

Lat: 12.0931S

Lon: 134.8919E

Elev: 54

StdP: 14.67

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	59.6	63.0	49.1	51.8	70.9	52.4	58.6	72.5	18.3	81.5	16.7	81.1	3.9	160	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.0	93.5	78.6	92.3	78.5	91.3	78.4	83.0	88.3	82.1	87.5	81.2	87.1	9.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.7	165.3	86.3	80.7	159.7	85.4	79.8	154.8	84.6	47.1	88.3	46.0	87.8	45.1	87.3	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	14.4	13.2	57.3	96.9	3.0	2.2	55.2	98.4	53.4	99.7	51.7	100.9	49.6	102.5		
(5)			54.3	82.7	2.6	1.0	52.4	83.5	50.9	84.1	49.4	84.6	47.5	85.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	83.5	83.0	82.9	82.0	80.0	76.7	75.6	75.5	78.5	81.1	83.6	84.4	(6)
(7)		DBStd	4.38	2.46	2.18	2.00	1.76	2.41	3.27	2.81	3.69	2.55	3.84	3.12	5.11	(7)
(8)		HDD50	2	0	0	0	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD65	11	0	0	0	0	0	0	0	4	0	0	0	7	(9)
(10)		CDD50	11154	1037	924	1021	960	931	802	792	791	855	965	1008	1068	(10)
(11)		CDD65	5689	572	504	556	510	466	352	327	330	405	501	558	608	(11)
(12)		CDH74	61206	6658	5652	6188	5570	4556	2842	2482	2720	3911	5765	7011	7851	(12)
(13)		CDH80	23095	2674	2099	2309	2083	1558	791	610	722	1202	2211	3135	3701	(13)
(14)	Wind	WSAvg	6.7	6.5	6.5	5.5	6.3	7.7	8.1	7.8	7.5	6.7	6.4	5.8	6.0	(14)
(15)	Precipitation	PrecAvg	47.2	11.1	10.2	11.3	3.5	1.1	0.3	0.1	0.0	0.0	0.4	2.3	6.9	(15)
(16)		PrecMax	72.8	20.7	20.2	22.8	16.6	4.8	5.4	1.5	0.4	0.9	2.0	17.5	19.7	(16)
(17)		PrecMin	30.7	4.9	2.4	2.8	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.7	(17)
(18)		PrecStd	12.2	4.1	5.0	5.6	4.2	1.4	1.1	0.3	0.1	0.2	0.6	3.7	4.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.3	93.7	93.6	92.0	91.1	88.9	88.2	89.0	90.9	92.9	94.1	95.8	(19)
(20)			MCWB	80.6	80.4	79.0	77.1	76.0	73.4	71.5	68.7	71.0	73.8	77.1	79.1	(20)
(21)		2%	DB	92.3	91.5	91.6	90.7	89.4	87.3	86.6	87.1	88.8	90.8	92.2	93.6	(21)
(22)			MCWB	80.5	80.3	79.2	77.0	75.3	73.1	71.1	69.5	72.7	76.1	77.9	78.9	(22)
(23)		5%	DB	90.8	90.0	90.1	89.5	88.2	86.0	85.1	85.5	87.2	89.5	90.9	92.1	(23)
(24)			MCWB	80.3	80.0	79.2	76.7	75.1	72.7	70.7	69.7	73.1	76.4	77.9	78.8	(24)
(25)		10%	DB	89.3	88.5	88.6	88.3	86.9	84.5	83.6	84.1	85.8	88.2	89.9	90.9	(25)
(26)			MCWB	80.0	79.7	79.2	76.7	74.8	72.2	70.3	70.0	73.3	76.2	77.8	78.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	84.5	83.8	83.9	81.9	79.8	78.2	76.3	77.3	79.0	81.4	82.3	83.0	(27)
(28)			MCDWB	90.7	88.9	88.3	85.7	85.7	82.9	82.5	81.5	82.9	86.1	89.0	89.0	(28)
(29)		2%	WB	82.9	82.4	82.5	80.1	78.4	76.4	74.7	75.4	77.1	79.8	80.9	81.7	(29)
(30)			MCDWB	88.5	87.6	87.2	85.5	85.4	82.7	81.5	80.9	83.5	85.6	87.9	88.3	(30)
(31)		5%	WB	81.8	81.4	81.3	79.1	77.5	75.3	73.6	73.9	76.1	78.6	79.9	80.8	(31)
(32)			MCDWB	87.4	86.8	86.7	85.5	84.6	82.7	81.1	80.8	83.1	85.6	87.3	87.9	(32)
(33)		10%	WB	80.8	80.5	80.2	78.3	76.7	74.3	72.5	72.7	75.3	77.6	79.1	80.0	(33)
(34)			MCDWB	86.7	86.2	85.8	84.9	83.7	81.6	80.3	80.3	82.6	85.2	86.9	87.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	10.8	11.6	13.3	14.8	16.4	17.5	18.0	16.2	13.9	13.0	12.0	(35)
(36)			MCDBR	13.3	13.0	13.9	14.8	15.5	16.3	17.8	19.0	17.3	14.9	13.7	13.5	(36)
(37)			MCWBR	5.4	5.0	5.5	4.8	5.2	5.7	6.4	7.1	6.2	5.0	4.1	4.2	(37)
(38)		5% WB	MCDWB	12.2	11.9	12.2	12.8	13.2	14.2	15.4	15.3	14.6	13.2	13.0	12.6	(38)
(39)			MCWBR	6.8	6.0	6.6	5.1	5.3	5.7	6.6	7.0	6.0	5.1	4.9	5.2	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.414	0.404	0.395	0.382	0.375	0.362	0.353	0.363	0.405	0.419	0.425	0.415	(41)	
(42)		taud	2.528	2.556	2.579	2.602	2.590	2.591	2.610	2.556	2.423	2.403	2.429	2.504	(42)	
(43)		Ebn at Noon	295	296	293	287	279	278	283	289	285	288	290	294	(43)	
		Edh at Noon	36	34	33	30	29	28	28	31	38	40	39	36		
(44)	All-Sky Solar Radiation	RadAvg	1674	1716	1679	1697	1620	1548	1639	1891	2108	2211	2165	1888	(44)	
(45)		RadStd	207	257	189	210	121	87	67	66	81	95	99	184	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page