

CAPE WESSEL, Australia

WMO: 941470

Lat: 11.004S

Lon: 136.759E

Elev: 19

StdP: 101.09

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.8	23.2	16.4	11.7	24.3	17.5	12.5	24.6	13.0	25.2	12.4	25.4	7.2	150	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.9	34.3	26.9	33.7	26.8	33.1	26.7	28.9	30.8	28.2	30.9	27.8	30.8	4.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.5	24.9	29.6	27.8	23.8	29.2	27.2	23.0	29.3	94.3	30.7	91.3	30.8	89.3	30.8	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.6	11.6	10.8	DB	21.8	35.5	0.8	0.8	21.2	36.1	20.8	36.6	20.3	37.1	19.8	37.7	
			WB	17.9	29.4	1.4	1.1	16.9	30.1	16.0	30.7	15.2	31.3	14.1	32.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	29.2	28.8	28.8	28.8	28.1	27.0	26.3	26.4	27.5	28.8	29.8	30.0
	DBStd	1.63	1.35	1.42	1.26	1.20	1.00	1.03	0.91	0.88	0.80	0.89	0.89	1.34
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6674	594	527	582	564	562	509	505	509	524	583	595	620
	CDD18.3	3633	336	293	324	314	304	259	247	251	274	324	345	362
	CDH23.3	39188	4132	3523	3821	3665	3264	2297	1776	1793	2451	3559	4271	4636
	CDH26.7	14044	1715	1368	1424	1343	916	416	281	394	740	1339	1918	2189
Wind	WSAvg	6.4	6.1	6.2	5.4	6.2	7.8	8.5	8.3	7.0	6.1	5.5	4.4	4.6
Precipitation	PrecAvg	1377	268	283	235	167	102	37	17	7	8	14	37	137
	PrecMax	2128	662	666	537	964	552	247	83	23	56	131	359	433
	PrecMin	198	19	9	6	16	0	0	1	0	0	0	0	0
	PrecStd	556	165	195	126	204	130	55	20	7	15	29	79	123
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.3	33.7	33.4	33.1	31.9	30.9	30.2	30.9	32.1	33.7	34.6	35.5
		MCWB	27.3	27.6	27.6	26.9	26.3	25.0	24.4	24.2	25.4	25.9	26.6	26.9
	2%	DB	33.3	33.0	32.7	32.3	31.2	30.1	29.6	30.1	31.3	32.9	33.9	34.7
		MCWB	27.2	27.4	27.3	26.6	26.0	24.7	24.2	24.1	25.0	25.8	26.6	26.8
	5%	DB	32.6	32.2	32.1	31.8	30.7	29.5	28.9	29.5	30.8	32.2	33.3	34.0
		MCWB	27.1	27.2	27.1	26.4	25.7	24.5	23.9	23.8	24.7	25.7	26.4	26.7
	10%	DB	31.8	31.4	31.4	31.1	30.1	28.9	28.3	28.9	30.2	31.7	32.8	33.2
		MCWB	27.0	27.0	27.0	26.2	25.5	24.2	23.6	23.4	24.5	25.5	26.2	26.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.2	29.2	29.6	29.1	27.2	26.4	25.9	25.7	26.6	27.9	28.2	29.4
		MCDB	30.8	30.9	30.7	29.9	30.2	28.6	28.5	28.9	30.5	31.1	32.5	31.0
	2%	WB	28.2	28.5	28.7	27.9	26.7	25.5	25.2	25.1	25.9	26.8	27.5	28.4
		MCDB	30.9	30.9	30.5	30.4	29.9	28.5	27.8	28.6	29.4	31.2	32.2	31.2
	5%	WB	27.7	27.9	28.0	27.3	26.3	25.1	24.7	24.5	25.5	26.2	27.0	27.7
		MCDB	30.8	30.8	30.4	30.2	29.4	28.3	27.5	28.3	29.3	30.8	31.8	31.2
	10%	WB	27.3	27.5	27.5	26.9	26.0	24.7	24.2	24.0	25.0	25.8	26.6	27.2
		MCDB	30.5	30.4	30.1	29.9	29.0	27.9	27.4	27.9	29.3	30.3	31.4	31.5
Mean Daily Temperature Range	5% DB	MDBR	4.8	4.6	4.7	4.5	4.0	4.1	4.5	5.5	6.2	6.4	6.4	5.9
		MCDBR	5.8	5.4	5.5	5.2	4.5	4.5	5.0	6.1	6.6	6.7	6.8	7.2
		MCWBR	2.6	2.6	2.8	2.8	2.4	2.4	2.5	2.7	2.6	2.7	2.6	2.6
	5% WB	MCDBR	5.1	5.1	4.9	4.8	4.1	4.0	4.7	5.8	6.2	6.6	6.5	6.2
MCWBR		2.8	3.0	3.1	2.9	2.4	2.4	2.5	2.6	2.7	2.9	2.8	3.0	
Clear-Sky Solar Irradiance	taub		0.414	0.405	0.392	0.388	0.396	0.390	0.378	0.376	0.400	0.409	0.410	0.401
	taud		2.550	2.573	2.620	2.617	2.562	2.558	2.591	2.577	2.488	2.462	2.497	2.567
	Ebn at Noon		929	931	928	901	862	852	872	900	906	917	926	939
	Edh at Noon		109	107	99	95	95	93	92	97	112	118	115	107
All-Sky Solar Radiation	RadAvg		5.09	5.14	5.01	5.03	4.77	4.48	4.83	5.71	6.49	6.91	6.88	5.95
	RadStd		0.69	0.84	0.50	0.66	0.51	0.36	0.21	0.21	0.21	0.30	0.35	0.71

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	+0.41	+0.18	+0.26	N/A	N/A	N/A	N/A

Nomenclature: See separate page