

GOVE, Australia

WMO: 941500

Lat: 12.2742S

Lon: 136.8203E

Elev: 175

StdP: 14.60

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	62.6	64.7	53.2	60.7	75.3	55.5	66.1	74.5	23.1	78.6	21.7	79.0	2.3	160	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.1	93.0	77.2	91.6	77.3	90.4	77.1	80.8	86.3	80.0	85.7	79.6	85.2	12.1	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	152.4	82.9	78.9	150.9	82.7	78.4	148.4	82.4	44.7	87.0	43.9	86.4	43.4	85.4	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.6	17.1	DB	57.6	95.9	2.6	1.6	55.7	97.0	54.2	97.9	52.7	98.8	50.8	99.9	(4)
(5)			WB	55.9	82.6	2.6	2.0	54.0	84.1	52.4	85.3	51.0	86.4	49.0	87.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.5	82.7	82.4	81.6	80.5	79.1	76.5	74.8	74.5	76.8	79.9	82.4	83.5
	DBStd	3.78	2.26	2.26	1.94	1.77	2.16	2.48	2.50	2.30	2.29	2.28	2.04	2.26
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10783	1015	906	978	916	902	796	770	760	803	925	972	1040
	CDD65	5308	550	486	513	466	437	346	305	295	353	460	522	575
	CDH74	51292	6045	5165	5157	4560	3837	2228	1663	1926	3103	4768	6008	6832
	CDH80	17036	2176	1780	1686	1409	907	318	176	325	956	1822	2566	2915
Wind	WSAvg	8.3	7.9	7.4	6.4	7.8	9.8	10.8	10.6	9.6	8.1	7.6	6.8	6.9
Precipitation	PrecAvg	56.7	11.1	11.0	10.7	8.9	3.3	1.3	0.7	0.2	0.1	0.2	1.9	6.9
	PrecMax	104.6	29.1	22.5	20.3	42.5	14.7	4.4	2.7	1.1	1.3	3.2	11.2	20.3
	PrecMin	27.2	1.1	2.6	0.2	0.3	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0
	PrecStd	14.8	5.4	5.4	5.6	8.3	3.7	1.1	0.7	0.3	0.2	0.6	2.8	4.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.4	93.0	91.8	90.1	88.0	85.9	84.5	86.2	89.3	92.5	93.6	95.0
		MCWB	79.1	79.1	77.7	75.9	75.2	74.1	72.4	70.9	71.3	73.3	75.9	76.9
	2%	DB	91.5	91.2	89.9	88.8	86.3	84.3	82.8	84.4	87.5	89.9	91.7	93.1
		MCWB	78.7	78.5	77.5	76.0	74.9	73.4	71.7	70.9	72.6	74.9	76.3	77.3
	5%	DB	89.8	89.6	88.6	87.7	85.7	83.0	82.1	82.8	86.1	88.6	90.4	91.5
		MCWB	78.5	78.3	77.7	76.2	74.8	72.8	71.4	70.5	72.6	75.0	76.4	77.3
	10%	DB	88.2	87.9	87.5	86.3	84.4	82.1	80.7	82.1	84.7	87.6	89.4	89.9
		MCWB	78.6	78.3	77.8	76.0	74.3	72.4	70.7	70.2	72.3	75.0	76.4	77.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	81.1	81.4	79.8	79.1	76.7	75.9	76.0	78.0	78.9	80.4	81.4
		MCDB	87.4	86.9	86.3	84.8	83.8	81.5	80.1	80.8	83.3	85.2	86.9	86.5
	2%	WB	80.5	80.1	80.1	79.0	78.1	75.6	74.6	74.2	76.1	77.8	79.2	80.1
		MCDB	86.2	85.5	85.4	84.2	82.9	80.6	79.3	80.2	82.4	84.8	86.0	86.2
	5%	WB	79.9	79.7	79.3	78.5	77.3	74.7	73.7	72.9	75.0	77.0	78.7	79.5
		MCDB	85.4	85.1	84.5	83.6	82.1	79.9	78.7	79.1	82.0	84.6	85.6	85.7
	10%	WB	79.3	79.2	78.9	78.0	76.4	74.0	72.6	72.1	74.1	76.3	78.1	79.0
		MCDB	84.7	84.5	84.0	83.0	81.4	79.4	78.0	78.4	81.5	83.9	85.1	85.4
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.0	11.4	11.8	11.2	10.7	12.4	15.4	17.4	16.4	15.3	13.1
		MCDBR	13.2	13.4	13.7	14.0	12.6	11.9	13.6	17.1	18.2	17.2	16.3	15.2
		MCWBR	4.5	4.5	4.6	4.9	4.9	4.9	5.4	6.8	6.9	5.9	5.0	4.3
	5% WB	MCDBR	11.5	11.4	11.4	11.0	10.3	10.5	11.1	14.6	15.9	15.4	14.0	12.7
	MCWBR	4.6	4.5	4.5	4.6	4.6	4.6	4.6	4.8	6.1	6.4	5.4	4.6	4.3
Clear-Sky Solar Irradiance	taub	0.411	0.407	0.388	0.384	0.383	0.374	0.360	0.361	0.394	0.413	0.416	0.404	
	taud	2.540	2.547	2.612	2.601	2.571	2.573	2.610	2.582	2.466	2.421	2.454	2.538	
	Ebn at Noon	296	295	295	286	276	274	281	289	289	290	292	297	
	Edh at Noon	35	35	32	30	30	29	28	30	36	39	38	35	
All-Sky Solar Radiation	RadAvg	1649	1669	1618	1587	1501	1405	1515	1806	2058	2182	2137	1880	
	RadStd	222	244	166	210	142	117	68	69	92	121	117	195	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.74	+0.32	+0.47	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+0.74	+0.32	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page