

GOVE, Australia

WMO: 941500

Lat: 12.2742S

Lon: 136.8203E

Elev: 53

StdP: 100.69

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	18.1	11.8	8.7	24.0	13.1	9.4	23.6	10.3	25.9	9.7	26.1	1.0	160	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.3	33.9	25.1	33.1	25.1	32.4	25.1	27.1	30.2	26.7	29.8	26.5	29.6	5.4	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	28.3	26.1	21.6	28.2	25.8	21.2	28.0	86.2	30.5	84.3	30.2	83.1	29.7	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.3	7.6	14.2	35.5	1.5	0.9	13.2	36.1	12.3	36.6	11.5	37.1	10.4	37.7
			13.3	28.1	1.5	1.1	12.2	28.9	11.3	29.6	10.5	30.2	9.5	31.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.4	28.2	28.0	27.5	27.0	26.2	24.7	23.8	23.6	24.9	26.6	28.0	28.6	(6)
	DBStd	2.10	1.25	1.25	1.08	0.98	1.20	1.38	1.39	1.28	1.27	1.27	1.13	1.25	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	5991	564	503	543	509	501	442	428	422	446	514	540	578	(10)
	CDD18.3	2949	306	270	285	259	243	192	169	164	196	256	290	319	(11)
	CDH23.3	28496	3358	2869	2865	2533	2132	1238	924	1070	1724	2649	3338	3796	(12)
(13)	CDH26.7	9464	1209	989	937	783	504	177	98	181	531	1012	1426	1619	(13)
(14)	Wind	WSAvg	3.7	3.5	3.3	2.9	3.5	4.4	4.8	4.3	3.6	3.4	3.0	3.1	(14)
(15) Precipitation	PrecAvg	1439	282	280	273	227	85	33	19	5	2	6	47	174	(15)
	PrecMax	2657	740	571	515	1080	373	111	68	28	32	81	284	516	(16)
	PrecMin	690	27	65	6	7	3	0	2	0	0	0	1	1	(17)
	PrecStd	376	138	136	141	211	93	28	17	8	6	14	72	114	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	33.9	33.2	32.3	31.1	29.9	29.1	30.1	31.9	33.6	34.2	35.0	(19)
		MCWB	26.2	26.2	25.4	24.4	24.0	23.4	22.4	21.6	21.9	22.9	24.4	25.0	(20)
	2%	DB	33.0	32.9	32.2	31.5	30.2	29.1	28.2	29.1	30.9	32.2	33.2	33.9	(21)
		MCWB	26.0	25.8	25.3	24.5	23.8	23.0	22.1	21.6	22.6	23.8	24.6	25.2	(22)
	5%	DB	32.1	32.0	31.4	30.9	29.8	28.3	27.9	28.2	30.1	31.4	32.4	33.1	(23)
		MCWB	25.8	25.7	25.4	24.6	23.8	22.7	21.9	21.4	22.5	23.9	24.7	25.2	(24)
	10%	DB	31.2	31.1	30.8	30.2	29.1	27.8	27.1	27.8	29.3	30.9	31.9	32.2	(25)
		MCWB	25.9	25.7	25.5	24.4	23.5	22.5	21.5	21.2	22.4	23.9	24.6	25.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.3	27.4	26.6	26.2	24.9	24.4	24.4	25.6	26.1	26.9	27.5	(27)
		MCDB	30.8	30.5	30.1	29.4	28.8	27.5	26.7	27.1	28.5	29.6	30.5	30.3	(28)
	2%	WB	26.9	26.7	26.7	26.1	25.6	24.2	23.7	23.4	24.5	25.4	26.2	26.7	(29)
		MCDB	30.1	29.7	29.7	29.0	28.3	27.0	26.3	26.8	28.0	29.3	30.0	30.1	(30)
	5%	WB	26.6	26.5	26.3	25.8	25.1	23.7	23.2	22.7	23.9	25.0	25.9	26.4	(31)
		MCDB	29.7	29.5	29.2	28.6	27.9	26.6	25.9	26.2	27.8	29.2	29.8	29.9	(32)
	10%	WB	26.3	26.2	26.1	25.5	24.7	23.4	22.6	22.3	23.4	24.6	25.6	26.1	(33)
		MCDB	29.3	29.2	28.9	28.3	27.5	26.3	25.6	25.8	27.5	28.8	29.5	29.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.1	6.3	6.6	6.2	5.9	6.9	8.6	9.7	9.1	8.5	7.3	(35)
		MCDBR	7.3	7.4	7.6	7.8	7.0	6.6	7.5	9.5	10.1	9.6	9.0	8.4	(36)
	5% WB	MCWBR	2.5	2.5	2.6	2.7	2.7	2.7	3.0	3.8	3.9	3.3	2.8	2.4	(37)
		MCWBR	6.4	6.4	6.3	6.1	5.7	5.8	6.2	8.1	8.8	8.6	7.8	7.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.411	0.407	0.388	0.384	0.383	0.374	0.360	0.361	0.394	0.413	0.416	0.404	(40)
		taud	2.540	2.547	2.612	2.601	2.571	2.573	2.610	2.582	2.466	2.421	2.454	2.538	(41)
	Ebn at Noon	Ebn at Noon	933	929	930	902	871	864	886	912	910	914	921	937	(42)
		Edh at Noon	111	109	100	96	94	91	89	96	114	123	120	110	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.20	5.26	5.10	5.00	4.73	4.43	4.78	5.69	6.49	6.88	6.74	5.93	(44)
	RadStd	RadStd	0.70	0.77	0.52	0.66	0.45	0.37	0.21	0.22	0.29	0.38	0.37	0.62	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.41	+0.18	+0.26	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+0.41	+0.18	+0.26	N/A	N/A	N/A	N/A

Nomenclature: See separate page