

NORTH EAST ISLAND, Australia

WMO: 941510

Lat: 13.645S

Lon: 136.944E

Elev: 60

StdP: 14.66

Time Zone: 9.50 (AUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	67.9	70.1	52.4	58.6	72.6	54.6	63.6	73.2	24.9	75.4	23.1	75.9	9.4	130	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.8	92.1	78.9	91.3	78.6	90.6	78.4	81.0	88.8	80.3	88.3	79.8	87.8	8.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.1	86.1	78.1	146.2	85.5	77.4	142.9	85.0	44.8	88.8	44.0	88.6	43.5	88.3	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.3	20.7	18.4	DB	67.3	94.3	2.8	0.7	65.3	94.8	63.6	95.3	62.0	95.7	60.0	96.2
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	84.1	84.5	84.0	83.4	81.7	77.7	75.9	76.0	78.9	82.5	84.9	85.8	(6)
(7)		DBStd	4.31	4.65	3.21	2.81	2.58	2.46	2.80	2.00	1.72	1.78	1.69	1.62	2.54	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11529	1056	965	1054	1003	981	830	802	806	867	1008	1048	1109	(10)
(11)		CDD65	6054	591	545	589	553	516	380	337	341	417	543	598	644	(11)
(12)		CDH74	63733	7455	6851	7184	6478	5314	2504	1390	1509	3224	5944	7481	8399	(12)
(13)		CDH80	23325	3345	3006	2943	2395	1379	275	62	92	649	1951	3230	3998	(13)
(14)	Wind	WSAvg	9.4	9.4	9.2	8.9	10.7	12.5	11.9	10.8	9.4	7.7	7.6	7.3	7.7	(14)
(15)	Precipitation	PrecAvg	37.8	6.7	6.6	9.7	8.8	1.6	0.2	0.1	0.0	0.0	0.6	1.6	4.6	(15)
(16)		PrecMax	68.2	17.7	12.3	28.5	29.0	6.4	0.8	0.4	0.3	0.3	5.1	11.9	15.3	(16)
(17)		PrecMin	15.0	2.3	1.2	0.5	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)
(18)		PrecStd	15.9	4.1	3.1	7.7	8.2	1.8	0.2	0.1	0.1	0.1	1.2	2.7	4.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.7	92.6	91.9	91.2	89.2	85.5	82.8	83.5	87.0	90.2	92.1	93.4	(19)
(20)			MCWB	79.5	79.2	78.5	76.8	76.3	74.4	74.1	73.5	75.4	77.2	79.4	79.1	(20)
(21)		2%	DB	91.5	91.3	90.8	89.9	87.7	84.0	81.6	81.9	85.6	89.0	90.9	92.2	(21)
(22)			MCWB	79.3	78.9	78.0	76.6	76.1	73.4	73.2	72.4	74.9	76.9	78.5	78.9	(22)
(23)		5%	DB	90.4	90.2	89.8	88.8	86.5	82.9	80.6	81.0	84.7	88.1	90.0	91.3	(23)
(24)			MCWB	79.0	78.6	77.9	76.6	75.4	72.6	72.5	71.8	74.5	76.6	78.0	78.7	(24)
(25)		10%	DB	89.3	89.1	88.7	87.7	85.4	81.6	79.5	80.0	83.6	87.1	89.2	90.3	(25)
(26)			MCWB	78.8	78.4	77.8	76.5	74.7	71.9	71.3	71.1	74.1	76.3	77.7	78.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.0	81.0	80.9	80.0	78.3	75.6	75.8	75.4	77.8	79.1	81.0	81.5	(27)
(28)			MCD B	88.9	88.8	89.2	87.5	85.7	81.7	81.4	81.1	85.1	87.7	88.8	89.6	(28)
(29)		2%	WB	81.1	80.5	79.9	79.1	77.4	74.6	74.3	74.4	76.5	78.3	80.1	80.4	(29)
(30)			MCD B	88.5	88.5	87.8	86.0	84.7	81.2	79.3	79.8	83.1	86.6	87.7	89.3	(30)
(31)		5%	WB	80.1	79.9	79.2	78.4	76.9	73.8	73.3	73.6	75.9	77.9	79.3	79.8	(31)
(32)			MCD B	87.8	87.8	86.7	85.1	84.2	80.5	77.8	78.8	82.7	85.9	87.3	88.5	(32)
(33)		10%	WB	79.6	79.3	78.8	77.9	76.3	73.1	72.4	72.6	75.1	77.3	78.6	79.2	(33)
(34)			MCD B	87.2	87.1	85.9	84.5	83.7	79.8	77.2	77.7	82.1	85.0	86.9	87.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	7.8	7.5	7.0	6.3	6.3	6.8	8.1	9.5	9.7	9.3	8.8	(35)
(36)			MCDBR	9.1	9.0	8.9	8.5	7.6	7.2	7.6	9.2	10.3	10.3	9.8	9.7	(36)
(37)			MCWBR	4.0	3.8	3.8	3.8	3.9	4.3	3.8	4.3	4.2	4.0	3.6	3.5	(37)
(38)		5% WB	MCDBR	8.9	9.3	8.4	8.1	7.1	6.3	7.2	9.4	10.1	10.2	9.6	9.6	(38)
(39)			MCWBR	4.2	3.9	4.1	3.8	3.5	4.0	3.8	4.0	4.0	4.0	3.8	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.404	0.397	0.389	0.383	0.374	0.359	0.348	0.346	0.381	0.407	0.419	0.410	(40)	
(41)		taud	2.566	2.589	2.612	2.603	2.599	2.607	2.634	2.615	2.495	2.437	2.447	2.523	(41)	
(42)		Ebn at Noon	298	298	294	286	278	278	284	293	292	292	292	296	(42)	
(43)		Edh at Noon	34	33	32	30	29	28	27	30	35	38	38	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1819	1831	1727	1653	1552	1470	1600	1874	2110	2243	2206	1999	(44)	
(45)		RadStd	190	225	173	211	121	115	57	59	82	98	100	193	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.74	+0.32	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page