

NORTH EAST ISLAND, Australia

WMO: 941510

Lat: 13.645S

Lon: 136.944E

Elev: 18

StdP: 101.11

Time Zone: 9.50 (AUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	21.2	11.4	8.4	22.6	12.6	9.1	22.9	11.1	24.1	10.3	24.4	4.2	130	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.9	33.4	26.1	33.0	25.9	32.5	25.8	27.2	31.6	26.8	31.3	26.6	31.0	3.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	30.1	25.6	20.9	29.7	25.2	20.4	29.4	86.2	31.5	84.5	31.4	83.3	31.3	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.2	8.2	19.6	34.6	1.6	0.4	18.5	34.9	17.6	35.1	16.7	35.4	15.5	35.7		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	28.9	29.2	28.9	28.6	27.6	25.4	24.4	24.4	26.1	28.1	29.4	29.9
	DBStd	2.39	2.59	1.78	1.56	1.43	1.36	1.56	1.11	0.96	0.99	0.94	0.90	1.41
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6405	587	536	586	557	545	461	446	448	482	560	582	616
	CDD18.3	3363	328	303	327	307	287	211	187	189	232	302	332	358
	CDH23.3	35407	4142	3806	3991	3599	2952	1391	772	838	1791	3302	4156	4666
	CDH26.7	12958	1858	1670	1635	1331	766	153	34	51	361	1084	1794	2221
Wind	WSAvg	4.2	4.2	4.1	4.0	4.8	5.6	5.3	4.8	4.2	3.4	3.4	3.3	3.4
Precipitation	PrecAvg	959	169	168	246	223	41	6	2	1	1	14	41	118
	PrecMax	1733	449	312	723	737	163	21	9	9	8	129	302	389
	PrecMin	381	58	30	13	37	0	1	0	0	0	0	0	15
	PrecStd	405	103	80	196	209	45	5	3	3	2	30	69	101
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	33.7	33.3	32.9	31.8	29.7	28.2	28.6	30.5	32.3	33.4	34.1
		MCWB	26.4	26.2	25.8	24.9	24.6	23.6	23.4	23.1	24.1	25.1	26.3	26.2
	2%	DB	33.0	33.0	32.7	32.2	30.9	28.9	27.6	27.7	29.8	31.7	32.7	33.5
		MCWB	26.3	26.0	25.5	24.8	24.5	23.0	22.9	22.5	23.8	24.9	25.8	26.0
	5%	DB	32.5	32.3	32.1	31.6	30.3	28.3	27.0	27.2	29.3	31.2	32.2	32.9
		MCWB	26.1	25.9	25.5	24.8	24.1	22.6	22.5	22.1	23.6	24.8	25.6	25.9
	10%	DB	31.8	31.7	31.5	30.9	29.7	27.6	26.4	26.7	28.7	30.6	31.8	32.4
		MCWB	26.0	25.8	25.5	24.7	23.7	22.2	21.8	21.7	23.4	24.6	25.4	25.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.8	27.2	27.2	26.7	25.7	24.2	24.4	24.1	25.5	26.2	27.2	27.5
		MCDB	31.6	31.6	31.8	30.8	29.9	27.6	27.4	27.3	29.5	31.0	31.6	32.0
	2%	WB	27.3	26.9	26.6	26.1	25.2	23.7	23.5	23.6	24.7	25.7	26.7	26.9
		MCDB	31.4	31.4	31.0	30.0	29.3	27.3	26.3	26.5	28.4	30.4	31.0	31.8
	5%	WB	26.7	26.6	26.2	25.8	24.9	23.2	23.0	23.1	24.4	25.5	26.3	26.6
		MCDB	31.0	31.0	30.4	29.5	29.0	26.9	25.4	26.0	28.2	30.0	30.7	31.4
	10%	WB	26.4	26.3	26.0	25.5	24.6	22.9	22.4	22.6	24.0	25.2	25.9	26.2
		MCDB	30.6	30.6	30.0	29.2	28.7	26.6	25.1	25.4	27.8	29.4	30.5	30.9
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.3	4.2	3.9	3.5	3.5	3.8	4.5	5.3	5.4	5.2	4.9
		MCDBR	5.0	5.0	4.9	4.7	4.2	4.0	4.2	5.1	5.7	5.7	5.4	5.4
		MCWBR	2.2	2.1	2.1	2.1	2.1	2.4	2.1	2.4	2.3	2.2	2.0	1.9
	5% WB	MCDBR	4.9	5.2	4.7	4.5	4.0	3.5	4.0	5.2	5.6	5.7	5.3	5.3
		MCWBR	2.3	2.2	2.3	2.1	1.9	2.2	2.1	2.2	2.2	2.2	2.1	2.1
Clear-Sky Solar Irradiance	taub	0.404	0.397	0.389	0.383	0.374	0.359	0.348	0.346	0.381	0.407	0.419	0.410	
	taud	2.566	2.589	2.612	2.603	2.599	2.607	2.634	2.615	2.495	2.437	2.447	2.523	
	Ebn at Noon	939	939	928	901	877	875	895	924	921	919	920	933	
	Edh at Noon	108	105	100	95	90	87	86	93	110	121	121	112	
All-Sky Solar Radiation	RadAvg	5.74	5.77	5.44	5.21	4.89	4.63	5.04	5.91	6.65	7.07	6.95	6.30	
	RadStd	0.60	0.71	0.55	0.66	0.38	0.36	0.18	0.18	0.26	0.31	0.32	0.61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.41	+0.18	+0.26	N/A	N/A	N/A	N/A

Nomenclature: See separate page