

BORROLOOLA, AustraliaWMO: **941520**Lat: **16.0773S**Lon: **136.3050E**Elev: **54**StdP: **14.67**Time Zone: **9.50 (AUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	46.6	49.6	19.8	14.9	80.0	25.0	19.1	78.4	17.1	73.8	16.2	75.7	1.4	210	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	18.3	101.6	72.1	99.5	73.0	97.7	73.4	81.4	90.0	80.6	89.1	79.9	88.1	10.1	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	152.1	84.5	78.5	148.4	84.0	77.9	145.3	83.5	45.2	90.4	44.3	89.2	43.5	88.2	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	15.7	14.3	41.7	106.0	2.0	2.5	40.3	107.8	39.2	109.3	38.1	110.7	36.7	112.5
			38.7	82.8	2.4	1.1	36.9	83.5	35.5	84.1	34.1	84.7	32.4	85.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.6	84.6	84.1	83.1	80.4	75.0	70.3	70.2	72.4	78.6	83.5	86.3	86.9
	DBStd	7.08	3.42	3.00	2.91	3.19	4.79	5.30	4.72	4.37	3.88	3.54	2.81	3.47
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	31	0	0	0	0	3	15	11	2	0	0	0	0
	CDD50	10798	1074	955	1025	912	776	609	626	695	858	1037	1088	1143
	CDD65	5354	609	535	560	462	314	174	172	232	408	572	638	678
	CDH74	64114	7271	6191	6180	5041	3444	1987	2099	2773	4723	7180	8352	8873
	CDH80	31591	3417	2783	2817	2478	1526	703	742	1148	2480	4003	4676	4818
(14) Wind	WSAvg	6.0	5.9	5.5	5.2	5.3	5.5	5.7	5.6	6.1	6.6	6.9	6.8	6.7
(15) Precipitation	PrecAvg	37.0	8.3	8.3	7.6	2.0	0.4	0.3	0.0	0.0	0.2	0.7	2.6	6.5
	PrecMax	64.5	31.6	29.8	21.0	11.1	2.0	1.7	0.2	0.4	1.6	3.6	13.8	16.9
	PrecMin	15.3	2.3	0.6	0.4	0.0	0.2	0.2	0.0	0.0	0.0	0.0	0.2	0.9
	PrecStd	15.4	6.4	6.5	6.5	2.7	0.6	0.3	0.0	0.1	0.4	1.0	3.2	4.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.5	100.6	101.7	97.2	94.3	91.3	90.8	93.3	98.2	102.1	103.4	105.2
		MCWB	76.5	75.3	72.9	72.7	70.8	69.9	66.5	66.6	68.6	69.8	69.6	71.2
	2%	DB	97.9	96.5	96.3	95.2	92.3	89.0	88.6	90.7	95.8	99.4	100.9	101.3
		MCWB	76.8	77.4	75.3	72.9	69.4	67.7	65.4	65.4	67.8	70.3	71.2	73.7
	5%	DB	95.3	94.3	93.8	93.4	90.4	87.0	86.8	88.8	93.8	97.4	98.7	98.9
		MCWB	77.6	78.1	76.1	72.9	68.8	66.3	64.2	64.5	67.6	70.8	72.5	74.9
	10%	DB	93.0	92.1	91.7	91.5	88.3	84.4	84.6	86.7	91.8	95.2	96.6	96.3
		MCWB	78.1	78.5	76.4	72.8	68.2	64.7	63.2	63.6	66.9	71.0	72.8	75.7
	0.4%	WB	82.4	82.4	81.9	80.1	77.8	73.7	72.3	72.0	75.6	79.0	80.0	81.1
		MCDB	92.8	91.1	89.5	88.2	87.3	86.4	85.3	84.3	87.5	90.2	88.9	88.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	81.0	81.4	80.7	78.7	74.8	71.4	70.2	70.8	74.1	77.5	78.8	80.0
		MCDB	90.7	90.0	88.5	86.9	84.6	82.1	81.4	82.3	85.2	88.1	88.4	88.0
	5%	WB	80.1	80.6	79.8	77.4	73.4	69.9	68.3	69.4	73.0	76.2	77.9	79.2
		MCDB	89.1	89.1	87.4	85.4	83.6	80.6	79.0	80.5	83.9	86.9	87.7	87.7
	10%	WB	79.3	79.8	79.0	76.4	71.9	68.1	66.7	67.9	71.9	75.2	77.1	78.6
		MCDB	87.6	87.6	86.4	84.4	82.2	79.5	78.0	79.1	83.2	86.1	87.1	87.3
(35) Mean Daily Temperature Range	5% DB	MDBR	15.4	15.1	17.2	22.7	27.5	29.2	30.6	30.4	28.6	25.0	21.7	18.3
		MCDBR	20.0	19.6	21.7	25.5	27.9	29.2	30.8	30.9	29.5	27.1	25.1	22.8
		MCWBR	5.4	6.0	6.6	8.8	10.0	11.5	11.5	10.5	8.6	7.7	6.4	5.8
	5% WB	MCDBR	16.2	15.6	15.9	19.8	23.9	26.3	26.5	25.8	25.0	22.4	19.7	17.7
		MCWBR	5.5	5.9	6.3	7.9	9.8	11.5	11.2	9.9	8.0	7.0	5.7	5.1
(40) Clear-Sky Solar Irradiance	taub		0.410	0.405	0.393	0.376	0.352	0.332	0.330	0.335	0.388	0.415	0.432	0.423
	taud		2.486	2.502	2.530	2.536	2.540	2.557	2.551	2.520	2.390	2.346	2.351	2.421
	Ebn at Noon		297	295	292	286	283	284	287	295	289	289	288	292
	Edh at Noon		37	36	34	32	30	28	29	32	39	42	42	40
(44) All-Sky Solar Radiation	RadAvg		1869	1877	1836	1811	1652	1538	1642	1898	2143	2250	2204	2022
	RadStd		200	252	202	152	85	90	51	53	87	130	108	195

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page