

GROOTE EYLANDT, Australia

WMO: 941530

Lat: 13.9747S

Lon: 136.4631E

Elev: 14

StdP: 101.15

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	13.0	7.9	6.6	19.7	9.4	7.3	20.4	7.4	28.0	6.9	27.8	0.7	90	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.2	35.8	24.5	34.8	24.8	34.0	24.9	27.9	31.8	27.4	31.4	27.0	31.1	4.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	30.5	26.2	21.7	29.7	26.0	21.4	29.4	89.3	31.9	87.0	31.7	85.4	31.4	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.7	6.0	DB	9.1	37.6	1.3	1.2	8.1	38.5	7.4	39.2	6.6	39.8	5.7	40.7	(4)
(5)			WB	8.4	28.5	1.2	0.6	7.5	29.0	6.8	29.3	6.2	29.7	5.3	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	29.0	28.7	28.0	26.8	24.9	22.5	22.0	22.2	24.6	27.0	28.6	29.4
	DBStd	3.20	1.42	1.28	1.28	1.18	1.92	2.51	2.19	1.93	1.82	1.65	1.51	1.51
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	5	0	0	0	0	0	2	2	1	0	0	0	0
	CDD10.0	5887	589	525	558	504	462	376	372	377	438	527	557	602
	CDD18.3	2850	331	292	299	254	204	128	116	119	188	268	307	344
	CDH23.3	31686	4024	3430	3231	2562	1927	1018	954	1227	2047	3179	3758	4328
CDH26.7	13277	1755	1447	1297	1053	662	225	197	347	853	1523	1822	2097	
Wind	WSAvg	2.5	2.8	2.7	2.2	2.1	2.3	2.5	2.5	2.5	2.6	2.8	2.8	2.8
Precipitation	PrecAvg	1228	220	237	270	168	38	7	3	2	6	27	72	177
	PrecMax	1936	519	443	606	555	190	40	21	13	70	89	231	421
	PrecMin	684	96	55	58	26	0	0	0	0	0	0	1	35
	PrecStd	360	108	102	154	145	43	10	5	3	14	26	66	95
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.5	35.8	35.2	34.1	32.4	30.9	30.3	31.6	33.9	35.8	36.7	37.1
		MCWB	24.8	25.5	25.9	24.7	24.0	23.2	21.6	20.7	21.0	22.7	24.1	24.2
	2%	DB	34.8	34.3	33.6	33.1	31.7	29.9	29.5	30.5	32.6	34.3	34.9	35.8
		MCWB	25.5	26.1	25.9	24.8	23.8	22.6	21.4	20.5	22.1	23.3	24.2	24.7
	5%	DB	33.6	33.2	32.7	32.2	30.9	29.0	28.8	29.7	31.9	33.3	34.0	34.5
		MCWB	26.0	26.2	25.9	24.8	23.9	22.2	21.1	20.4	22.0	23.5	24.4	25.1
	10%	DB	32.5	32.2	31.8	31.5	30.0	28.0	27.9	28.8	30.9	32.4	33.1	33.5
		MCWB	26.1	26.2	26.0	24.8	23.5	21.7	20.9	20.2	22.0	23.6	24.7	25.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.2	28.6	28.6	28.2	27.0	24.7	24.0	23.8	25.3	26.5	27.2	27.8
		MCDB	32.3	32.2	32.0	31.5	30.6	28.6	28.6	28.6	30.2	31.4	31.7	31.5
	2%	WB	27.6	27.6	27.6	26.8	25.7	24.0	23.1	23.0	24.6	25.9	26.7	27.2
		MCDB	31.8	31.7	31.5	30.8	29.3	28.2	27.5	27.7	29.7	30.9	31.3	31.3
	5%	WB	27.2	27.1	27.1	26.2	25.1	23.3	22.4	22.4	24.0	25.4	26.3	26.9
		MCDB	31.2	31.2	30.8	30.1	29.0	27.3	26.8	27.3	29.4	30.5	30.8	31.1
	10%	WB	26.8	26.7	26.6	25.7	24.5	22.6	21.7	21.7	23.4	25.0	25.9	26.6
		MCDB	30.7	30.6	30.2	29.5	28.3	26.5	26.2	26.7	28.8	30.0	30.4	30.8
Mean Daily Temperature Range	5% DB	MDBR	6.9	7.1	7.7	9.7	10.5	10.7	11.8	13.5	13.2	11.8	9.6	8.2
		MCDBR	8.7	8.8	9.4	11.0	11.1	10.9	12.2	14.3	13.8	12.5	10.7	9.9
		MCWBR	3.1	3.5	4.1	5.0	5.1	5.3	5.8	6.3	5.7	4.4	3.5	3.3
	5% WB	MCDBR	7.3	7.5	7.8	9.1	9.2	9.8	10.9	12.7	12.3	10.8	9.2	8.1
		MCWBR	3.2	3.3	3.8	4.7	4.8	4.9	5.6	6.5	5.8	4.4	3.6	3.1
Clear-Sky Solar Irradiance	taub	0.403	0.397	0.389	0.382	0.370	0.354	0.341	0.342	0.375	0.407	0.420	0.411	
	taud	2.564	2.582	2.601	2.597	2.598	2.605	2.638	2.610	2.498	2.425	2.434	2.511	
	Ebn at Noon	941	939	927	902	880	879	901	928	926	918	918	932	
	Edh at Noon	108	106	101	96	90	87	86	93	110	122	122	114	
All-Sky Solar Radiation	RadAvg	5.82	5.83	5.50	5.24	4.91	4.65	5.04	5.89	6.67	7.09	6.96	6.38	
	RadStd	0.57	0.72	0.57	0.63	0.36	0.34	0.18	0.19	0.26	0.33	0.29	0.56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.41	+0.18	+0.26	N/A	N/A	N/A	N/A

Nomenclature: See separate page