

SCHERGER RAAF, Australia

WMO: 941710

Lat: 12.617S

Lon: 142.087E

Elev: 132

StdP: 14.63

Time Zone: 10.00 (E10)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.2	64.1	50.7	55.2	85.5	53.6	61.5	83.4	20.3	83.8	18.5	83.2	2.2	170	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	21.2	97.0	73.4	95.4	73.6	94.1	73.8	80.5	87.4	79.9	86.7	79.3	86.0	9.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.9	150.9	83.6	78.3	147.5	83.1	77.4	143.2	82.3	44.3	87.5	43.6	87.4	43.1	86.5	97.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.1	16.1	14.3	DB	58.0	100.4	2.0	1.0	56.5	101.1	55.3	101.7	54.2	102.3	52.7	103.0
			WB	55.5	83.9	2.8	4.9	53.5	87.3	51.9	90.2	50.3	92.9	48.3	96.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	82.2	81.9	81.7	80.9	79.2	77.1	76.4	77.6	80.3	83.2	84.9	84.4
	DBStd	3.44	2.41	2.07	1.88	1.66	2.09	2.37	2.47	2.45	2.33	2.11	1.69	2.18
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11239	997	892	982	927	905	814	817	854	910	1028	1048	1065
	CDD65	5764	532	472	517	477	440	364	352	389	460	563	598	600
	CDH74	56394	5155	4486	4688	4555	3878	2822	2787	3546	4760	6269	6870	6578
CDH80	22959	1824	1511	1554	1685	1372	864	867	1390	2258	3152	3477	3005	
Wind	WSAvg	6.3	4.8	4.9	4.7	6.0	7.1	7.3	7.4	7.0	7.3	7.2	6.1	5.2
Precipitation	PrecAvg	62.8	16.6	15.9	12.5	4.0	0.9	0.4	0.3	0.2	0.1	0.8	3.1	9.4
	PrecMax	83.0	26.9	25.8	24.3	12.6	5.7	1.9	1.1	0.9	0.4	4.1	10.4	26.3
	PrecMin	46.7	10.1	4.6	4.8	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.2	2.0
	PrecStd	10.2	3.9	4.7	5.0	3.3	1.2	0.4	0.2	0.2	0.1	1.1	3.1	5.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.4	93.2	92.6	92.2	91.5	89.6	89.6	92.4	96.0	98.4	99.0	98.6
		MCWB	76.5	77.9	78.5	76.8	76.3	73.5	71.3	71.0	70.7	72.9	74.1	73.3
	2%	DB	92.7	91.3	91.0	90.7	89.6	88.0	87.9	90.2	93.8	96.5	97.1	96.2
		MCWB	77.5	78.1	78.3	76.3	75.1	72.9	70.6	70.2	70.5	72.3	73.7	74.7
	5%	DB	90.5	89.7	89.5	89.5	88.1	86.5	86.4	88.8	92.3	94.7	95.4	94.1
		MCWB	78.1	78.4	78.0	75.9	74.4	72.3	70.5	69.8	70.6	72.7	73.7	75.6
	10%	DB	88.3	87.9	87.8	88.0	86.9	85.1	84.9	87.2	90.7	93.0	93.8	91.9
		MCWB	78.6	78.7	78.4	75.8	74.0	71.8	70.2	69.8	70.6	72.5	74.1	76.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	80.9	81.1	80.3	78.8	76.9	75.6	75.7	77.1	78.1	80.0	80.8
		MCDB	87.6	87.3	87.6	87.6	86.2	85.5	84.3	85.8	88.3	89.1	88.3	88.5
	2%	WB	80.1	80.0	80.1	79.0	77.2	75.4	74.4	74.3	75.4	76.7	79.0	79.9
		MCDB	86.5	86.4	86.7	85.4	85.8	83.6	83.1	84.3	85.9	88.1	87.8	87.5
	5%	WB	79.6	79.4	79.4	78.2	76.2	74.4	73.1	73.2	74.4	75.9	78.2	79.2
		MCDB	85.9	85.6	85.7	84.6	84.9	82.7	81.8	83.4	85.2	87.1	87.3	86.8
	10%	WB	79.0	78.9	78.8	77.4	75.3	73.3	72.0	72.1	73.2	75.1	77.3	78.6
		MCDB	85.2	85.1	84.8	84.0	84.0	81.9	81.0	82.5	84.5	86.1	86.6	86.1
Mean Daily Temperature Range	5% DB	MDBR	12.8	12.4	13.3	15.8	17.1	17.8	19.2	21.8	23.5	23.1	21.2	17.5
		MCDBR	16.8	15.7	15.8	17.8	18.7	19.4	21.0	23.6	25.4	24.8	22.9	20.7
		MCWBR	5.5	5.4	5.8	6.3	6.9	7.3	7.4	7.5	7.4	6.7	6.1	5.9
	5% WB	MCDBR	13.2	13.0	13.8	14.2	16.2	16.1	16.4	18.5	21.5	21.9	19.5	16.6
		MCWBR	5.4	5.2	5.8	6.0	6.7	6.7	6.5	6.8	6.8	6.5	6.0	5.7
Clear-Sky Solar Irradiance	taub	0.408	0.404	0.391	0.389	0.379	0.371	0.361	0.373	0.393	0.405	0.412	0.408	
	taud	2.515	2.527	2.565	2.547	2.549	2.561	2.578	2.524	2.452	2.424	2.431	2.481	
	Ebn at Noon	297	296	294	285	277	274	280	285	289	292	293	296	
	Edh at Noon	36	36	33	32	30	29	29	32	36	39	39	37	
All-Sky Solar Radiation	RadAvg	1599	1614	1612	1669	1535	1399	1478	1729	2004	2163	2138	1908	
	RadStd	192	251	123	146	92	102	86	113	93	119	134	208	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	+202	+196

Nomenclature: See separate page