

COCONUT ISLAND, Australia

WMO: 941820

Lat: 10.051S

Lon: 143.069E

Elev: 13

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	73.3	74.1	N/A	N/A	N/A	N/A	N/A	N/A	29.0	77.3	27.6	77.4	11.6	130	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.1	92.8	N/A	91.7	N/A	90.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.2	25.0	22.9	DB	71.7	95.5	2.0	1.5	70.3	96.6	69.1	97.5	67.9	98.3	66.5	99.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	83.8	83.5	83.4	83.4	82.9	81.2	80.0	79.9	81.2	82.6	84.2	84.7	(6)	
	DBStd	2.48	2.28	2.10	2.05	1.92	1.86	1.94	1.79	1.81	1.74	1.88	1.88	2.07	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	11881	1048	937	1034	1003	1020	936	930	927	935	1011	1025	1075	(10)	
	CDD65	6406	583	517	569	553	555	486	465	462	485	546	575	610	(11)	
	CDH74	67783	7105	6216	6668	6284	5872	4445	3652	3572	4291	5555	6622	7501	(12)	
(13)	CDH80	22305	2767	2319	2385	2125	1711	946	679	752	1129	1788	2563	3141	(13)	
(14)	Wind	WSAvg	9.6	8.5	8.7	7.2	9.3	10.8	12.2	11.4	10.9	10.6	8.0	7.0	(14)	
(15) Precipitation	PrecAvg	49.6	10.6	11.0	10.5	6.1	1.7	0.6	0.4	0.3	0.1	0.5	1.9	6.0	(15)	
	PrecMax	77.4	16.8	19.4	17.4	16.4	7.2	2.3	0.9	1.1	0.4	2.2	7.6	18.5	(16)	
	PrecMin	33.9	1.3	3.8	2.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)	
	PrecStd	10.9	3.8	4.1	3.5	4.0	1.9	0.6	0.2	0.2	0.1	0.6	2.2	4.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.5	91.8	92.5	92.6	91.5	90.8	89.2	89.7	90.9	92.5	94.1	94.3	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	91.4	90.2	90.7	90.7	90.0	88.5	87.3	87.7	89.0	90.7	92.3	92.7	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	89.7	88.9	89.2	89.1	88.6	86.6	85.6	86.0	87.3	89.1	90.9	91.3	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	88.2	87.8	87.8	87.6	86.9	84.8	83.8	84.2	85.8	87.6	89.4	89.9	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
(31) Mean Daily Temperature Range	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
	5% DB	MDBR	8.0	7.7	8.3	8.3	8.5	7.9	8.3	9.4	10.4	11.1	11.2	10.1	(35)	
		MCDBR	10.4	9.3	10.6	10.8	10.9	10.5	11.1	12.1	12.4	13.1	13.4	12.5	(36)	
(40) Clear-Sky Solar Irradiance	taub	taud	2.574	2.575	2.593	2.539	2.479	2.486	2.498	2.484	2.450	2.437	2.458	2.517	(41)	
		Ebn at Noon	298	296	293	279	265	261	266	274	280	285	289	294	(42)	
	Edh at Noon		34	34	32	33	33	32	32	34	37	38	38	36	(43)	
															(44)	
(44)	All-Sky Solar Radiation	RadAvg	1676	1716	1592	1527	1476	1379	1451	1660	1837	2016	2032	1892	(44)	
(45)		RadStd	163	162	87	159	129	99	87	139	138	115	153	202	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page