

COCONUT ISLAND, Australia

WMO: 941820

Lat: 10.051S

Lon: 143.069E

Elev: 4

StdP: 101.28

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.0	23.4	N/A	N/A	N/A	N/A	N/A	N/A	12.9	25.2	12.3	25.2	5.2	130	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.6	33.8	N/A	33.2	N/A	32.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.6	130

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		Extreme Max WB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
12.2	11.2	10.3	DB	22.1	35.3	1.1	0.8	21.3	35.9	20.6	36.4	20.0	36.8	19.1	37.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	28.8	28.6	28.5	28.6	28.3	27.3	26.7	26.6	27.3	28.1	29.0	29.3
	DBStd	1.38	1.26	1.17	1.14	1.07	1.03	1.08	0.99	1.01	0.96	1.04	1.04	1.15
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6601	582	521	574	557	567	520	517	515	519	562	569	597
	CDD18.3	3559	324	287	316	307	308	270	258	257	269	303	319	339
	CDH23.3	37657	3947	3453	3704	3491	3262	2469	2029	1984	2384	3086	3679	4167
Wind	WSAvg	4.3	3.8	3.9	3.2	4.1	4.8	5.5	5.1	4.9	4.9	4.8	3.6	3.1
	PrecAvg	1261	268	279	266	156	44	16	10	7	3	13	48	152
	PrecMax	1966	426	492	441	417	183	59	22	27	10	55	193	471
	PrecMin	862	34	96	55	7	0	1	1	0	0	1	1	14
	PrecStd	278	96	104	90	102	48	14	6	6	3	16	55	103
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	33.2	33.6	33.7	33.1	32.7	31.8	32.0	32.7	33.6	34.5	34.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	33.0	32.3	32.6	32.6	32.2	31.4	30.7	30.9	31.7	32.6	33.5	33.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	32.1	31.6	31.8	31.7	31.4	30.3	29.8	30.0	30.7	31.7	32.7	32.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	31.2	31.0	31.0	30.9	30.5	29.4	28.8	29.0	29.9	30.9	31.9	32.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.3	4.6	4.6	4.7	4.4	4.6	5.2	5.8	6.1	6.2	5.6
		MCDBR	5.8	5.2	5.9	6.0	6.0	5.8	6.2	6.7	6.9	7.3	7.5	6.9
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.404	0.402	0.397	0.413	0.426	0.421	0.415	0.417	0.426	0.428	0.426	0.413	
	taud	2.574	2.575	2.593	2.539	2.479	2.486	2.498	2.484	2.450	2.437	2.458	2.517	
	Ebn at Noon	938	934	923	878	836	824	839	863	883	900	910	927	
	Edh at Noon	107	106	102	103	104	101	101	107	116	121	119	112	
All-Sky Solar Radiation	RadAvg	5.28	5.41	5.02	4.81	4.65	4.35	4.57	5.23	5.79	6.35	6.41	5.96	
	RadStd	0.51	0.51	0.28	0.50	0.41	0.31	0.27	0.44	0.43	0.36	0.48	0.64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page