

COEN, Australia

WMO: 941830

Lat: 13.7614S

Lon: 143.1170E

Elev: 525

StdP: 14.42

Time Zone: 10.00 (E10)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	57.1	59.6	48.8	52.1	75.7	52.1	59.0	74.2	18.4	80.4	16.8	80.0	1.6	170	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	17.2	95.3	73.8	93.4	73.9	91.8	74.0	79.1	86.6	78.3	85.7	77.7	84.8	10.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	145.3	81.8	76.5	140.8	81.0	75.9	138.0	80.5	43.1	86.9	42.3	86.1	41.7	85.3	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 16.5	15.3	14.1	DB	52.0	100.5	3.4	2.1	49.5	102.0	47.5	103.2	45.5	104.4	43.0	105.9	
(5)			WB	50.6	80.7	3.6	1.5	48.0	81.7	45.9	82.6	43.8	83.5	41.2	84.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.5	81.8	81.6	80.7	79.1	76.6	74.0	73.1	73.4	76.4	79.6	82.1	83.5
	DBStd	4.34	2.56	2.00	1.95	1.90	2.56	3.15	3.15	2.94	2.83	2.69	2.17	2.18
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10391	986	884	952	873	824	721	716	727	791	916	963	1038
	CDD65	4917	521	464	487	423	359	272	251	262	341	451	513	573
	CDH74	44010	4905	4231	4305	3588	2643	1759	1575	1932	2950	4351	5451	6320
	CDH80	15221	1741	1393	1348	1049	628	318	228	430	1011	1793	2467	2815
(14) Wind	WSAvg	6.7	5.8	5.3	5.2	6.1	6.4	6.4	7.1	7.3	7.9	8.3	7.7	6.7
(15) Precipitation	PrecAvg	46.8	11.5	12.7	9.9	2.6	0.4	0.1	0.1	0.0	0.0	0.5	2.3	5.6
	PrecMax	74.3	28.3	23.0	28.7	14.5	2.6	0.7	0.4	0.3	0.5	6.6	11.0	14.1
	PrecMin	25.4	3.3	2.2	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	11.3	6.1	5.1	5.9	3.0	0.5	0.2	0.1	0.1	0.1	1.1	2.5	3.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.7	93.3	91.6	89.6	88.4	87.0	86.0	88.2	93.1	96.8	97.8	98.5
		MCWB	75.3	77.1	77.5	74.5	73.8	71.8	69.9	69.5	69.8	71.2	73.4	73.0
	2%	DB	92.7	91.3	89.9	88.0	86.4	84.8	84.0	85.6	89.2	93.0	94.4	95.3
		MCWB	75.6	76.8	77.2	74.7	72.8	71.1	69.3	68.8	69.4	72.0	73.5	74.1
	5%	DB	90.7	89.6	88.3	86.7	85.1	83.4	82.5	84.1	87.3	90.4	92.3	93.4
		MCWB	75.8	77.0	76.7	74.3	72.3	70.3	68.7	68.0	68.9	71.2	72.9	74.1
	10%	DB	88.4	87.7	86.7	85.5	83.6	81.9	81.0	82.6	85.6	88.3	90.6	91.5
		MCWB	76.0	76.7	76.2	73.8	71.7	69.6	68.2	67.5	68.7	70.9	72.4	74.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.5	80.0	81.1	78.9	76.7	74.6	73.4	73.1	74.7	75.4	77.3	78.7
		MCDB	86.5	88.2	87.3	85.1	84.4	82.0	81.3	82.9	86.4	88.4	89.3	88.4
	2%	WB	78.4	78.9	79.4	77.3	75.3	73.0	72.0	71.6	73.3	74.3	76.1	77.6
		MCDB	85.8	86.6	86.1	83.8	82.5	81.4	80.1	81.6	83.5	86.5	87.3	87.3
	5%	WB	77.7	78.2	78.2	76.4	74.2	72.0	70.9	70.3	71.8	73.4	75.2	76.9
		MCDB	84.8	85.4	84.6	82.8	81.8	80.4	79.4	80.6	82.7	85.1	85.8	86.4
	10%	WB	77.1	77.6	77.3	75.6	73.2	71.0	69.7	69.2	70.3	72.6	74.3	76.2
		MCDB	83.8	84.3	83.3	81.8	81.1	79.4	78.7	79.5	81.9	83.9	85.1	84.9
(35) Mean Daily Temperature Range	MDBR		13.2	12.7	12.4	13.8	15.5	17.2	17.5	19.7	20.2	19.2	19.1	17.2
	5% DB	MCDBR	17.3	16.0	15.2	15.6	17.3	18.8	18.4	21.9	23.5	23.8	22.1	20.7
		MCWBR	4.2	4.7	5.0	5.6	7.1	7.7	7.5	8.4	7.9	6.9	5.6	4.5
	5% WB	MCDBR	13.3	13.4	13.0	12.2	14.5	15.1	15.0	18.0	18.0	18.5	19.2	15.8
		MCWBR	4.5	4.8	5.4	5.3	6.8	6.8	6.9	7.7	7.1	5.7	5.2	4.3
(40) Clear-Sky Solar Irradiance	taub		0.403	0.397	0.393	0.388	0.376	0.368	0.357	0.374	0.393	0.408	0.418	0.421
	taud		2.509	2.530	2.537	2.525	2.530	2.543	2.560	2.487	2.422	2.393	2.387	2.418
	Ebn at Noon		298	298	293	284	277	274	281	284	288	291	292	293
	Edh at Noon		36	35	34	33	31	29	30	33	38	40	41	40
(44) All-Sky Solar Radiation	RadAvg		1716	1699	1654	1643	1473	1337	1439	1704	1988	2134	2132	1953
	RadStd		155	209	127	141	100	105	93	105	97	127	135	199

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	+202	+196	

Nomenclature: See separate page