

COEN, Australia

WMO: 941830

Lat: 13.7614S

Lon: 143.1170E

Elev: 160

StdP: 99.42

Time Zone: 10.00 (E10)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	15.3	9.4	7.4	24.3	11.2	8.4	23.5	8.2	26.9	7.5	26.7	0.7	170	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.5	35.2	23.2	34.1	23.3	33.2	23.3	26.2	30.3	25.7	29.8	25.4	29.4	4.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.8	27.7	24.7	20.1	27.2	24.4	19.7	26.9	82.5	30.5	80.5	30.1	79.1	29.6	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.4	6.8	6.3	DB	11.1	38.1	1.9	1.2	9.7	38.9	8.6	39.6	7.5	40.2	6.1	41.1
			WB	10.3	27.0	2.0	0.8	8.9	27.6	7.7	28.1	6.6	28.6	5.1	29.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	27.7	27.5	27.1	26.2	24.8	23.4	22.8	23.0	24.6	26.4	27.8	28.6	(6)
(7)		DBStd	2.41	1.42	1.11	1.08	1.06	1.42	1.75	1.75	1.64	1.57	1.50	1.21	1.21	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	5773	548	491	529	485	458	401	398	404	439	509	535	577	(10)
(11)		CDD18.3	2732	289	258	271	235	199	151	139	146	189	251	285	318	(11)
(12)		CDH23.3	24450	2725	2351	2392	1993	1468	977	875	1073	1639	2417	3028	3511	(12)
(13)	CDH26.7	8456	967	774	749	583	349	177	127	239	562	996	1371	1564	(13)	
(14)	Wind	WSAvg	3.0	2.6	2.4	2.3	2.7	2.8	2.9	3.2	3.2	3.6	3.7	3.5	3.0	(14)
(15)	Precipitation	PrecAvg	1189	293	323	251	67	9	2	2	1	13	58	141		(15)
(16)		PrecMax	1887	720	584	730	369	65	17	11	8	12	167	279	357	(16)
(17)		PrecMin	646	85	57	18	0	0	0	0	0	0	0	0	2	(17)
(18)		PrecStd	287	155	129	151	77	13	4	3	2	2	27	64	90	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.4	34.1	33.1	32.0	31.3	30.5	30.0	31.2	33.9	36.0	36.5	37.0	(19)
MCWB			24.0	25.1	25.3	23.6	23.2	22.1	21.0	20.8	21.0	21.8	23.0	22.8	(20)	
2%		DB	33.7	33.0	32.2	31.1	30.2	29.3	28.9	29.8	31.8	33.9	34.7	35.2	(21)	
		MCWB	24.2	24.9	25.1	23.7	22.7	21.7	20.7	20.4	20.8	22.2	23.1	23.4	(22)	
5%		DB	32.6	32.0	31.3	30.4	29.5	28.6	28.1	28.9	30.7	32.5	33.5	34.1	(23)	
		MCWB	24.4	25.0	24.8	23.5	22.4	21.3	20.4	20.0	20.5	21.8	22.7	23.4	(24)	
10%		DB	31.3	30.9	30.4	29.7	28.7	27.7	27.2	28.1	29.8	31.3	32.5	33.0	(25)	
		MCWB	24.5	24.8	24.6	23.2	22.1	20.9	20.1	19.7	20.4	21.6	22.4	23.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.7	27.3	26.1	24.8	23.7	23.0	22.9	23.7	24.1	25.2	25.9	(27)
MCD B			30.3	31.2	30.7	29.5	29.1	27.8	27.4	28.3	30.2	31.3	31.8	31.4	(28)	
2%		WB	25.8	26.1	26.3	25.2	24.0	22.8	22.2	22.0	22.9	23.5	24.5	25.4	(29)	
		MCD B	29.9	30.3	30.1	28.8	28.0	27.4	26.7	27.5	28.6	30.3	30.7	30.7	(30)	
5%		WB	25.4	25.7	25.7	24.7	23.5	22.2	21.6	21.3	22.1	23.0	24.0	24.9	(31)	
		MCD B	29.3	29.6	29.2	28.2	27.7	26.9	26.3	27.0	28.2	29.5	29.9	30.2	(32)	
10%		WB	25.1	25.3	25.2	24.2	22.9	21.7	21.0	20.6	21.3	22.6	23.5	24.6	(33)	
		MCD B	28.8	29.0	28.5	27.7	27.3	26.4	25.9	26.4	27.7	28.8	29.5	29.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.4	7.1	6.9	7.7	8.6	9.5	9.7	11.0	11.2	10.7	10.6	9.5	(35)
MCDBR			9.6	8.9	8.4	8.7	9.6	10.5	10.2	12.2	13.1	13.2	12.3	11.5	(36)	
MCWBR			2.3	2.6	2.8	3.1	3.9	4.3	4.1	4.6	4.4	3.9	3.1	2.5	(37)	
5% WB		MCDBR	7.4	7.5	7.2	6.8	8.0	8.4	8.3	10.0	10.0	10.3	10.7	8.8	(38)	
		MCWBR	2.5	2.7	3.0	3.0	3.8	3.8	3.8	4.3	3.9	3.2	2.9	2.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.403	0.397	0.393	0.388	0.376	0.368	0.357	0.374	0.393	0.408	0.418	0.421	(40)	
taud		2.509	2.530	2.537	2.525	2.530	2.543	2.560	2.487	2.422	2.393	2.387	2.418	(41)		
Ebn at Noon		941	939	924	895	874	864	885	895	909	918	920	923	(42)		
Edh at Noon		114	111	108	103	97	92	93	105	119	126	128	125	(43)		
(44)	All-Sky Solar Radiation	RadAvg	5.41	5.36	5.21	5.18	4.64	4.21	4.54	5.37	6.27	6.73	6.72	6.16	(44)	
(45)		RadStd	0.49	0.66	0.40	0.44	0.32	0.33	0.29	0.33	0.30	0.40	0.42	0.63	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A	+112	+109	(47)

Nomenclature: See separate page