

LOCKHART RIVER, Australia

WMO: 941860

Lat: 12.7850S

Lon: 143.3047E

Elev: 58

StdP: 14.66

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	59.7	62.0	57.7	71.1	64.6	59.5	76.0	67.1	21.7	78.5	20.7	78.5	0.2	280	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.4	91.6	78.9	89.9	78.4	88.6	78.0	80.7	86.9	80.0	86.0	79.5	85.3	9.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	151.6	82.9	78.5	148.4	82.4	78.0	145.9	82.1	44.4	87.2	43.7	86.4	43.2	85.6	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	18.5	17.0	DB	56.0	95.5	4.2	2.5	53.0	97.3	50.5	98.7	48.2	100.1	45.1	101.9
			WB	55.7	82.3	3.9	0.8	52.9	82.9	50.6	83.4	48.4	83.9	45.6	84.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.4	81.6	81.4	80.4	79.3	77.2	75.0	74.0	73.6	76.5	78.8	81.1	82.2	(6)
(7)		DBStd	3.83	2.24	2.00	1.85	1.89	2.51	2.92	2.80	2.83	2.91	2.59	2.12	2.00	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	10372	980	879	943	879	845	751	743	732	795	894	932	999	(10)
(11)		CDD65	4897	515	459	478	429	380	301	278	267	345	429	482	534	(11)
(12)		CDH74	41888	5046	4386	4305	3782	2819	1611	1226	1387	2525	3862	5030	5909	(12)
(13)		CDH80	10607	1696	1378	1174	771	326	104	31	76	359	901	1564	2227	(13)
(14)	Wind	WSAvg	8.3	5.7	5.1	5.2	8.4	9.5	8.7	9.8	9.4	10.9	10.1	9.2	6.9	(14)
(15)	Precipitation	PrecAvg	80.2	15.1	16.0	17.3	11.6	4.1	2.3	1.7	1.0	0.7	0.8	3.2	8.2	(15)
(16)		PrecMax	129.8	30.9	30.8	50.6	46.4	19.1	8.1	5.4	4.2	3.4	3.9	20.5	28.2	(16)
(17)		PrecMin	44.7	4.1	4.3	3.3	1.0	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.6	(17)
(18)		PrecStd	21.9	6.6	6.3	10.0	9.6	3.9	1.9	1.0	0.9	0.9	0.9	4.6	5.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.4	93.6	90.9	87.3	84.5	83.9	82.1	83.4	85.5	89.1	92.2	93.6	(19)
(20)			MCWB	78.7	79.2	79.6	77.8	75.5	75.6	73.2	73.8	75.1	76.3	78.8	78.4	(20)
(21)		2%	DB	90.8	90.8	88.5	85.9	83.6	82.4	80.9	81.8	84.2	86.7	88.7	90.8	(21)
(22)			MCWB	79.0	79.3	79.2	76.9	75.4	74.6	72.4	71.9	73.8	75.7	76.9	78.2	(22)
(23)		5%	DB	88.9	88.6	87.0	85.0	82.9	81.2	80.0	80.8	83.2	85.5	87.3	89.4	(23)
(24)			MCWB	78.5	78.9	78.6	76.6	75.0	73.8	72.0	71.2	72.9	75.0	76.1	77.8	(24)
(25)		10%	DB	87.3	86.9	85.7	84.0	82.0	80.0	79.1	79.8	82.2	84.4	86.3	88.2	(25)
(26)			MCWB	78.2	78.6	78.2	76.3	74.6	73.3	71.7	70.8	72.2	74.3	75.5	77.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	81.5	81.6	80.2	78.8	77.4	76.4	76.9	78.1	78.7	79.7	80.8	(27)
(28)			MCD B	87.6	88.7	87.0	84.1	82.0	81.2	79.3	80.8	82.7	85.9	88.0	88.1	(28)
(29)		2%	WB	80.3	80.4	80.5	79.2	77.4	76.3	75.4	75.2	76.8	77.4	78.5	79.9	(29)
(30)			MCD B	86.7	87.0	85.7	82.9	80.9	79.9	78.3	78.5	80.8	83.6	85.8	86.8	(30)
(31)		5%	WB	79.6	79.8	79.8	78.5	76.6	75.4	74.4	73.7	75.3	76.6	77.8	79.2	(31)
(32)			MCD B	85.9	85.9	84.7	82.1	80.4	79.0	77.7	77.8	80.5	82.5	84.6	85.9	(32)
(33)		10%	WB	79.0	79.1	79.1	77.9	76.0	74.6	73.4	72.4	73.9	75.9	77.0	78.6	(33)
(34)			MCD B	84.9	84.9	83.7	81.4	80.0	78.3	77.2	77.3	80.2	81.9	83.6	85.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.8	11.5	10.6	9.8	10.0	10.1	10.7	12.9	12.1	11.9	11.7	12.4	(35)
(36)			MCD BR	14.4	14.6	13.1	11.4	11.1	11.1	11.8	14.8	13.0	13.2	12.8	14.5	(36)
(37)			MCWBR	4.9	5.6	5.2	4.9	5.2	5.0	5.5	6.8	5.4	5.0	4.2	4.6	(37)
(38)		5% WB	MCD BR	12.6	12.3	11.5	9.1	8.2	8.3	7.2	9.3	9.8	11.3	12.2	12.8	(38)
(39)			MCWBR	5.2	5.4	5.1	4.5	4.3	4.2	3.7	4.5	4.6	4.5	4.5	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.405	0.399	0.397	0.400	0.399	0.393	0.382	0.389	0.400	0.412	0.414	0.412	(40)	
(41)		taud	2.534	2.555	2.559	2.528	2.496	2.508	2.524	2.488	2.450	2.417	2.439	2.480	(41)	
(42)		Ebn at Noon	298	297	292	281	271	267	273	280	287	290	293	295	(42)	
(43)		Edh at Noon	35	35	33	33	32	31	31	34	37	39	39	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1705	1716	1580	1560	1437	1285	1386	1640	1907	2066	2091	1943	(44)	
(45)		RadStd	177	199	111	155	104	101	95	137	106	126	126	193	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	+202	+196	(47)

Nomenclature: See separate page