

CAPE FLATTERY, Australia

WMO: 941880

Lat: 14.967S

Lon: 145.311E

Elev: 19

StdP: 101.09

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	20.4	12.5	9.0	22.2	13.5	9.7	22.7	12.8	23.3	12.2	23.3	3.1	100	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.1	32.5	25.7	31.9	25.5	31.4	25.3	27.1	30.6	26.7	30.2	26.3	29.8	5.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.1	25.7	21.0	28.9	25.3	20.6	28.6	85.9	30.8	84.0	30.4	82.4	29.9	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	11.0	10.3	DB	16.1	35.0	2.5	1.5	14.3	36.0	12.9	36.9	11.5	37.7	9.7	38.8	(4)
(5)			WB	13.7	28.0	1.8	0.6	12.4	28.5	11.4	28.8	10.3	29.2	9.0	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	28.0	28.0	27.6	27.0	25.7	24.1	23.6	23.9	25.2	26.2	27.5	28.3	(6)	
	DBStd	1.97	1.07	1.08	1.04	0.96	1.04	1.29	1.16	1.11	1.03	1.12	0.90	1.00	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	5930	557	504	544	509	486	424	421	432	455	504	525	568	(10)	
	CDD18.3	2888	299	271	286	259	227	174	163	174	205	246	275	310	(11)	
	CDH23.3	24483	3334	3063	2996	2419	1558	674	477	627	1180	1934	2712	3508	(12)	
(13)	CDH26.7	6372	1158	1074	845	465	152	28	9	24	148	417	785	1268	(13)	
(14)	Wind	WSAvg	6.4	4.7	4.6	5.5	7.4	7.8	7.7	7.6	7.2	7.0	6.7	5.9	5.2	(14)
(15) Precipitation	PrecAvg	1474	263	290	335	162	71	41	37	17	9	18	53	154	(15)	
	PrecMax	2636	661	564	650	550	225	145	97	66	29	74	410	642	(16)	
	PrecMin	863	84	23	15	6	1	5	3	0	0	1	0	0	(17)	
	PrecStd	450	160	128	172	153	66	37	24	16	7	18	97	140	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	34.1	32.5	30.6	29.4	28.4	27.6	28.1	29.4	30.8	32.2	33.4	(19)	
		MCWB	26.2	25.8	26.2	24.8	24.1	23.5	22.0	22.2	23.3	24.4	25.1	25.8	(20)	
	2%	DB	32.1	32.2	31.4	30.0	28.7	27.5	26.8	27.3	28.7	30.1	31.2	32.4	(21)	
		MCWB	25.9	26.1	26.0	24.6	23.4	22.8	21.6	21.5	22.5	23.6	24.6	25.3	(22)	
	5%	DB	31.5	31.6	30.7	29.5	28.1	26.8	26.2	26.7	28.2	29.5	30.7	31.8	(23)	
		MCWB	25.7	25.9	25.6	24.2	23.1	22.4	21.4	21.0	22.0	23.2	24.2	25.0	(24)	
	10%	DB	30.9	30.9	30.1	29.0	27.6	26.1	25.6	26.1	27.6	28.9	30.1	31.3	(25)	
		MCWB	25.4	25.7	25.4	23.9	22.9	22.1	21.2	20.7	21.6	22.7	23.8	24.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.7	27.6	26.5	25.7	24.7	24.1	24.1	24.7	25.2	26.5	27.3	(27)	
		MCDB	31.1	31.1	30.9	28.7	27.6	26.8	25.8	26.0	28.0	29.6	30.4	30.6	(28)	
	2%	WB	26.9	27.1	26.9	25.7	24.9	23.7	23.2	23.2	23.9	24.6	25.7	26.5	(29)	
		MCDB	30.6	30.6	30.3	28.4	27.0	26.0	25.1	25.5	27.2	28.6	29.5	30.5	(30)	
	5%	WB	26.5	26.6	26.4	25.3	24.3	23.2	22.7	22.5	23.2	24.1	25.1	26.0	(31)	
		MCDB	30.1	30.1	29.5	28.0	26.7	25.6	24.7	25.2	26.7	27.8	29.3	30.1	(32)	
	10%	WB	26.1	26.2	26.0	25.0	23.8	22.8	22.2	21.8	22.5	23.6	24.6	25.6	(33)	
		MCDB	29.6	29.7	29.0	27.6	26.4	25.3	24.5	24.9	26.4	27.4	28.8	29.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	5.7	4.9	4.1	3.9	3.8	4.0	4.7	5.3	5.6	5.8	6.1	(35)	
		MCDBR	6.5	6.9	5.8	4.5	4.4	4.4	4.5	5.1	5.6	6.0	6.2	6.8	(36)	
	5% WB	MCWBR	2.8	2.9	2.6	2.2	2.1	2.2	2.2	2.5	2.3	2.5	2.3	2.5	(37)	
		MCWBR	6.0	6.2	5.4	4.1	3.9	4.0	3.6	4.4	5.1	5.8	5.9	6.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.397	0.395	0.395	0.389	0.382	0.376	0.367	0.365	0.384	0.400	0.402	0.407	(40)	
		taud	2.568	2.582	2.574	2.569	2.553	2.564	2.570	2.562	2.490	2.457	2.483	2.506	(41)	
	Ebn at Noon		947	940	921	892	865	853	872	903	917	925	936	937	(42)	
		Edh at Noon	108	106	103	98	94	90	91	97	111	118	117	115	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.98	5.76	5.35	5.14	4.58	4.13	4.44	5.30	6.26	6.82	6.95	6.59	(44)	
	RadStd		0.52	0.66	0.37	0.47	0.35	0.28	0.29	0.32	0.23	0.34	0.43	0.67	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page