

CURTIN, Australia

WMO: 942040

Lat: 17.574S

Lon: 123.822E

Elev: 256

StdP: 14.56

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	54.5	57.1	15.5	12.2	76.2	19.8	15.0	74.9	16.7	75.0	16.0	74.7	5.1	120	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	26.3	106.0	71.3	104.0	72.0	102.2	72.7	82.0	89.7	81.2	89.5	80.5	89.2	8.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	160.7	84.3	79.2	153.2	83.7	78.8	150.7	83.4	46.2	90.7	45.3	89.9	44.5	88.9	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	14.4	13.1	DB	48.7	110.2	3.3	1.7	46.3	111.5	44.3	112.5	42.4	113.5	40.0	114.7	(4)
(5)			WB	40.2	83.7	2.4	1.9	38.5	85.1	37.2	86.2	35.8	87.2	34.1	88.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	86.3	85.8	86.1	84.4	78.6	74.2	73.7	75.5	81.1	86.5	89.3	88.6	(6)	
	DBStd	6.54	3.76	3.51	2.92	3.21	4.18	4.17	4.02	3.67	3.86	3.31	2.77	3.78	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	2	0	0	0	0	0	1	1	0	0	0	0	0	(9)	
	CDD50	11859	1125	1003	1119	1031	888	725	735	791	932	1133	1180	1197	(10)	
	CDD65	6386	660	583	654	581	423	276	271	326	482	668	730	732	(11)	
	CDH74	79333	8184	7117	8133	7116	4399	2537	2723	3814	6200	9002	10262	9846	(12)	
	CDH80	44119	4278	3657	4374	3964	2239	1062	1168	1942	3699	5570	6413	5753	(13)	
(14) Wind	WSAvg	6.7	6.5	6.1	5.6	5.8	6.9	7.5	7.3	7.2	6.9	6.7	6.8	6.8	(14)	
(15) Precipitation	PrecAvg	32.0	8.3	8.0	4.6	1.3	0.7	0.5	0.4	0.1	0.0	0.4	0.9	4.9	(15)	
	PrecMax	51.7	20.6	16.6	22.1	7.5	4.1	2.6	4.7	1.1	0.2	1.3	3.2	11.4	(16)	
	PrecMin	20.9	2.1	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)	
	PrecStd	7.5	4.3	4.3	5.1	1.8	1.2	0.7	1.1	0.3	0.0	0.4	0.7	2.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.2	104.4	103.2	102.4	98.7	93.4	93.4	97.2	103.7	107.4	109.3	108.0	(19)	
		MCWB	76.0	76.6	74.4	71.1	68.1	67.9	64.9	64.7	66.0	68.4	68.7	73.9	(20)	
	2%	DB	100.8	101.2	100.7	100.1	96.2	91.2	91.3	94.8	100.7	104.4	106.1	105.3	(21)	
		MCWB	77.6	77.6	74.0	72.0	67.6	66.9	64.0	63.9	65.9	68.9	70.5	74.9	(22)	
	5%	DB	98.7	98.4	98.8	98.3	93.5	89.1	89.4	92.4	98.7	102.4	104.0	102.1	(23)	
		MCWB	78.5	78.3	75.3	71.4	66.9	65.0	63.3	63.0	65.8	69.7	71.6	75.5	(24)	
	10%	DB	96.1	95.1	96.6	96.1	91.3	86.4	87.0	89.9	96.5	100.2	101.6	99.1	(25)	
		MCWB	78.6	78.8	76.2	71.3	66.3	63.5	62.3	61.7	65.5	70.2	72.6	76.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.8	83.5	82.8	80.7	77.4	73.8	72.5	72.0	74.5	78.9	79.7	81.9	(27)	
		MCDB	91.3	90.6	89.2	87.0	83.8	82.2	81.3	82.6	84.9	87.7	89.1	90.9	(28)	
	2%	WB	81.7	82.0	81.5	79.0	74.7	71.3	69.4	69.7	72.9	77.4	78.7	80.7	(29)	
		MCDB	90.4	89.5	88.7	86.9	83.1	83.6	82.9	83.3	84.7	87.4	88.4	89.8	(30)	
	5%	WB	80.8	81.1	80.6	78.0	72.8	69.4	67.1	67.8	71.5	76.4	77.9	79.8	(31)	
		MCDB	90.0	89.3	88.5	86.4	83.0	82.0	82.1	82.5	85.2	87.1	88.3	89.3	(32)	
	10%	WB	80.0	80.4	79.7	77.0	70.9	67.1	65.0	65.8	70.0	75.4	77.1	79.0	(33)	
		MCDB	89.0	88.8	87.8	85.8	83.1	80.7	81.2	82.6	85.4	86.7	88.3	88.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	18.4	18.3	20.3	24.0	24.5	24.4	26.7	29.9	31.5	29.0	26.3	21.5	(35)	
		MCDBR	22.9	23.5	24.5	26.7	27.7	26.3	28.9	32.6	33.2	31.7	29.5	25.9	(36)	
	5% WB	MCWBR	6.6	7.4	7.9	9.3	10.3	10.7	11.6	11.9	10.4	9.8	8.9	7.0	(37)	
		MCWBR	19.4	19.3	19.9	21.8	21.8	21.8	24.3	28.1	29.9	27.2	25.3	21.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.415	0.409	0.393	0.378	0.364	0.338	0.336	0.345	0.384	0.413	0.418	0.413	(40)	
		taud	2.456	2.478	2.520	2.493	2.463	2.509	2.488	2.425	2.363	2.329	2.364	2.437	(41)	
	Ebn at Noon		295	294	292	284	277	279	283	290	290	289	292	296	(42)	
		Edh at Noon	38	37	34	33	32	29	30	35	40	43	42	39	(43)	
(44) All-Sky Solar Radiation	RadAvg		2049	2057	1958	1894	1640	1550	1637	1920	2200	2350	2381	2218	(44)	
	RadStd		175	211	212	78	106	84	88	56	50	76	84	133	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.94	N/A	N/A	N/A	+0.67	+0.58	N/A	N/A	+414	+416

Nomenclature: See separate page