

CURTIN, Australia

WMO: 942040

Lat: 17.574S

Lon: 123.822E

Elev: 78

StdP: 100.39

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	13.9	-9.2	1.7	24.6	-6.8	2.1	23.8	7.5	23.9	7.2	23.7	2.3	120	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.6	41.1	21.8	40.0	22.2	39.0	22.6	27.8	32.1	27.3	31.9	26.9	31.8	3.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	23.0	29.0	26.2	21.9	28.7	26.0	21.5	28.6	89.5	32.6	87.5	32.1	85.7	31.6	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.4	5.9	9.3	43.5	1.9	1.0	7.9	44.2	6.8	44.7	5.8	45.3	4.4	46.0		
(5)			4.6	28.7	1.3	1.0	3.6	29.5	2.9	30.1	2.1	30.7	1.2	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	30.2	29.9	30.1	29.1	25.9	23.4	23.2	24.2	27.3	30.3	31.8	31.4		
	DBStd	3.63	2.09	1.95	1.62	1.78	2.32	2.32	2.23	2.04	2.15	1.84	1.54	2.10		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0		
	CDD10.0	6588	625	557	622	573	493	403	408	439	518	629	656	665		
	CDD18.3	3548	367	324	363	323	235	153	151	181	268	371	406	407		
	CDH23.3	44074	4547	3954	4518	3953	2444	1409	1513	2119	3444	5001	5701	5470		
(13)	CDH26.7	24511	2377	2032	2430	2202	1244	590	649	1079	2055	3094	3563	3196		
(14)	Wind	WSAvg	3.0	2.9	2.7	2.5	2.6	3.1	3.4	3.3	3.2	3.1	3.0	3.0		
(15) Precipitation	PrecAvg	814	211	203	118	32	18	13	9	2	1	9	22	124		
	PrecMax	1313	523	421	562	190	105	67	119	29	6	33	82	289		
	PrecMin	531	54	38	1	0	0	0	0	0	0	0	0	16		
	PrecStd	191	110	110	130	46	31	19	27	8	1	10	17	74		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.1	40.2	39.6	39.1	37.1	34.1	34.1	36.2	39.8	41.9	43.0	42.2		
		MCWB	24.5	24.8	23.5	21.7	20.0	19.9	18.3	18.2	18.9	20.2	20.4	23.3		
	2%	DB	38.2	38.4	38.2	37.9	35.7	32.9	33.0	34.9	38.1	40.2	41.2	40.7		
		MCWB	25.3	25.3	23.4	22.2	19.8	19.4	17.8	17.7	18.9	20.5	21.4	23.8		
	5%	DB	37.1	36.9	37.1	36.8	34.2	31.7	31.9	33.6	37.0	39.1	40.0	38.9		
		MCWB	25.8	25.7	24.0	21.9	19.4	18.3	17.4	17.2	18.8	21.0	22.0	24.2		
	10%	DB	35.6	35.0	35.9	35.6	32.9	30.2	30.5	32.2	35.8	37.9	38.6	37.3		
		MCWB	25.9	26.0	24.5	21.8	19.1	17.5	16.8	16.5	18.6	21.2	22.6	24.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.2	28.6	28.2	27.0	25.2	23.2	22.5	22.2	23.6	26.1	26.5	27.7		
		MCDB	33.0	32.6	31.8	30.6	28.8	27.9	27.4	28.1	29.4	31.0	31.7	32.7		
	2%	WB	27.6	27.8	27.5	26.1	23.7	21.8	20.8	21.0	22.7	25.2	26.0	27.1		
		MCDB	32.4	32.0	31.5	30.5	28.4	28.7	28.3	28.5	29.3	30.8	31.3	32.1		
	5%	WB	27.1	27.3	27.0	25.6	22.6	20.8	19.5	19.9	21.9	24.7	25.5	26.6		
		MCDB	32.2	31.8	31.4	30.2	28.3	27.8	27.9	28.1	29.6	30.6	31.3	31.8		
	10%	WB	26.7	26.9	26.5	25.0	21.6	19.5	18.3	18.8	21.1	24.1	25.0	26.1		
		MCDB	31.7	31.6	31.0	29.9	28.4	27.0	27.3	28.1	29.7	30.4	31.3	31.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	10.2	11.3	13.4	13.6	13.5	14.8	16.6	17.5	16.1	14.6	12.0		
		MCDBR	12.7	13.1	13.6	14.8	15.4	14.6	16.1	18.1	18.4	17.6	16.4	14.4		
		MCWBR	3.7	4.1	4.4	5.1	5.7	6.0	6.4	6.6	5.8	5.4	5.0	3.9		
	5% WB	MCDBR	10.8	10.7	11.1	12.1	12.1	12.1	13.5	15.6	16.6	15.1	14.1	12.2		
		MCWBR	3.7	3.9	4.0	4.2	4.9	5.4	5.9	6.3	5.7	4.8	4.4	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.415	0.409	0.393	0.378	0.364	0.338	0.336	0.345	0.384	0.413	0.418	0.413		
	taud		2.456	2.478	2.520	2.493	2.463	2.509	2.488	2.425	2.363	2.329	2.364	2.437		
	Ebn at Noon		931	927	920	896	872	881	892	915	913	912	922	932		
	Edh at Noon		121	117	108	104	100	92	96	110	125	134	132	123		
(44) All-Sky Solar Radiation	RadAvg		6.46	6.48	6.17	5.97	5.17	4.88	5.16	6.05	6.94	7.41	7.51	6.99		
	RadStd		0.55	0.67	0.67	0.24	0.33	0.27	0.28	0.18	0.16	0.24	0.27	0.42		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47)	Regional (4 neighbors)	+0.52	N/A	N/A	N/A	+0.37	+0.32	N/A	N/A	+230	+231	

Nomenclature: See separate page