

ROWLEY SHOALS, Australia

WMO: 942070

Lat: 17.520S

Lon: 118.945E

Elev: 25

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.4	72.6	N/A	N/A	N/A	N/A	N/A	N/A	31.8	73.1	29.9	74.5	19.8	110	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	2.9	87.9	N/A	87.2	N/A	86.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.9	170

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
30.0	26.9	24.3	DB	69.3	89.7	1.6	1.6	68.1	90.8	67.2	91.7	66.3	92.6	65.1	93.8	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	83.4	83.7	84.5	84.3	81.4	78.0	76.6	76.0	77.1	79.6	81.4	83.0
	DBStd	3.52	1.67	1.67	1.65	1.43	2.09	2.16	1.81	1.62	1.58	2.12	1.80	1.90
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11216	1036	943	1069	1028	973	841	826	806	812	918	941	1023
	CDD65	5741	571	523	604	578	508	391	361	341	362	453	491	558
	CDH74	59274	7093	6598	7809	7398	5538	2952	2023	1584	2181	4110	5260	6728
	CDH80	17182	2654	2585	3358	3087	1326	157	18	1	21	508	1150	2317
Wind	WSAvg	12.6	14.1	12.9	11.5	10.2	13.3	14.8	13.8	12.8	11.6	11.5	12.0	12.6
Precipitation	PrecAvg	18.0	3.4	4.6	3.1	1.4	1.5	1.0	0.5	0.2	0.1	0.1	0.1	1.9
	PrecMax	34.8	14.6	13.0	13.8	6.8	5.8	5.7	2.4	1.7	1.0	0.4	0.3	7.9
	PrecMin	6.1	0.0	0.1	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	7.1	3.5	3.6	3.5	1.7	1.7	1.3	0.6	0.4	0.2	0.1	0.1	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.9	88.1	88.8	88.5	86.9	83.3	81.7	80.1	81.6	84.9	86.9	88.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	86.9	87.1	87.8	87.6	85.7	82.2	80.5	79.4	80.7	83.8	85.6	87.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	86.2	86.4	87.2	86.9	84.9	81.6	79.8	78.9	80.0	83.1	84.6	86.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	85.6	85.9	86.6	86.3	84.2	80.9	79.1	78.3	79.4	82.4	83.9	85.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.7	2.9	2.9	2.9	2.8	2.7	2.8	2.9	2.8	2.9	2.6	2.6
		MCDBR	3.1	3.3	3.3	3.3	3.0	3.0	2.8	3.1	3.2	3.6	3.5	3.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.415	0.404	0.383	0.359	0.359	0.342	0.329	0.326	0.359	0.385	0.388	0.392	
	taud	2.513	2.556	2.614	2.646	2.598	2.642	2.652	2.609	2.525	2.473	2.505	2.562	
	Ebn at Noon	295	295	295	291	279	279	286	297	297	298	301	302	
	Edh at Noon	36	34	31	29	28	26	26	29	34	37	36	35	
All-Sky Solar Radiation	RadAvg	2174	2117	2018	1882	1599	1481	1602	1918	2175	2387	2486	2381	
	RadStd	216	238	202	110	116	123	92	39	54	38	51	115	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page