

ARGYLE, Australia

WMO: 942170

Lat: 16.6381S

Lon: 128.4517E

Elev: 165

StdP: 99.36

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.6	14.1	-10.4	1.6	26.4	-8.0	1.9	24.9	7.1	23.0	6.5	23.9	1.8	90	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	10.9	40.4	21.4	39.4	21.7	38.5	21.8	30.0	32.7	27.3	31.9	26.1	31.0	4.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
29.4	26.9	31.8	26.2	22.0	29.7	25.0	20.5	27.8	101.5	32.7	87.8	31.6	82.2	31.1	37.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.5	5.8	10.3	41.9	1.3	1.2	9.3	42.8	8.6	43.5	7.8	44.1	6.9	45.0		
(5)			4.6	34.1	0.9	2.8	4.0	36.1	3.4	37.8	2.9	39.4	2.3	41.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	30.7	30.2	30.1	28.9	25.5	22.8	22.8	24.7	29.4	31.9	32.3	31.4		
	DBStd	4.16	2.27	2.27	2.05	2.16	2.78	3.13	2.75	2.75	2.39	2.16	2.22	2.53		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	4	0	0	0	0	0	3	2	0	0	0	0	0		
	CDD10.0	6718	642	566	622	568	482	385	398	457	583	679	670	664		
	CDD18.3	3681	384	333	364	318	224	138	141	199	333	421	420	406		
	CDH23.3	47982	5158	4272	4754	3993	2326	1267	1327	2162	4481	6242	6276	5726		
	CDH26.7	26612	2868	2275	2554	2114	1028	451	472	965	2577	3928	3977	3403		
(14) Wind	WSAvg	2.8	3.1	2.8	2.6	2.6	2.7	2.7	2.6	2.8	2.9	3.1	3.2	3.2		
(15) Precipitation	PrecAvg	754	173	195	118	29	9	4	1	1	5	30	61	138		
	PrecMax	1475	308	399	476	130	101	67	8	6	35	159	134	272		
	PrecMin	329	28	22	0	0	0	0	0	0	1	0	10	9		
	PrecStd	234	66	115	134	37	20	13	2	1	8	41	36	76		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	39.8	39.1	37.9	35.5	33.9	33.6	35.7	38.9	40.9	41.5	41.9		
		MCWB	22.3	23.2	22.1	21.2	20.4	19.3	18.7	18.9	19.9	21.2	20.5	21.6		
	2%	DB	38.6	38.4	37.6	36.7	34.3	32.3	32.3	34.2	37.7	39.7	40.3	40.1		
		MCWB	23.6	23.1	22.7	21.5	19.8	18.7	17.6	18.3	19.5	20.5	21.0	22.7		
	5%	DB	37.3	37.0	36.5	35.7	33.1	30.9	30.9	32.9	36.8	38.7	39.3	38.4		
		MCWB	23.8	23.7	22.8	21.4	19.3	17.9	16.7	17.5	19.3	20.5	21.4	23.4		
	10%	DB	35.9	35.4	35.2	34.6	31.8	29.5	29.5	31.6	35.7	37.7	38.1	36.9		
		MCWB	24.3	24.0	22.9	21.3	18.6	16.9	16.1	16.7	19.1	20.4	21.7	23.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.3	29.2	31.2	32.5	29.2	22.5	21.2	21.7	27.2	30.7	30.1	30.9		
		MCDB	34.5	35.3	33.6	33.6	30.5	27.4	29.5	31.3	32.5	34.2	30.4	34.8		
	2%	WB	27.6	26.5	26.6	27.8	24.1	20.7	19.9	20.6	23.4	25.1	25.6	27.4		
		MCDB	31.2	31.3	31.1	31.6	27.8	29.0	29.4	30.8	30.7	32.1	31.7	33.3		
	5%	WB	26.2	26.0	25.7	25.0	22.5	19.5	18.7	19.5	22.1	23.9	24.8	25.9		
		MCDB	31.2	30.6	30.1	29.4	28.9	29.0	28.0	30.0	31.2	31.2	31.6	31.3		
	10%	WB	25.7	25.6	25.3	24.1	21.1	18.4	17.4	18.5	21.2	23.2	24.3	25.4		
		MCDB	30.8	30.3	29.7	29.5	28.9	27.6	27.0	29.1	31.9	31.3	31.5	30.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	9.3	9.5	10.9	11.7	12.2	13.0	13.3	12.4	11.4	10.9	9.8		
		MCDBR	11.1	11.6	11.2	11.7	12.2	12.2	13.3	13.3	12.5	12.2	12.0	11.7		
	5% WB	MCWBR	3.4	3.2	3.2	3.9	4.3	4.2	4.9	4.5	4.0	4.0	3.4	3.5		
		MCWBR	9.3	9.1	8.9	9.5	9.8	10.8	11.5	11.6	11.0	10.7	10.5	9.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.407	0.402	0.390	0.368	0.360	0.339	0.343	0.358	0.424	0.435	0.443	0.416		
		taud	2.484	2.500	2.529	2.522	2.482	2.503	2.467	2.399	2.260	2.269	2.311	2.439		
	Ebn at Noon	Ebn at Noon	939	934	924	908	880	882	889	904	877	893	899	929		
		Edh at Noon	118	114	108	102	99	93	99	113	139	142	139	123		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.42	6.38	6.10	6.00	5.32	5.00	5.30	6.12	6.78	7.11	7.03	6.57		
	RadStd	RadStd	0.46	0.69	0.69	0.35	0.39	0.22	0.22	0.18	0.31	0.39	0.33	0.37		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page