

DELAMERE WEAPONS RANGE, Australia

WMO: 942250

Lat: 15.7442S

Lon: 131.9183E

Elev: 222

StdP: 98.69

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.7	14.1	-9.7	1.7	24.4	-7.5	2.1	23.4	7.6	21.9	7.3	22.1	2.8	120	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.6	39.2	20.7	38.3	21.1	37.4	21.3	26.7	32.3	26.0	31.7	25.6	31.1	4.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.4	21.1	29.0	24.6	20.2	28.0	24.2	19.6	27.5	85.2	32.5	82.2	31.7	80.2	31.3	35.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.6	6.1	DB	9.9	41.0	1.3	1.3	8.9	41.9	8.2	42.7	7.5	43.4	6.5	44.4	(4)
(5)			WB	4.3	27.0	0.9	0.4	3.6	27.3	3.1	27.6	2.6	27.8	1.9	28.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	29.1	29.0	28.8	27.7	25.0	22.3	22.4	23.6	27.9	30.4	30.8	30.2	(6)	
	DBStd	3.68	1.84	1.87	1.56	1.87	2.35	2.64	2.49	2.43	2.33	1.85	1.88	2.18	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	4	0	0	0	0	0	3	1	0	0	0	0	0	(9)	
	CDD10.0	6302	593	531	582	531	464	370	385	423	537	633	625	628	(10)	
	CDD18.3	3264	335	298	324	281	206	123	128	164	287	374	375	369	(11)	
	CDH23.3	40173	3942	3491	3757	3334	2061	1097	1270	1839	3783	5447	5329	4824	(12)	
	CDH26.7	20810	1914	1718	1826	1695	876	357	445	797	2082	3263	3168	2669	(13)	
(14) Wind	WSAvg	3.2	3.0	2.9	2.8	3.0	3.4	3.6	3.5	3.5	3.4	3.4	3.1	2.9	(14)	
(15) Precipitation	PrecAvg	949	205	234	155	21	5	3	1	0	5	34	75	207	(15)	
	PrecMax	1372	363	553	352	179	51	53	4	0	27	138	146	406	(16)	
	PrecMin	581	104	40	7	0	0	0	0	0	0	0	18	48	(17)	
	PrecStd	222	63	151	104	42	12	12	1	0	8	38	34	97	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.8	38.2	37.9	36.1	34.4	32.7	32.8	34.7	37.5	39.7	40.1	40.8	(19)	
		MCWB	22.9	22.0	22.9	21.5	20.0	19.2	19.4	19.2	19.6	19.5	20.3	20.8	(20)	
	2%	DB	36.9	37.0	36.1	35.3	33.2	31.4	31.5	33.4	36.5	38.6	39.0	39.2	(21)	
		MCWB	23.9	23.0	22.8	21.2	19.7	18.9	18.0	18.3	19.4	19.7	20.8	21.2	(22)	
	5%	DB	35.6	35.7	35.1	34.6	32.3	30.2	30.5	32.1	35.7	37.7	38.1	37.6	(23)	
		MCWB	24.2	23.6	23.1	21.1	19.4	18.3	17.3	17.2	19.1	19.8	21.1	22.4	(24)	
	10%	DB	34.2	34.3	33.9	33.7	31.2	28.9	29.3	30.9	34.8	36.7	37.0	36.0	(25)	
		MCWB	24.6	23.9	23.2	20.8	18.8	17.3	16.6	16.6	18.7	19.8	21.6	23.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.0	26.4	24.9	23.6	21.5	21.4	21.6	23.0	24.1	31.8	28.0	(27)	
		MCDB	32.5	32.7	32.2	32.4	29.0	29.2	30.3	30.7	32.1	32.1	36.3	33.2	(28)	
	2%	WB	26.5	26.1	25.7	24.1	22.7	20.3	20.2	20.5	22.3	23.4	25.5	26.1	(29)	
		MCDB	32.1	31.9	31.2	29.9	28.6	28.8	29.2	30.1	31.5	31.6	32.2	31.9	(30)	
	5%	WB	25.9	25.6	25.2	23.6	21.7	19.5	19.1	19.3	21.6	22.9	24.5	25.5	(31)	
		MCDB	31.4	31.1	30.3	29.5	28.7	28.4	27.9	29.7	31.3	31.2	31.7	31.3	(32)	
	10%	WB	25.5	25.2	24.8	23.1	20.7	18.5	17.9	18.0	20.9	22.4	24.0	25.0	(33)	
		MCDB	30.8	30.3	29.7	29.2	28.5	27.2	27.3	28.6	31.3	31.1	31.1	30.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.1	9.4	9.8	11.8	12.0	12.4	13.1	14.1	13.4	12.5	11.6	10.3	(35)	
		MCDBR	11.5	12.0	11.8	12.8	12.8	13.1	13.7	14.7	13.6	13.4	13.1	12.8	(36)	
	5% WB	MCWBR	2.9	3.0	3.0	3.4	4.6	5.2	5.7	5.8	5.2	5.1	4.6	3.6	(37)	
		MCWBR	9.4	9.1	9.2	9.9	10.2	11.8	12.7	12.7	11.4	11.1	10.9	9.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.402	0.401	0.388	0.365	0.347	0.326	0.325	0.339	0.410	0.432	0.451	0.424	(40)	
		taud	2.501	2.501	2.531	2.546	2.531	2.546	2.531	2.466	2.292	2.268	2.279	2.414	(41)	
	Ebn at Noon	Ebn at Noon	942	935	927	913	896	900	910	926	891	895	891	921	(42)	
		Edh at Noon	115	114	108	100	95	90	94	106	135	143	143	126	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.27	6.22	6.14	5.95	5.33	5.04	5.34	6.11	6.73	7.00	6.82	6.43	(44)	
	RadStd	RadStd	0.50	0.74	0.60	0.40	0.31	0.26	0.19	0.20	0.34	0.41	0.25	0.43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page