

VICTORIA RIVER DOWNS, Australia

WMO: 942320

Lat: 16.403S

Lon: 131.014E

Elev: 90

StdP: 100.25

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	9.1	-7.7	2.0	23.7	-5.7	2.4	22.6	6.3	26.4	5.5	25.6	1.2	270	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	12.4	40.0	21.3	39.1	21.5	38.1	21.8	27.7	31.3	26.5	31.3	26.0	31.0	3.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.0	29.0	25.4	20.9	28.1	24.9	20.1	27.8	89.6	31.2	83.6	31.5	81.3	31.1	36.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.5	5.0	DB	4.6	41.3	1.2	1.0	3.7	42.0	3.0	42.6	2.4	43.1	1.5	43.8	(4)
(5)			WB	1.8	31.5	1.1	4.3	1.0	34.6	0.4	37.1	-0.2	39.6	-1.0	42.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	30.0	29.5	29.0	27.3	23.6	20.5	20.4	22.0	27.0	30.0	31.2	30.9	(6)	
	DBStd	4.69	1.81	1.89	1.59	2.31	3.10	3.36	3.18	3.11	3.10	2.55	1.99	2.07	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	38	0	0	0	0	2	16	15	4	0	0	0	0	(9)	
	CDD10.0	6117	621	547	588	518	422	315	323	371	509	620	636	647	(10)	
	CDD18.3	3113	362	314	330	268	166	81	80	117	259	362	386	388	(11)	
	CDH23.3	41437	4656	3873	3979	3247	1956	1026	1127	1789	3604	5255	5609	5317	(12)	
	CDH26.7	22479	2437	1951	1993	1741	903	369	416	837	2098	3236	3443	3056	(13)	
	WSAvg	2.0	2.0	1.9	1.7	1.8	1.9	2.0	1.8	2.0	2.2	2.3	2.2	2.2	(14)	
(15) Precipitation	PrecAvg	743	161	206	132	23	9	1	4	1	5	21	63	116	(15)	
	PrecMax	1126	368	580	398	254	54	18	76	28	28	98	220	295	(16)	
	PrecMin	313	13	6	4	0	0	0	0	0	0	0	7	13	(17)	
	PrecStd	213	91	134	104	51	14	3	15	4	8	22	46	74	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.6	39.4	38.0	37.5	35.3	33.6	33.3	35.8	38.1	40.5	41.0	41.2	(19)	
		MCWB	23.0	22.4	22.3	20.9	20.4	19.3	18.9	19.5	19.9	20.5	21.0	21.5	(20)	
	2%	DB	37.7	37.9	36.8	36.2	33.8	31.8	31.9	34.2	37.1	39.3	39.9	39.7	(21)	
		MCWB	23.7	22.8	22.7	20.9	19.6	18.9	17.9	18.4	19.7	20.3	21.1	22.1	(22)	
	5%	DB	36.5	36.6	35.6	35.2	32.8	30.5	30.6	32.7	36.2	38.4	39.0	38.2	(23)	
		MCWB	24.1	23.6	23.1	21.0	19.5	18.1	17.1	17.3	19.4	20.4	21.5	23.0	(24)	
	10%	DB	35.3	34.9	34.4	34.2	31.6	28.9	29.2	31.3	35.2	37.4	37.8	36.6	(25)	
		MCWB	24.5	24.2	23.2	21.3	19.0	16.8	16.6	16.7	19.0	20.7	22.0	23.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.5	27.7	26.7	29.4	25.6	22.6	21.6	21.2	23.6	32.8	29.6	30.4	(27)	
		MCDB	31.5	31.7	31.0	30.8	29.3	27.9	29.8	32.5	31.9	33.7	32.1	31.7	(28)	
	2%	WB	26.7	26.7	26.1	25.1	23.4	20.6	19.9	20.0	22.5	25.7	25.5	26.3	(29)	
		MCDB	32.0	31.4	30.7	30.0	29.2	29.2	29.3	31.0	31.8	31.7	32.2	31.2	(30)	
	5%	WB	26.2	26.2	25.7	24.3	22.1	19.4	18.7	19.0	21.7	23.8	24.8	25.7	(31)	
		MCDB	31.6	30.9	30.2	29.7	28.9	28.6	27.7	30.3	32.2	31.1	32.0	31.1	(32)	
	10%	WB	25.8	25.7	25.3	23.5	20.7	18.1	17.5	17.8	20.9	23.1	24.3	25.2	(33)	
		MCDB	31.1	30.3	29.8	29.4	28.6	27.3	27.3	29.1	32.2	31.2	31.6	30.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.4	10.3	13.5	15.4	16.0	17.1	18.1	16.2	14.1	12.4	10.7	(35)	
		MCDBR	11.9	12.6	12.8	14.7	16.0	16.4	17.4	18.2	16.0	15.5	14.5	13.1	(36)	
		MCWBR	3.1	3.2	3.0	3.9	5.6	6.3	7.1	7.2	5.7	5.7	4.4	3.4	(37)	
	5% WB	MCDBR	9.5	8.8	8.8	10.7	11.6	14.4	15.2	15.6	12.6	11.5	11.5	9.9	(38)	
		MCWBR	3.3	2.9	2.6	4.0	5.1	6.0	6.9	6.4	5.1	4.8	3.9	3.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.412	0.410	0.395	0.374	0.360	0.341	0.344	0.357	0.428	0.443	0.458	0.431	(40)	
	taud		2.469	2.473	2.508	2.507	2.482	2.492	2.460	2.400	2.235	2.237	2.259	2.390	(41)	
	Ebn at Noon		934	926	919	903	881	881	888	905	874	886	885	915	(42)	
	Edh at Noon		119	118	110	104	99	95	100	113	142	147	146	129	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.42	6.28	6.15	5.95	5.30	4.99	5.30	6.08	6.74	7.03	6.92	6.49	(44)	
	RadStd		0.47	0.73	0.64	0.36	0.33	0.24	0.21	0.20	0.33	0.40	0.28	0.41	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page