

DALY WATERS, Australia

WMO: 942340

Lat: 16.2636S

Lon: 133.3783E

Elev: 694

StdP: 14.33

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	45.4	48.4	17.1	13.3	73.2	20.0	15.4	71.3	15.9	68.0	14.4	71.4	2.8	170	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	25.5	104.0	68.8	102.3	69.0	100.7	69.4	78.7	88.5	77.9	87.7	77.2	87.0	8.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	141.8	81.4	75.6	137.5	81.1	74.9	134.2	80.9	42.8	88.5	42.0	87.8	41.3	87.1	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	14.5	13.0	40.2	106.9	2.2	2.3	38.6	108.5	37.3	109.9	36.1	111.2	34.5	112.9
			35.3	80.0	2.2	1.3	33.7	80.9	32.5	81.7	31.3	82.5	29.7	83.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.3	84.7	84.0	83.0	79.9	74.5	69.7	68.9	70.7	78.4	84.0	86.7	86.8	(6)
	DBStd	7.66	3.65	3.13	3.11	3.57	4.89	5.11	4.52	4.67	4.96	3.95	3.53	3.91	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	39	0	0	0	0	2	17	15	5	0	0	0	0	(9)
	CDD50	10677	1075	951	1024	898	760	590	587	643	852	1055	1102	1140	(10)
	CDD65	5243	610	531	559	448	297	157	138	184	402	590	652	675	(11)
	CDH74	68432	7288	6166	6409	5219	3454	1833	2081	3034	5811	8626	9350	9161	(12)
	CDH80	37320	3745	3122	3305	2778	1613	669	784	1416	3393	5352	5775	5368	(13)
(14) Wind	WSAvg	5.7	5.8	5.4	5.0	5.2	5.8	6.1	5.7	5.6	5.6	6.2	5.9	5.8	(14)
(15) Precipitation	PrecAvg	31.2	7.0	8.0	4.5	0.9	0.1	0.2	0.1	0.0	0.3	0.9	2.5	5.1	(15)
	PrecMax	49.8	12.8	20.7	14.5	5.9	0.7	5.0	1.7	0.5	2.6	5.1	6.1	10.5	(16)
	PrecMin	19.8	0.5	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	(17)
	PrecStd	7.8	3.7	4.8	4.4	1.3	0.2	0.9	0.4	0.1	0.6	1.2	1.5	2.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.7	102.0	101.4	97.6	95.3	91.5	91.5	95.3	100.6	104.4	105.6	106.8	(19)
		MCWB	71.8	69.5	71.8	69.7	67.6	66.6	66.1	65.7	66.8	67.3	68.5	68.7	(20)
	2%	DB	100.6	99.4	98.5	95.8	92.8	89.0	89.1	92.6	98.5	102.4	103.5	104.2	(21)
		MCWB	72.6	72.7	72.7	69.6	67.3	65.7	63.7	64.2	66.1	67.3	68.2	69.3	(22)
	5%	DB	97.7	97.0	96.0	94.3	91.0	86.9	87.1	90.4	96.8	100.6	102.0	101.5	(23)
		MCWB	73.6	73.7	72.9	69.4	66.6	64.2	62.3	62.6	65.6	67.1	68.4	70.7	(24)
	10%	DB	94.9	94.3	93.7	92.6	88.9	84.4	84.9	88.0	94.9	98.9	100.2	99.0	(25)
		MCWB	74.6	74.2	72.9	69.1	65.6	62.4	61.0	61.2	64.7	66.8	68.9	71.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.5	80.0	79.6	76.2	74.1	70.1	69.7	69.7	72.3	75.4	76.7	78.3	(27)
		MCDB	89.8	89.8	87.6	86.5	85.8	85.2	85.0	86.4	89.9	88.2	87.2	87.8	(28)
	2%	WB	78.4	78.7	78.2	75.0	72.3	68.2	67.1	67.4	71.0	73.6	75.4	77.2	(29)
		MCDB	88.2	88.6	87.9	85.7	84.3	84.4	84.1	86.8	88.7	88.8	88.1	87.2	(30)
	5%	WB	77.7	77.8	77.3	74.0	70.3	66.5	64.8	65.4	69.7	72.5	74.6	76.4	(31)
		MCDB	87.4	87.6	87.1	84.9	84.1	83.0	82.2	85.3	88.7	88.6	87.9	86.7	(32)
	10%	WB	77.0	77.1	76.5	73.0	68.4	64.4	62.8	63.2	68.2	71.4	73.8	75.7	(33)
		MCDB	86.5	86.8	85.9	84.1	84.1	79.9	81.3	84.1	86.9	88.4	87.5	86.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	19.2	20.8	25.3	28.3	28.4	31.7	34.2	33.1	30.0	25.5	21.5	(35)
		MCDBR	23.8	25.0	25.5	28.0	30.8	31.3	34.6	37.1	34.4	32.7	30.2	27.2	(36)
	5% WB	MCWBR	5.4	5.8	6.2	8.2	10.5	12.3	14.0	14.2	11.9	10.7	8.9	7.3	(37)
		MCWBR	17.2	17.4	18.2	22.2	25.3	28.6	31.8	32.7	27.1	25.2	21.9	18.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.405	0.395	0.382	0.365	0.344	0.324	0.325	0.333	0.396	0.429	0.443	0.426	(40)
		taud	2.492	2.522	2.553	2.550	2.542	2.555	2.533	2.487	2.336	2.277	2.301	2.405	(41)
	Ebn at Noon		298	298	295	289	285	286	288	295	286	285	285	292	(42)
		Edh at Noon	37	36	33	31	30	28	30	33	41	45	44	40	(43)
(44) All-Sky Solar Radiation	RadAvg		2006	2004	1943	1868	1680	1576	1675	1926	2136	2239	2175	2064	(44)
	RadStd		170	213	190	130	95	84	63	64	111	130	89	150	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page