

TENNANT CREEK, Australia

WMO: 942380

Lat: 19.6422S

Lon: 134.1833E

Elev: 1237

StdP: 14.05

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	49.5	51.5	4.3	7.2	76.2	8.9	9.1	75.0	23.4	60.7	22.3	61.4	12.0	110	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.9	104.0	67.4	102.2	67.1	100.5	67.1	77.2	85.0	76.2	84.6	75.4	84.3	10.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	139.5	79.3	74.3	134.4	78.9	73.4	130.3	78.6	41.6	84.7	40.7	84.0	40.0	84.0	97.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.3	20.5	18.8	DB	45.5	107.4	1.9	2.5	44.1	109.2	43.0	110.6	41.9	112.0	40.6	113.8	(4)
(5)			WB	36.2	82.5	1.7	6.9	35.0	87.5	34.0	91.5	33.0	95.4	31.8	100.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.6	86.8	85.9	84.0	79.6	71.5	65.9	65.8	69.5	78.0	83.1	86.1	87.2	(6)
(7)		DBStd	9.57	4.84	4.37	4.36	4.86	5.60	6.11	5.34	5.92	5.89	5.69	4.87	5.08	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	156	0	0	0	1	12	61	56	23	2	1	0	0	(9)
(10)		CDD50	10431	1142	1006	1054	887	667	479	489	603	840	1026	1083	1155	(10)
(11)		CDD65	5113	677	586	589	438	214	90	80	162	392	562	633	690	(11)
(12)		CDH74	64761	9386	7908	7532	4735	1675	641	636	1488	4507	7457	8959	9837	(12)
(13)		CDH80	35312	5569	4498	4004	2190	525	149	132	485	2220	4216	5359	5965	(13)
(14)	Wind	WSAvg	10.3	9.5	9.2	9.7	10.5	10.8	11.1	10.7	10.7	10.8	10.6	10.0	9.7	(14)
(15)	Precipitation	PrecAvg	13.5	3.3	3.9	2.2	0.6	0.5	0.2	0.1	0.1	0.3	0.7	1.3	2.0	(15)
(16)		PrecMax	30.3	11.1	13.6	11.4	5.4	6.8	3.3	1.6	0.8	2.2	3.0	6.7	5.8	(16)
(17)		PrecMin	5.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.0	3.0	4.0	2.8	1.0	1.2	0.6	0.4	0.2	0.6	0.7	1.3	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.6	104.3	102.1	97.0	91.2	87.8	87.7	91.8	98.5	102.9	104.3	107.5	(19)
MCWB			67.4	67.9	68.0	66.1	65.1	63.8	62.3	62.5	64.0	65.2	66.4	67.8	(20)	
2%		DB	103.7	101.9	99.1	94.8	87.9	84.1	83.5	88.4	95.8	100.5	102.3	103.8	(21)	
		MCWB	68.1	67.8	67.8	65.1	63.1	61.8	59.3	60.7	62.9	64.6	66.0	67.6	(22)	
5%		DB	100.7	99.6	96.9	92.7	85.7	80.9	80.6	85.6	93.6	98.3	100.4	101.5	(23)	
		MCWB	68.6	68.1	67.7	64.8	61.8	59.7	57.3	59.0	61.9	64.3	65.9	67.5	(24)	
10%		DB	98.5	97.1	94.7	90.2	82.8	77.4	77.4	82.2	91.3	95.9	98.4	98.9	(25)	
		MCWB	69.1	68.1	67.1	64.1	60.3	57.6	55.7	56.9	60.8	63.5	65.8	68.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.1	77.9	77.1	74.1	75.1	66.6	67.2	66.4	69.6	77.4	80.8	77.2	(27)
MCDWB			86.1	84.6	84.2	85.8	77.2	81.9	78.3	84.7	82.9	82.5	83.1	85.3	(28)	
2%		WB	76.9	76.7	75.8	72.3	69.1	64.4	63.1	63.4	67.3	71.3	73.7	75.8	(29)	
		MCDWB	85.2	84.6	83.7	84.2	79.9	79.7	78.2	83.7	85.3	85.5	87.6	85.0	(30)	
5%		WB	76.0	76.0	74.7	70.4	65.6	62.3	60.1	61.1	65.2	69.7	72.4	75.0	(31)	
		MCDWB	84.7	84.2	83.4	83.5	79.6	77.6	76.4	82.6	87.9	85.5	86.2	84.9	(32)	
10%		WB	75.2	75.3	73.7	67.9	62.7	59.7	57.5	58.8	63.3	68.0	71.2	74.2	(33)	
		MCDWB	84.2	83.8	83.4	84.1	79.4	75.3	75.0	79.4	87.6	86.2	85.5	85.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.1	18.9	18.4	19.1	19.1	19.5	20.8	21.8	22.5	22.0	21.1	19.9	(35)
MCDBR			22.5	22.5	21.5	20.7	20.8	21.1	23.1	23.6	23.7	24.1	23.1	22.7	(36)	
MCWBR			7.6	8.0	7.7	8.4	9.4	9.6	10.8	10.5	9.9	10.2	9.1	8.2	(37)	
5% WB		MCDWR	17.2	16.2	16.9	18.0	18.0	18.8	20.9	21.6	20.6	20.3	20.3	18.2	(38)	
		MCWBR	5.7	5.3	6.2	8.0	10.1	8.9	11.2	10.5	9.7	9.6	7.3	5.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.379	0.379	0.366	0.347	0.337	0.312	0.316	0.325	0.375	0.387	0.403	0.395	(40)	
taud		2.506	2.507	2.526	2.504	2.481	2.529	2.493	2.439	2.343	2.334	2.357	2.432	(41)		
Ebn at Noon		306	303	299	292	283	286	288	295	292	297	297	301	(42)		
Edh at Noon		36	36	34	32	30	28	30	34	40	42	42	39	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2214	2214	2053	1886	1600	1483	1572	1853	2116	2292	2299	2228	(44)	
(45)		RadStd	160	170	166	119	114	74	80	71	108	143	121	162	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page