

TENNANT CREEK, Australia

WMO: 942380

Lat: 19.6422S

Lon: 134.1833E

Elev: 377

StdP: 96.88

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	10.8	-15.4	1.0	24.6	-12.9	1.3	23.9	10.5	16.0	10.0	16.3	5.4	110	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.1	40.0	19.6	39.0	19.5	38.0	19.5	25.1	29.4	24.6	29.2	24.1	29.0	4.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.9	26.3	23.5	19.2	26.0	23.0	18.6	25.9	79.0	29.3	76.7	28.9	75.1	28.9	36.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.0	9.1	8.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			7.5	41.9	1.0	1.4	6.7	42.9	6.1	43.7	5.5	44.5	4.8	45.4
			2.4	28.0	1.0	3.9	1.7	30.8	1.1	33.1	0.6	35.2	-0.1	38.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	30.5	30.0	28.9	26.4	22.0	18.9	18.8	20.8	25.6	28.4	30.1	30.7		
	DBStd	5.32	2.69	2.43	2.42	2.70	3.11	3.40	2.96	3.29	3.27	3.16	2.71	2.82		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	87	0	0	0	1	7	34	31	13	1	1	0	0		
	CDD10.0	5795	634	559	586	493	371	266	272	335	467	570	602	642		
	CDD18.3	2841	376	326	327	243	119	50	44	90	218	312	352	383		
	CDH23.3	35978	5214	4393	4184	2631	931	356	353	827	2504	4143	4977	5465		
	CDH26.7	19618	3094	2499	2224	1217	292	83	73	269	1233	2342	2977	3314		
(14) Wind	WSAvg	4.6	4.3	4.1	4.3	4.7	4.8	5.0	4.8	4.8	4.8	4.7	4.5	4.3		
(15) Precipitation	PrecAvg	343	84	99	56	14	12	4	3	2	8	17	32	51		
	PrecMax	769	282	345	289	136	172	83	41	20	56	77	171	147		
	PrecMin	131	0	1	0	0	0	0	0	0	0	0	0	0		
	PrecStd	152	77	102	70	25	30	14	9	4	14	19	34	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	40.2	39.0	36.1	32.9	31.0	30.9	33.2	36.9	39.4	40.2	42.0		
		MCWB	19.7	19.9	20.0	19.0	18.4	17.7	16.8	16.9	17.8	18.5	19.1	19.9		
	2%	DB	39.8	38.8	37.3	34.9	31.1	28.9	28.6	31.3	35.5	38.0	39.0	39.9		
		MCWB	20.0	19.9	19.9	18.4	17.3	16.6	15.1	15.9	17.1	18.1	18.9	19.8		
	5%	DB	38.2	37.5	36.1	33.7	29.8	27.2	27.0	29.8	34.2	36.8	38.0	38.6		
		MCWB	20.3	20.0	19.8	18.2	16.5	15.4	14.1	15.0	16.6	18.0	18.8	19.7		
	10%	DB	36.9	36.2	34.8	32.4	28.2	25.2	25.2	27.9	32.9	35.5	36.9	37.2		
		MCWB	20.6	20.0	19.5	17.8	15.7	14.2	13.2	13.8	16.0	17.5	18.8	20.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	25.5	25.0	23.4	23.9	19.2	19.5	19.1	20.9	25.2	27.1	25.1		
		MCDB	30.0	29.2	29.0	29.9	25.1	27.7	25.7	29.3	28.3	28.1	28.4	29.6		
	2%	WB	24.9	24.9	24.3	22.4	20.6	18.0	17.3	17.5	19.6	21.9	23.2	24.3		
		MCDB	29.5	29.2	28.7	29.0	26.6	26.5	25.7	28.7	29.6	29.7	30.9	29.4		
	5%	WB	24.5	24.5	23.7	21.3	18.6	16.8	15.6	16.2	18.4	21.0	22.5	23.9		
		MCDB	29.3	29.0	28.6	28.6	26.5	25.3	24.7	28.1	31.1	29.7	30.1	29.4		
	10%	WB	24.0	24.0	23.2	20.0	17.0	15.4	14.2	14.9	17.4	20.0	21.8	23.4		
		MCDB	29.0	28.8	28.6	28.9	26.3	24.0	23.9	26.4	30.9	30.1	29.7	29.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	10.5	10.2	10.6	10.6	10.8	11.5	12.1	12.5	12.2	11.7	11.1		
		MCDBR	12.5	12.5	11.9	11.5	11.6	11.7	12.8	13.1	13.1	13.4	12.9	12.6		
	5% WB	MCWBR	4.2	4.4	4.3	4.7	5.2	5.3	6.0	5.8	5.5	5.6	5.0	4.6		
		MCWBR	9.5	9.0	9.4	10.0	10.0	10.4	11.6	12.0	11.5	11.3	11.3	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.379	0.379	0.366	0.347	0.337	0.312	0.316	0.325	0.375	0.387	0.403	0.395		
	taud		2.506	2.507	2.526	2.504	2.481	2.529	2.493	2.439	2.343	2.334	2.357	2.432		
	Ebn at Noon		965	954	943	922	893	901	907	930	919	935	936	950		
	Edh at Noon		115	113	107	102	96	88	94	107	126	133	133	124		
(44) All-Sky Solar Radiation	RadAvg		6.98	6.98	6.47	5.95	5.04	4.68	4.96	5.84	6.67	7.23	7.25	7.02		
	RadStd		0.50	0.54	0.52	0.37	0.36	0.23	0.25	0.22	0.34	0.45	0.38	0.51		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page