

CENTRE ISLAND, Australia

WMO: 942480

Lat: 15.742S

Lon: 136.819E

Elev: 13

StdP: 101.17

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	17.9	4.3	5.2	20.3	5.8	5.7	20.7	12.8	21.5	11.5	21.0	6.8	140	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.1	35.7	25.9	34.9	26.0	34.2	25.9	28.6	32.4	28.0	32.4	27.5	31.9	4.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.7	30.8	26.9	22.5	30.5	26.4	21.9	30.2	93.0	32.5	89.8	32.4	87.7	32.2	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.6	9.5	DB	15.4	37.8	1.6	0.8	14.2	38.4	13.3	38.9	12.4	39.4	11.2	40.0	(4)
(5)			WB	9.6	29.2	1.0	1.3	8.9	30.1	8.3	30.8	7.8	31.5	7.1	32.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	30.1	29.9	29.6	28.7	25.9	23.1	22.6	23.5	26.2	28.8	30.4	30.8	(6)	
	DBStd	3.35	1.77	1.78	1.59	1.49	1.94	2.11	1.56	1.49	1.45	1.33	1.11	1.51	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6367	623	557	607	559	492	393	390	418	487	583	613	645	(10)	
	CDD18.3	3326	365	323	348	309	233	143	132	160	237	324	363	387	(11)	
	CDH23.3	35972	4829	4207	4380	3571	1837	581	395	658	1829	3677	4745	5263	(12)	
	CDH26.7	15541	2413	2034	1977	1356	403	66	29	89	517	1474	2374	2809	(13)	
(14) Wind	WSAvg	5.0	4.7	4.8	4.7	5.4	5.7	5.6	5.4	5.2	4.8	4.8	4.7	4.7	(14)	
(15) Precipitation	PrecAvg	981	216	286	280	84	9	1	2	2	2	9	35	103	(15)	
	PrecMax	1674	631	574	1214	667	80	9	14	12	23	63	250	372	(16)	
	PrecMin	453	4	4	10	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	349	151	159	298	130	17	2	3	3	4	17	53	86	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.7	36.0	35.7	34.2	31.9	29.5	28.7	29.6	32.6	35.0	36.2	36.7	(19)	
		MCWB	26.1	26.7	26.1	24.4	23.9	22.2	21.0	21.3	22.7	23.6	24.9	25.8	(20)	
	2%	DB	35.1	34.7	34.2	33.1	30.7	28.4	27.4	28.5	31.4	33.6	35.0	35.5	(21)	
		MCWB	26.7	26.5	25.8	24.6	23.4	21.8	20.3	20.6	22.8	24.1	25.0	26.3	(22)	
	5%	DB	34.1	33.8	33.3	32.2	29.8	27.3	26.5	27.7	30.5	32.8	34.2	34.7	(23)	
		MCWB	26.9	26.4	25.7	24.5	23.0	21.3	19.7	20.3	22.6	24.2	25.2	26.4	(24)	
	10%	DB	33.2	32.9	32.4	31.4	28.9	26.3	25.5	26.7	29.6	32.0	33.4	33.9	(25)	
		MCWB	26.7	26.4	25.7	24.4	22.6	20.6	19.1	19.7	22.3	24.3	25.3	26.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.1	29.2	28.5	27.5	26.3	24.2	23.2	23.7	25.6	27.1	27.9	28.7	(27)	
		MCDB	32.2	32.9	32.7	30.6	29.9	27.1	26.2	27.2	29.9	31.7	33.8	33.0	(28)	
	2%	WB	29.0	28.2	27.7	26.7	25.5	23.5	22.4	23.0	24.8	26.4	27.3	28.0	(29)	
		MCDB	31.8	32.3	32.0	29.8	28.5	26.2	25.0	26.1	28.8	31.0	32.5	32.9	(30)	
	5%	WB	28.1	27.6	27.2	26.3	24.9	22.9	21.7	22.4	24.3	25.9	26.9	27.5	(31)	
		MCDB	32.1	31.7	31.1	29.5	27.8	25.4	24.2	25.2	28.0	30.4	31.7	32.3	(32)	
	10%	WB	27.5	27.2	26.8	25.9	24.3	22.3	21.1	21.8	23.8	25.5	26.5	27.1	(33)	
		MCDB	31.6	31.2	30.5	29.3	27.3	24.9	23.6	24.4	27.4	29.7	31.1	31.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	5.4	5.4	5.5	5.9	6.1	6.6	7.2	7.2	7.0	6.8	6.1	(35)	
		MCDBR	6.7	6.4	6.5	6.4	6.3	6.5	7.1	7.7	7.7	7.6	7.4	6.9	(36)	
	5% WB	MCWBR	2.6	2.4	2.7	2.7	3.2	3.5	3.7	3.6	2.9	2.9	2.7	2.3	(37)	
		MCWBR	6.2	5.9	5.8	5.3	5.5	5.9	6.3	6.9	7.0	6.9	6.8	6.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.412	0.403	0.387	0.378	0.357	0.341	0.326	0.332	0.381	0.408	0.426	0.425	(40)	
		taud	2.523	2.550	2.594	2.578	2.581	2.575	2.621	2.582	2.452	2.404	2.407	2.454	(41)	
	Ebn at Noon		933	933	927	901	888	885	911	933	919	917	914	920	(42)	
		Edh at Noon	113	109	101	97	91	88	86	95	115	125	126	121	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.78	5.79	5.64	5.60	5.14	4.81	5.14	5.93	6.74	7.09	6.94	6.34	(44)	
	RadStd		0.65	0.83	0.65	0.49	0.28	0.28	0.14	0.16	0.23	0.36	0.35	0.64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page