

CAMOOWEAL TOWNSHIP, Australia

WMO: 942550

Lat: 19.9223S

Lon: 138.1215E

Elev: 232

StdP: 98.57

Time Zone: 10.00 (E10)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.8	7.5	-11.1	1.5	21.0	-9.5	1.7	20.5	9.5	19.9	9.0	20.3	2.4	210	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.4	41.1	20.3	40.0	20.1	39.0	20.2	25.8	31.0	25.3	30.5	24.9	30.1	4.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	20.3	27.3	24.2	19.6	27.2	23.6	18.9	27.2	81.3	31.0	79.3	30.4	77.3	29.9	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.2	8.3	7.5	DB	2.6	42.9	1.1	1.5	1.8	43.9	1.2	44.8	0.6	45.6	-0.2	46.6	(4)
(5)			WB	-0.7	26.5	1.0	0.7	-1.4	27.0	-2.0	27.4	-2.6	27.7	-3.3	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	30.6	30.0	28.9	26.3	21.7	18.0	18.0	19.8	24.7	28.0	30.1	31.2	(6)	
	DBStd	5.66	2.61	2.38	2.34	2.73	3.44	3.44	3.21	3.37	3.46	3.19	2.71	2.75	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	129	0	0	0	1	11	48	46	22	2	0	0	0	(9)	
	CDD10.0	5688	637	559	586	488	362	241	249	305	441	558	603	658	(10)	
	CDD18.3	2776	379	326	327	239	114	39	37	69	192	301	353	399	(11)	
	CDH23.3	38626	5241	4407	4297	2986	1322	508	574	1102	2667	4373	5209	5941	(12)	
(13)	CDH26.7	22014	3090	2542	2408	1584	528	139	151	427	1455	2671	3259	3761	(13)	
(14)	Wind	WSAvg	3.9	3.6	3.7	3.6	3.7	3.9	4.0	3.9	4.0	4.1	3.9	3.8	(14)	
(15) Precipitation	PrecAvg	392	108	96	55	14	13	5	6	2	8	14	26	60	(15)	
	PrecMax	1003	593	385	248	174	73	57	77	29	77	81	85	258	(16)	
	PrecMin	150	0	3	0	0	0	0	0	0	0	0	0	5	(17)	
	PrecStd	191	118	87	55	31	21	11	16	5	15	19	23	48	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	41.4	39.9	37.2	34.3	31.5	31.5	34.5	38.0	40.5	41.5	42.8	(19)	
		MCWB	21.3	21.0	21.1	19.7	18.9	17.8	17.5	17.3	18.0	18.8	19.4	20.5	(20)	
	2%	DB	40.2	39.5	38.2	36.0	32.6	29.9	29.7	32.6	36.6	39.2	40.2	41.2	(21)	
		MCWB	21.2	20.9	21.1	19.2	17.9	17.2	15.9	16.5	17.5	18.5	19.4	20.3	(22)	
	5%	DB	38.9	38.1	36.9	34.9	31.4	28.3	28.4	31.0	35.2	37.9	39.0	40.0	(23)	
		MCWB	21.5	21.2	21.0	19.1	17.4	16.0	15.0	15.5	17.0	18.4	19.4	20.2	(24)	
	10%	DB	37.3	36.8	35.6	33.7	29.9	26.5	26.9	29.1	33.9	36.6	37.8	38.6	(25)	
		MCWB	21.8	21.4	20.9	18.9	16.6	14.9	14.2	14.4	16.5	17.9	19.3	20.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.2	25.6	24.0	22.5	19.6	19.8	19.4	21.2	23.0	24.5	25.8	(27)	
		MCDB	32.2	31.4	31.1	30.1	28.6	27.9	27.6	28.9	29.7	31.4	31.4	30.7	(28)	
	2%	WB	25.9	25.7	25.0	23.0	20.6	18.5	17.9	18.0	19.9	21.9	23.8	25.1	(29)	
		MCDB	31.1	30.9	30.4	28.8	28.0	26.9	26.6	29.2	29.8	30.6	31.0	30.3	(30)	
	5%	WB	25.4	25.3	24.4	22.2	19.1	17.4	16.3	16.6	18.8	20.8	23.2	24.6	(31)	
		MCDB	30.5	30.4	29.8	29.4	28.4	25.6	26.2	29.0	30.8	31.3	30.4	30.2	(32)	
	10%	WB	24.8	24.8	23.8	21.2	17.9	16.2	15.0	15.3	17.7	19.9	22.6	24.0	(33)	
		MCDB	30.0	29.9	29.2	29.5	27.8	24.7	25.2	28.0	31.0	31.6	30.4	30.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	11.6	12.2	13.8	14.6	15.4	16.3	17.0	16.3	15.5	14.0	12.4	(35)	
		MCDBR	14.0	14.3	14.4	15.3	15.3	16.4	17.3	17.9	16.9	16.7	15.5	14.9	(36)	
	5% WB	MCWBR	4.3	4.3	4.6	5.4	6.3	7.3	7.9	7.7	6.5	6.2	5.1	4.9	(37)	
		MCWBR	10.0	9.9	10.3	11.2	12.7	13.8	14.9	15.8	14.2	13.1	12.3	10.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.397	0.399	0.376	0.357	0.343	0.322	0.325	0.339	0.379	0.397	0.416	0.415	(40)	
		taud	2.451	2.435	2.479	2.472	2.452	2.481	2.444	2.384	2.303	2.280	2.300	2.353	(41)	
	Ebn at Noon	Ebn at Noon	948	934	932	911	885	888	895	915	914	925	924	932	(42)	
		Edh at Noon	122	122	112	105	99	92	98	113	131	140	140	134	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.76	6.82	6.40	5.82	4.95	4.56	4.91	5.80	6.70	7.27	7.29	7.05	(44)	
	RadStd	RadStd	0.62	0.52	0.52	0.43	0.29	0.27	0.22	0.21	0.37	0.51	0.36	0.58	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page