

BURKETOWN, AustraliaWMO: **942600**Lat: **17.7483S**Lon: **139.5356E**Elev: **21**StdP: **14.68**Time Zone: **10.00 (E10)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	53.2	55.5	18.3	13.8	75.2	21.8	16.4	72.8	23.5	68.3	22.3	68.8	8.7	180	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	16.0	100.0	72.5	97.9	73.7	96.2	74.4	82.3	89.4	81.5	88.7	80.8	88.0	11.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.0	84.9	79.9	155.3	84.3	79.1	151.2	83.9	46.2	89.5	45.3	88.9	44.5	87.9	89.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	19.7	17.9	48.6	104.4	2.4	2.2	46.9	106.0	45.5	107.3	44.2	108.6	42.5	110.2		
(5)			39.6	85.2	1.5	2.0	38.5	86.6	37.6	87.8	36.7	88.9	35.6	90.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	84.8	84.4	83.9	81.5	76.1	71.7	71.0	72.6	78.0	82.7	85.3	86.2		
	DBStd	6.55	3.49	3.08	2.83	3.17	4.34	4.93	4.21	3.76	3.48	3.10	2.71	3.35		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	13	0	0	0	0	0	8	4	1	0	0	0	0		
	CDD50	10883	1079	963	1050	945	811	650	651	700	839	1014	1058	1123		
	CDD65	5421	614	543	585	495	346	208	190	236	389	549	608	658		
	CDH74	62802	7707	6648	6974	5395	3140	1616	1551	2177	4063	6677	7997	8857		
(13)	CDH80	29579	3653	3056	3219	2555	1256	452	405	714	1838	3452	4241	4738		
(14)	Wind	WSAvg	8.9	8.0	7.7	7.5	7.9	8.9	10.0	9.6	9.8	9.6	9.5	9.1		
(15) Precipitation	PrecAvg	29.6	7.9	8.4	6.4	0.7	0.3	0.2	0.1	0.0	0.1	0.5	1.7	4.4		
	PrecMax	78.0	23.7	24.3	25.6	3.2	4.0	2.7	2.2	0.2	1.0	2.9	9.3	35.7		
	PrecMin	10.4	0.5	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1		
	PrecStd	14.5	6.2	6.4	6.7	0.9	0.8	0.5	0.4	0.0	0.2	0.7	1.9	5.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.8	99.2	99.9	96.6	93.2	89.2	89.1	91.6	96.4	100.8	102.0	103.0		
		MCWB	75.9	76.3	74.5	71.7	69.5	67.5	66.7	63.2	64.5	67.7	68.6	71.9		
	2%	DB	97.4	96.4	96.5	94.5	90.6	86.7	86.3	88.4	93.3	97.4	98.8	99.5		
		MCWB	77.5	77.2	75.2	71.5	69.1	66.6	64.8	63.7	66.9	68.4	71.0	74.6		
	5%	DB	94.9	94.3	94.2	92.6	88.8	84.8	84.2	86.2	90.9	94.9	96.3	97.1		
		MCWB	78.7	77.9	75.8	72.1	68.6	66.0	64.2	62.9	67.0	70.3	72.9	76.3		
	10%	DB	92.5	92.1	92.1	90.9	86.9	82.8	82.0	84.0	88.8	92.7	94.1	94.8		
		MCWB	78.8	78.7	76.0	72.0	68.0	64.7	63.0	62.8	67.0	71.4	74.7	76.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.9	83.6	82.4	81.2	76.8	72.9	71.5	72.4	76.3	79.2	81.6	82.4		
		MCDB	91.9	90.4	89.3	85.4	86.3	82.1	83.8	83.2	85.2	89.3	91.4	90.5		
	2%	WB	82.2	82.1	81.0	79.0	74.5	70.8	69.3	70.5	74.8	77.9	80.2	81.2		
		MCDB	89.5	88.8	87.6	85.5	83.5	81.3	80.7	81.3	85.0	88.3	89.7	89.5		
	5%	WB	81.4	81.3	80.1	77.7	72.9	68.9	67.6	68.5	73.6	77.0	79.3	80.5		
		MCDB	88.6	87.9	86.6	84.6	82.0	80.3	79.2	79.5	84.3	87.3	89.0	88.9		
	10%	WB	80.6	80.6	79.4	76.5	71.2	67.2	65.6	66.7	72.3	76.1	78.4	79.8		
		MCDB	87.8	87.1	85.8	83.8	82.2	79.5	78.1	78.1	82.7	86.3	88.2	88.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	13.8	15.7	19.3	21.4	21.5	22.7	23.9	22.7	21.0	18.5	16.0		
		MCDBR	18.4	18.5	20.1	21.5	22.3	22.0	24.0	25.7	25.0	24.0	22.6	20.6		
		MCWBR	5.7	5.5	6.6	8.2	9.5	10.4	11.2	10.9	10.4	9.4	8.7	6.5		
	5% WB	MCDBR	14.4	13.9	14.9	15.9	18.4	19.6	20.8	22.1	20.4	19.3	18.1	15.9		
		MCWBR	5.3	5.2	5.4	6.7	9.4	10.1	11.3	11.1	8.6	7.6	6.7	5.5		
(40) Clear-Sky Solar Irradiance	taub		0.414	0.412	0.391	0.367	0.351	0.332	0.331	0.346	0.393	0.414	0.433	0.435		
	taud		2.480	2.482	2.531	2.552	2.522	2.535	2.519	2.456	2.349	2.330	2.337	2.374		
	Ebn at Noon		296	293	292	288	281	281	285	290	287	289	288	289		
	Edh at Noon		37	37	34	31	30	29	30	34	40	43	43	42		
(44) All-Sky Solar Radiation	RadAvg		1813	1884	1891	1820	1587	1466	1573	1830	2128	2270	2176	2036		
	RadStd		227	228	186	148	81	99	46	57	83	134	141	205		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page