

BURKETOWN, AustraliaWMO: **942600**Lat: **17.7483S**Lon: **139.5356E**Elev: **6**StdP: **101.25**Time Zone: **10.00 (E10)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	13.1	-7.6	2.0	24.0	-5.6	2.3	22.7	10.5	20.2	10.0	20.5	3.9	180	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.9	37.8	22.5	36.6	23.2	35.7	23.5	27.9	31.9	27.5	31.5	27.1	31.1	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.9	29.4	26.6	22.2	29.1	26.2	21.6	28.8	89.6	31.9	87.5	31.6	85.7	31.0	31.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.7	8.8	8.0	DB	9.2	40.2	1.3	1.2	8.3	41.1	7.5	41.9	6.8	42.6	5.8	43.5
			WB	4.2	29.6	0.8	1.1	3.6	30.3	3.1	31.0	2.6	31.6	2.0	32.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	29.3	29.1	28.8	27.5	24.5	22.0	21.7	22.5	25.5	28.2	29.6	30.1
	DBStd	3.64	1.94	1.71	1.57	1.76	2.41	2.74	2.34	2.09	1.93	1.72	1.51	1.86
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	7	0	0	0	0	0	4	2	1	0	0	0	0
	CDD10.0	6046	599	535	583	525	451	361	362	389	466	563	588	624
	CDD18.3	3012	341	302	325	275	192	116	106	131	216	305	338	366
	CDH23.3	34890	4282	3693	3874	2997	1744	898	862	1209	2257	3709	4443	4921
	CDH26.7	16433	2029	1698	1788	1419	698	251	225	397	1021	1918	2356	2632
(14) Wind	WSAvg	4.0	3.6	3.4	3.3	3.5	4.0	4.4	4.3	4.4	4.3	4.3	4.3	4.1
(15) Precipitation	PrecAvg	753	201	214	162	18	8	4	3	0	2	13	43	111
	PrecMax	1981	601	616	651	82	102	68	55	5	25	73	235	907
	PrecMin	264	12	10	0	0	0	0	0	0	0	0	0	2
	PrecStd	369	157	162	169	23	20	13	10	1	5	19	48	145
	PrecMax	1981	601	616	651	82	102	68	55	5	25	73	235	907
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	38.2	37.4	37.7	35.9	34.0	31.8	31.7	33.1	35.8	38.2	38.9	39.4	39.4
	0.4% MCWB	24.4	24.6	23.6	22.0	20.9	19.7	19.3	17.3	18.0	19.8	20.4	22.2	22.2
	2% DB	36.3	35.8	35.8	34.7	32.6	30.4	30.2	31.3	34.1	36.3	37.1	37.5	37.5
	2% MCWB	25.3	25.1	24.0	22.0	20.6	19.2	18.2	17.6	19.4	20.2	21.7	23.7	23.7
	5% DB	34.9	34.6	34.5	33.7	31.6	29.3	29.0	30.1	32.7	34.9	35.7	36.2	36.2
	5% MCWB	25.9	25.5	24.3	22.3	20.4	18.9	17.9	17.2	19.5	21.3	22.7	24.6	24.6
	10% DB	33.6	33.4	33.4	32.7	30.5	28.2	27.8	28.9	31.5	33.7	34.5	34.9	34.9
	10% MCWB	26.0	25.9	24.5	22.2	20.0	18.1	17.2	17.1	19.5	21.9	23.7	24.9	24.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	28.8	28.7	28.0	27.3	24.9	22.7	21.9	22.4	24.6	26.2	27.6	28.0	28.0
	0.4% MCDB	33.3	32.5	31.8	29.7	30.1	27.8	28.8	28.4	29.5	31.8	33.0	32.5	32.5
	2% WB	27.9	27.8	27.2	26.1	23.6	21.5	20.7	21.4	23.8	25.5	26.8	27.3	27.3
	2% MCDB	31.9	31.5	30.9	29.7	28.6	27.4	27.0	27.4	29.4	31.3	32.0	32.0	32.0
	5% WB	27.4	27.4	26.7	25.4	22.7	20.5	19.8	20.3	23.1	25.0	26.3	26.9	26.9
	5% MCDB	31.4	31.0	30.3	29.2	27.8	26.8	26.2	26.4	29.1	30.7	31.7	31.6	31.6
	10% WB	27.0	27.0	26.3	24.7	21.8	19.5	18.7	19.3	22.4	24.5	25.8	26.5	26.5
	10% MCDB	31.0	30.6	29.9	28.8	27.9	26.4	25.6	25.6	28.1	30.2	31.2	31.3	31.3
(35) Mean Daily Temperature Range	MDBR	7.5	7.7	8.7	10.7	11.9	11.9	12.6	13.3	12.6	11.7	10.3	8.9	8.9
	5% DB	10.2	10.3	11.2	11.9	12.4	12.2	13.3	14.3	13.9	13.3	12.5	11.4	11.4
	MCDBR	3.2	3.1	3.6	4.5	5.3	5.8	6.2	6.1	5.8	5.2	4.8	3.6	3.6
	5% WB	8.0	7.7	8.3	8.9	10.2	10.9	11.5	12.3	11.4	10.7	10.0	8.8	8.8
	MCWBR	2.9	2.9	3.0	3.7	5.2	5.6	6.3	6.2	4.8	4.2	3.7	3.0	3.0
(40) Clear-Sky Solar Irradiance	taub	0.414	0.412	0.391	0.367	0.351	0.332	0.331	0.346	0.393	0.414	0.433	0.435	0.435
	taud	2.480	2.482	2.531	2.552	2.522	2.535	2.519	2.456	2.349	2.330	2.337	2.374	2.374
	Ebn at Noon	932	923	921	907	886	887	898	914	905	911	908	912	912
	Edh at Noon	118	116	107	98	94	90	93	106	126	134	135	131	131
	RadAvg	5.72	5.94	5.96	5.74	5.00	4.62	4.96	5.77	6.71	7.16	6.86	6.42	6.42
(45) All-Sky Solar Radiation	RadStd	0.71	0.72	0.59	0.47	0.26	0.31	0.14	0.18	0.26	0.42	0.44	0.65	0.65

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page