

GEORGETOWN AP, Australia

WMO: 942740

Lat: 18.3039S

Lon: 143.5306E

Elev: 303

StdP: 97.74

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	11.0	-7.5	2.1	23.6	-4.9	2.6	22.6	8.0	21.0	7.2	21.4	1.5	190	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.3	38.0	20.2	36.9	20.2	36.0	20.4	25.8	30.6	25.3	30.1	24.9	29.7	3.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	20.4	27.7	24.1	19.8	27.3	23.6	19.2	27.0	81.9	30.8	79.6	30.2	77.7	29.7	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.3	6.6	6.1	5.4	40.0	2.6	1.3	3.5	40.9	2.0	41.7	0.6	42.4	-1.3	43.3
			2.5	26.9	2.2	0.7	1.0	27.4	-0.3	27.9	-1.5	28.3	-3.1	28.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.7	28.2	27.8	27.4	25.7	23.5	21.2	21.0	22.0	25.0	27.8	29.4	29.7
	DBStd	3.64	1.75	1.46	1.39	1.76	2.43	2.55	2.50	2.41	2.14	1.95	1.70	1.82
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	17	0	0	0	0	1	7	6	3	0	0	0	0
	CDD10.0	5731	564	497	539	472	417	337	339	372	451	551	581	611
	CDD18.3	2707	306	264	281	222	160	94	88	116	201	292	331	353
	CDH23.3	31098	3458	2842	2956	2241	1364	756	783	1263	2479	3841	4441	4673
	CDH26.7	14750	1603	1270	1297	921	434	159	170	423	1217	2138	2520	2598
Wind	WSAvg	3.0	2.8	2.6	2.8	3.0	3.1	2.9	2.9	2.9	3.2	3.6	3.4	3.2
Precipitation	PrecAvg	812	229	210	120	28	10	6	4	3	4	17	56	115
	PrecMax	2046	779	527	455	219	59	76	38	50	41	140	314	306
	PrecMin	368	41	21	0	0	0	0	0	0	0	0	0	8
	PrecStd	297	173	121	109	41	15	14	10	8	9	26	61	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.9	36.2	35.8	34.2	33.0	30.9	31.2	33.7	36.1	38.2	38.9	39.5
		MCWB	22.5	22.4	22.0	21.2	19.9	19.5	18.5	18.5	17.8	18.9	20.2	20.2
	2%	DB	36.0	34.8	34.3	33.0	31.5	29.5	29.6	31.9	34.8	37.0	37.6	38.1
		MCWB	22.2	22.8	22.4	21.2	19.6	18.5	18.1	17.6	17.7	18.8	19.9	20.5
	5%	DB	34.5	33.8	33.3	32.0	30.3	28.5	28.5	30.4	33.6	35.9	36.6	36.9
		MCWB	22.6	23.1	22.6	20.8	19.3	18.1	17.5	16.9	17.7	18.9	19.9	21.0
	10%	DB	33.1	32.7	32.3	31.1	29.2	27.4	27.4	29.1	32.5	34.8	35.6	35.7
		MCWB	23.3	23.3	22.7	20.6	18.8	17.5	16.8	16.3	17.4	18.8	20.0	21.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.4	25.7	24.6	22.4	20.8	21.3	20.6	22.1	22.6	24.3	26.0
		MCDB	31.4	30.7	30.7	29.4	28.9	28.3	26.2	29.4	30.5	30.5	30.8	31.2
	2%	WB	25.9	25.7	25.0	23.9	21.6	20.1	19.7	19.6	21.1	21.7	23.6	25.0
		MCDB	30.7	30.3	29.9	28.6	28.4	27.5	26.7	28.3	29.3	30.0	30.3	30.9
	5%	WB	25.4	25.2	24.6	23.1	20.9	19.3	18.9	18.7	20.1	21.1	23.1	24.4
		MCDB	30.0	29.9	29.3	28.7	27.4	26.5	26.2	27.5	28.7	30.3	30.1	30.3
	10%	WB	24.9	24.7	24.1	22.2	20.1	18.6	18.2	17.7	19.2	20.5	22.5	23.9
		MCDB	29.4	29.4	28.8	28.5	26.8	25.5	25.4	26.7	29.0	30.3	30.0	29.9
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.4	9.8	11.4	11.9	12.8	13.5	14.6	15.1	14.1	12.5	11.3
		MCDBR	12.0	11.5	11.8	12.5	12.7	13.5	14.2	15.8	16.3	15.5	13.7	13.5
		MCWBR	3.1	3.4	3.5	4.0	4.4	5.1	5.1	5.8	5.4	4.7	4.0	3.7
	5% WB	MCDBR	8.4	8.7	8.8	9.3	10.1	11.3	11.6	13.0	12.5	12.5	10.7	9.7
		MCWBR	3.6	3.7	3.0	3.3	3.8	4.5	4.2	4.8	4.2	3.7	3.0	3.1
Clear-Sky Solar Irradiance	taub	0.385	0.384	0.360	0.341	0.322	0.312	0.303	0.318	0.356	0.388	0.408	0.411	
	taud	2.536	2.541	2.605	2.624	2.622	2.617	2.633	2.554	2.440	2.375	2.364	2.404	
	Ebn at Noon	959	950	951	932	917	908	928	942	939	935	931	935	
	Edh at Noon	112	110	99	91	85	82	83	96	115	128	132	127	
All-Sky Solar Radiation	RadAvg	6.43	6.41	6.18	5.76	5.00	4.60	5.01	5.86	6.80	7.30	7.39	6.97	
	RadStd	0.49	0.55	0.50	0.39	0.26	0.34	0.20	0.25	0.26	0.41	0.46	0.61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page