

GEORGETOWN, Australia

WMO: 942750

Lat: 18.300S

Lon: 143.550E

Elev: 968

StdP: 14.19

Time Zone: 10.00 (E10)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	46.5	50.6	27.9	22.6	66.2	31.2	26.4	64.7	26.3	60.4	20.3	67.5	2.4	200	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	24.7	101.4	71.6	99.5	71.6	97.7	71.7	79.2	89.7	78.5	88.8	77.9	87.9	5.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.0	145.7	82.8	76.2	141.6	82.2	75.4	138.1	81.6	43.7	89.6	42.9	88.9	42.2	88.3	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	16.2	14.8	40.0	105.1	4.1	2.4	37.1	106.8	34.7	108.2	32.4	109.5	29.4	111.2		
(5)			35.6	82.0	3.4	1.4	33.2	82.9	31.2	83.7	29.3	84.5	26.9	85.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.6	84.0	83.3	81.6	79.4	74.5	70.2	68.6	70.9	77.7	83.0	85.3	85.3
	DBStd	6.96	3.29	2.57	2.50	3.05	4.26	4.59	4.36	4.51	3.98	3.40	3.13	3.63
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	44	0	0	0	0	1	16	19	8	0	0	0	0
	CDD50	10452	1054	933	980	882	759	606	578	649	832	1024	1060	1095
	CDD65	5021	589	513	515	432	296	171	132	192	382	559	610	630
	CDH74	57874	6856	5774	5596	4534	2605	1334	1265	1976	4608	7123	8239	7964
	CDH80	28107	3403	2642	2511	2001	865	284	244	588	2373	4025	4836	4335
(14) Wind	WSAvg	4.6	4.0	3.8	4.4	5.0	4.5	4.7	4.5	5.0	5.3	5.1	4.7	4.4
(15) Precipitation	PrecAvg	32.0	9.0	8.3	4.7	1.1	0.4	0.2	0.2	0.1	0.2	0.7	2.2	4.5
	PrecMax	80.6	30.7	20.7	17.9	8.6	2.3	3.0	1.5	2.0	1.6	5.5	12.4	12.0
	PrecMin	14.5	1.6	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
	PrecStd	11.7	6.8	4.8	4.3	1.6	0.6	0.6	0.4	0.3	0.4	1.0	2.4	2.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.7	97.8	95.6	95.1	90.7	87.9	87.5	91.3	98.0	102.6	103.8	102.6
		MCWB	73.7	75.4	74.8	72.8	70.9	67.2	66.2	66.7	67.1	69.5	70.7	73.2
	2%	DB	98.7	95.9	93.4	93.0	88.6	85.3	84.8	88.0	95.6	100.0	101.1	100.6
		MCWB	74.2	75.7	74.5	72.0	69.6	67.1	64.8	66.5	66.7	70.0	70.8	72.9
	5%	DB	95.7	94.3	91.9	91.1	86.8	83.3	82.7	85.8	93.5	97.8	99.3	98.4
		MCWB	75.0	75.8	74.0	70.8	68.6	66.0	63.5	65.2	66.7	69.9	70.6	73.5
	10%	DB	93.4	92.2	90.5	89.4	85.0	81.4	80.8	83.8	91.4	95.7	97.2	96.1
		MCWB	75.4	75.9	73.2	70.1	67.7	64.9	62.6	63.7	66.8	69.4	70.8	73.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	80.4	80.0	77.1	74.9	71.1	68.9	70.2	74.2	78.4	78.6	79.0
		MCDB	91.8	90.5	89.6	86.6	87.4	83.4	83.7	85.1	89.2	93.7	93.1	91.4
	2%	WB	79.0	79.2	78.3	75.6	72.5	69.0	67.1	68.3	71.7	74.7	76.8	78.0
		MCDB	90.1	88.6	87.5	86.0	84.1	81.3	81.4	84.4	88.8	90.2	90.1	90.3
	5%	WB	78.2	78.5	77.3	74.6	71.0	67.7	65.6	67.0	70.2	73.4	75.6	77.2
		MCDB	88.7	87.5	85.9	85.4	82.7	80.0	79.4	82.8	86.8	88.5	89.5	89.2
	10%	WB	77.4	77.8	76.3	73.3	69.8	66.4	64.2	65.6	68.8	72.2	74.6	76.4
		MCDB	87.4	86.7	84.7	84.4	81.6	78.5	77.8	80.7	85.5	88.3	89.0	88.0
(35) Mean Daily Temperature Range	5% DB	MDBR	18.2	17.0	18.7	20.6	21.9	22.1	25.6	26.2	28.4	25.9	24.7	20.2
		MCDBR	22.3	21.0	21.1	23.0	23.8	24.2	27.4	28.3	30.6	29.4	28.0	24.3
		MCWBR	5.9	6.1	6.5	7.1	8.9	9.8	11.6	11.3	10.6	9.8	8.4	6.4
	5% WB	MCDBR	17.5	16.4	16.7	18.6	18.6	20.9	24.2	22.9	24.7	23.2	21.5	18.6
		MCWBR	5.7	5.7	6.1	6.7	7.4	8.6	10.4	9.5	10.0	9.1	6.7	5.7
(40) Clear-Sky Solar Irradiance	taub		0.385	0.384	0.360	0.342	0.322	0.312	0.303	0.319	0.356	0.388	0.409	0.411
	taud		2.535	2.540	2.604	2.623	2.622	2.616	2.632	2.554	2.439	2.374	2.364	2.402
	Ebn at Noon		304	301	301	296	291	288	294	298	298	297	295	296
	Edh at Noon		36	35	31	29	27	26	26	30	36	41	42	40
(44) All-Sky Solar Radiation	RadAvg		2040	2032	1959	1826	1586	1457	1588	1859	2157	2314	2344	2211
	RadStd		154	175	159	125	83	110	63	79	82	130	148	193

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page