

LOW ISLES LH, Australia

WMO: 942850

Lat: 16.3842S

Lon: 145.5592E

Elev: 13

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	67.3	68.2	53.3	60.5	70.7	55.5	65.7	70.6	32.2	71.4	30.7	71.8	15.3	160	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	92.6	80.6	91.0	79.8	89.6	78.9	82.2	89.3	81.4	88.0	80.7	86.7	10.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.1	85.7	79.6	153.8	84.9	79.0	150.4	84.3	46.1	89.6	45.2	88.3	44.4	87.1	94.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.1	27.8	25.7	65.4	95.6	1.8	1.6	64.1	96.8	63.0	97.7	62.0	98.6	60.7	99.7		
(5)			58.0	86.0	1.3	3.5	57.0	88.6	56.2	90.6	55.5	92.6	54.5	95.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.2	83.7	83.4	82.1	79.9	77.2	74.2	73.1	74.3	77.3	79.9	82.0	83.6
	DBStd	4.39	2.53	2.87	2.33	1.95	2.00	2.30	2.00	2.17	2.00	2.01	2.15	2.55
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10657	1045	935	995	897	842	726	716	752	819	927	960	1043
	CDD65	5182	580	515	530	447	377	276	251	287	369	462	510	578
	CDH74	42562	6607	5788	5535	3879	2044	659	380	752	1881	3569	5017	6451
CDH80	11505	2369	2027	1464	558	130	20	5	47	289	832	1455	2309	
Wind	WSAvg	14.9	12.9	12.9	15.5	18.1	17.4	17.2	16.9	15.2	13.7	13.3	12.9	12.3
Precipitation	PrecAvg	89.5	16.6	18.2	17.7	9.7	4.3	2.4	1.5	1.5	1.4	1.9	4.3	8.7
	PrecMax	152.7	84.6	39.4	46.5	25.9	10.6	10.1	7.0	5.6	5.5	10.6	19.4	27.9
	PrecMin	37.7	2.3	2.8	1.1	1.8	0.3	0.1	0.0	0.1	0.0	0.0	0.0	1.8
	PrecStd	23.4	15.1	9.5	11.3	5.6	2.5	2.0	1.3	1.3	1.3	2.2	4.4	6.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.4	94.8	91.9	88.1	85.0	82.1	80.7	83.7	86.4	89.7	92.4	94.0
		MCWB	81.7	81.7	80.6	77.3	75.3	73.9	72.2	72.6	74.0	77.4	79.6	81.0
	2%	DB	92.0	92.2	89.2	85.9	82.8	79.9	78.9	81.2	84.6	87.8	90.0	92.0
		MCWB	80.6	81.0	79.5	77.0	74.1	72.9	70.7	70.9	73.1	76.3	77.7	79.8
	5%	DB	90.1	90.0	87.4	84.3	81.5	78.5	77.4	79.6	83.2	86.2	88.3	90.3
		MCWB	79.9	80.1	78.8	76.4	73.6	72.0	69.9	70.1	72.5	75.0	76.7	78.9
	10%	DB	88.4	88.0	85.8	83.0	80.1	77.3	76.2	78.0	81.6	84.6	86.8	88.6
		MCWB	79.3	79.6	78.1	75.9	73.2	71.5	69.5	69.5	71.9	74.1	75.9	78.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.9	83.4	82.5	80.3	77.4	75.8	74.4	74.7	77.3	79.2	81.6	82.8
		MCDB	90.0	90.9	89.4	84.6	81.9	79.8	78.0	79.7	82.1	86.5	88.5	90.6
	2%	WB	81.9	82.1	80.9	78.9	76.2	74.4	72.9	73.4	75.7	78.0	79.7	81.6
		MCDB	88.7	89.1	87.0	82.7	80.5	78.1	76.4	78.0	81.0	84.5	86.4	88.7
	5%	WB	81.1	81.2	80.0	78.0	75.4	73.5	72.0	72.1	74.5	76.9	78.3	80.6
		MCDB	87.4	87.5	85.2	81.8	79.5	77.3	75.4	77.0	80.1	83.1	85.0	87.3
	10%	WB	80.2	80.4	79.2	77.2	74.5	72.6	71.1	71.0	73.4	75.8	77.5	79.6
		MCDB	86.0	86.0	83.6	81.1	78.7	76.4	74.8	76.1	79.2	81.9	83.8	85.7
Mean Daily Temperature Range	5% DB	MDBR	9.4	8.7	7.3	6.4	5.9	5.6	6.3	8.1	9.6	10.2	10.1	10.0
		MCDBR	11.8	11.4	9.6	7.9	7.5	6.9	7.8	9.9	11.2	11.9	12.3	12.2
		MCWBR	5.0	5.0	4.1	3.6	3.7	3.8	3.8	4.4	4.6	4.5	4.3	4.6
	5% WB	MCDBR	10.8	10.2	8.5	6.8	6.3	6.2	6.2	8.8	10.2	10.9	11.2	11.3
		MCWBR	5.1	5.0	4.2	3.6	3.5	3.8	3.5	4.4	4.7	4.6	4.4	4.9
Clear-Sky Solar Irradiance	taub	0.398	0.396	0.395	0.385	0.370	0.363	0.350	0.357	0.381	0.397	0.401	0.412	
	taud	2.566	2.579	2.567	2.574	2.587	2.594	2.611	2.578	2.490	2.466	2.491	2.489	
	Ebn at Noon	300	298	292	283	277	273	281	288	291	294	297	296	
	Edh at Noon	34	34	33	31	29	27	28	30	35	37	37	37	
All-Sky Solar Radiation	RadAvg	1849	1773	1653	1544	1368	1224	1336	1617	1931	2094	2143	2043	
	RadStd	164	207	134	150	114	104	94	114	91	133	154	229	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page