

LOW ISLES LH, Australia

WMO: 942850

Lat: 16.3842S

Lon: 145.5592E

Elev: 4

StdP: 101.28

Time Zone: 10.00 (E10)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	20.1	11.8	8.6	21.5	13.1	9.4	21.5	14.4	21.9	13.7	22.1	6.8	160	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.2	33.7	27.0	32.8	26.5	32.0	26.1	27.9	31.9	27.5	31.1	27.0	30.4	4.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.6	29.8	26.5	22.0	29.4	26.1	21.5	29.0	89.4	32.0	87.4	31.3	85.4	30.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	12.4	11.5	18.6	35.3	1.0	0.9	17.8	36.0	17.2	36.5	16.7	37.0	16.0	37.6
			14.4	30.0	0.7	2.0	13.9	31.4	13.5	32.6	13.1	33.7	12.5	35.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	28.7	28.6	27.8	26.6	25.1	23.4	22.8	23.5	25.2	26.6	27.8	28.7
	DBStd	2.44	1.41	1.60	1.29	1.08	1.11	1.28	1.11	1.21	1.11	1.12	1.20	1.41
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5921	581	519	553	498	468	403	398	418	455	515	533	579
	CDD18.3	2879	322	286	294	248	209	153	139	159	205	257	283	321
	CDH23.3	23646	3671	3216	3075	2155	1136	366	211	418	1045	1983	2787	3584
(13)	CDH26.7	6392	1316	1126	813	310	72	11	3	26	161	462	808	1283
(14)	Wind	WSAvg	6.7	5.8	5.8	6.9	8.1	7.8	7.5	6.8	6.1	6.0	5.8	5.5
(15) Precipitation	PrecAvg	2273	422	463	449	247	109	61	39	38	36	47	108	221
	PrecMax	3878	2148	1002	1182	659	269	256	179	143	140	269	493	708
	PrecMin	958	58	71	27	46	7	2	0	3	1	0	1	45
	PrecStd	595	383	242	286	142	64	50	34	34	34	55	113	166
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.7	34.9	33.3	31.1	29.5	27.8	27.0	28.7	30.2	32.1	33.6	34.4
		MCWB	27.6	27.6	27.0	25.2	24.1	23.3	22.3	22.5	23.3	25.2	26.5	27.2
	2%	DB	33.3	33.4	31.8	29.9	28.2	26.6	26.0	27.3	29.2	31.0	32.2	33.3
		MCWB	27.0	27.2	26.4	25.0	23.4	22.7	21.5	21.6	22.8	24.6	25.4	26.6
	5%	DB	32.3	32.2	30.8	29.1	27.5	25.8	25.2	26.5	28.4	30.1	31.3	32.4
		MCWB	26.6	26.7	26.0	24.6	23.1	22.2	21.0	21.2	22.5	23.9	24.8	26.0
	10%	DB	31.3	31.1	29.9	28.3	26.7	25.2	24.5	25.6	27.6	29.2	30.4	31.4
		MCWB	26.3	26.4	25.6	24.4	22.9	21.9	20.8	20.8	22.2	23.4	24.4	25.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.3	28.6	28.1	26.8	25.2	24.3	23.6	23.7	25.2	26.2	27.6	28.2
		MCDB	32.2	32.7	31.9	29.2	27.7	26.5	25.5	26.5	27.8	30.3	31.4	32.6
	2%	WB	27.7	27.8	27.2	26.1	24.6	23.6	22.7	23.0	24.3	25.5	26.5	27.5
		MCDB	31.5	31.7	30.5	28.2	27.0	25.6	24.7	25.5	27.2	29.2	30.2	31.5
	5%	WB	27.3	27.4	26.6	25.6	24.1	23.0	22.2	22.3	23.6	25.0	25.7	27.0
		MCDB	30.8	30.8	29.6	27.7	26.4	25.2	24.1	25.0	26.7	28.4	29.4	30.7
	10%	WB	26.8	26.9	26.2	25.1	23.6	22.5	21.7	21.7	23.0	24.3	25.3	26.5
		MCDB	30.0	30.0	28.7	27.3	26.0	24.7	23.8	24.5	26.2	27.7	28.8	29.8
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	4.8	4.1	3.5	3.3	3.1	3.5	4.5	5.4	5.7	5.6	5.6
		MCDBR	6.6	6.4	5.3	4.4	4.1	3.9	4.3	5.5	6.2	6.6	6.8	6.8
		MCWBR	2.8	2.8	2.3	2.0	2.0	2.1	2.1	2.4	2.6	2.5	2.4	2.5
	5% WB	MCDBR	6.0	5.7	4.7	3.8	3.5	3.4	3.5	4.9	5.7	6.0	6.2	6.3
		MCWBR	2.8	2.8	2.3	2.0	1.9	2.1	1.9	2.4	2.6	2.6	2.5	2.7
(40) Clear-Sky Solar Irradiance	taub		0.398	0.396	0.395	0.385	0.370	0.363	0.350	0.357	0.381	0.397	0.401	0.412
	taud		2.566	2.579	2.567	2.574	2.587	2.594	2.611	2.578	2.490	2.466	2.491	2.489
	Ebn at Noon		947	939	920	893	873	862	885	908	918	927	937	932
	Edh at Noon		108	106	104	97	90	86	87	95	110	117	116	117
(44) All-Sky Solar Radiation	RadAvg		5.83	5.59	5.21	4.87	4.31	3.86	4.21	5.10	6.09	6.60	6.75	6.44
	RadStd		0.52	0.65	0.42	0.47	0.36	0.33	0.30	0.36	0.29	0.42	0.48	0.72

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page